

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550	1	4	1	4	1	4			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	1	7	1	7	1	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	3	2	3	2	3			
2	NLG	144	988		3		3		3			
3	MDK	107	933		3		3		3			
4	SDPT			1	6	1	6	1	6			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	15	3	15	3	15	0	0	
	Grand Total	1082	6468	4	22	4	22	4	22	0	0	

TSSPDCL - LMRC / Corporate office

Date: 30.07.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Gadwal	Maldakal	33KV	Gadwal	03.07	09.30	06.23	EL	Insulator Replacement near Eidga at Gadwal	Maldakal	-
2		Balanagar	Nava Durga	33KV	Jadcherla	21.20	21.50	00.30	EL & OL	No visibule fault	Nava Durga	-
1	SDP	Angadikistapur	Jagadevpur	33KV	Gajwel	11.06	12.46	01.40			Insulator Changed	Jagadevpur
1	RR N	132KV LGM Pet	33KV Aliabad	33KV	Medchal	03.45	04.50	01.10	EL	33KV Cable endkit failed	33KV Aliabad	-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 30.07.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Narayanpet	Narayanpet Rural	11KV	Narayanapet	14.15	19.00	04.45		11 KV line fall due to heavy gail	-
2		Chinnajatram	Laxmipur	11KV	Narayanapet	05.30	08.30	03.00		Disc insulator fail on the feeder	-
3		Kotakonda	Bommanpad	11KV	Narayanapet	15.12	17.50	02.38		11 Kv insulator fail	-
1	NLG	Janpahad	Janpahad	11KV	Huzurnagar	04.00	07.00	03.00	EL	11 KV LINE SNAPPED	-
2		Mandollagudem	Prathista Indl	11KV	Choutuppal	06.42	10.46	04.04	EL	11 kv Insulator failed	-
3		Jublakpally	Jublakpally	11KV	Choutuppal	12.46	17.08	04.22	EL	11kv Insulator Failed	-
1	MDK	Dundigal	AFA	11KV	Patancheru	10.20	14.20	04.00		B/D Due to Insulator Failure	-
2		Bollaram - I	Arobindo	11KV	Patancheru	03.10	04.10	01.00		B/D Due to Jumper Cut	-
3		Bollaram - I	Soubagya	11KV	Patancheru	07.25	08.55	01.30		B/D Due to Conductor Snapped	-
1	SDP	P G velly	Balwanthapur	11KV	Siddipet	09.10	11.10	02.00		B/D	-
2		PAMULAPARTHI	INDRANAGAR& PATHUR (LC.NO:25366) CHANDRAM.CL	11KV	Gajwel	14.40	15.30	00.50		11 KV LINE CUT	-
3		SITHARAM PALLY	VELURE (LC.NO:3042) RAMULU.CL	11KV	Gajwel	15.20	16.50	01.30		BIRD FALLEN ON THE 11 KV LINE	-
4		THIPPARAM	THIPPARAM(LC.NO :11512)RAJU OPERATOR	11KV	Gajwel	07.00	08.30	01.30		DISK FAILED	-
5		THIPPARAM	ERRAVALLY TRIPPING	11KV	Gajwel	04.30	12.40	08.10		3 PH LINE NOT STANDING	-
6		POTHARAM	NAGARAM	11KV	Husnabad	10.50	11.20	00.30		SQUIREL DEAD ON THE CONDUCTOR	-
1	RR S	Gachibowli	Aparna	11KV	Gachibowli	19.00	20.25	01.25		11 KV Disk Fail at Raghavendra Apartment	-
2		Chandanagar	Huda Colony	11KV	Gachibowli	20.00	22.10	02.10		11 KV Line Snapped at Majid back Side and 11 KV Jumper cut at SS	-
1	RR N	Jeedimetla SS III	VSP Organics	11KV	Jeedimetla	13.25	14.25	01.00	EL	11kv AB Cable failure opp Mylan Company	-
2		Medchal	Navadurga	11KV	Medchal	20.00	20.40	00.40	EL	Lizard fallen on the 11KV Line at Vidyuth Control	-
3		Devarayamjal	Pothaipally	11KV	Medchal	16.15	18.40	02.25	EL/OL	11KV Line cut and replaced at Pothaipally Village, Bus Bar replaced in SS	-
4		Kolthur	Anantharam	11KV	Medchal	08.00	09.10	01.10	EL/OL	HT Line touched to LT Line at Darmareddy Thota	-
1	HYD N	Clock Tower	Sangeeth	11KV	V	15.30	16.50	01.20	All Indication	R.M.U fault at Opp: SS	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
------	--------	-----------------------	-------------------------	-----	-------------------------	------	----	----------	---------------------	--------------------	------------------------------