

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		5		5		5			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		7		7		7			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>14</b>	<b>0</b>	<b>14</b>	<b>0</b>	<b>14</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		4		4		4			
2	NLG	144	988		6		6		6			
3	MDK	107	933	1	2	1	2	1	2			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>13</b>	<b>1</b>	<b>13</b>	<b>1</b>	<b>13</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>27</b>	<b>1</b>	<b>27</b>	<b>1</b>	<b>27</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 31.07.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Jogipet	Dakur	33KV	Jogipet	16:10	18:30	2:20		Jumper cut	Dakur	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kosgi	Sampally	11KV	Narayanapet	01.00	08.06	07.06		Break Down due to Bush Rod damage	No
2		Salkarpet SS	Reddypally	11KV	Narayanapet	08.20	11.47	03.27		Break Down due to Heavy Gail & Wind	No
3		Marikal	Teeler	11KV	Narayanapet	12.40	13.15	00.35		L-L due to bird fallen	No
4		Appakpally	Jajapur	11KV	Narayanapet	4:40	6:38	1:58		Disc insulator failed	No
1	NLG	Gondiryala	Chimiryala	11KV	Huzurnagar	4:00	6:45	2:45	E/L	11KV Line Snapped	No
2		Penpahad	Anajipuram	11KV	Suryapet	11.25	13.40	02.15	E/L	11KV Insulator failed	No
3		Paladugu	Panakabanda	11KV	Bhongir	12.00	14.20	02.20	EL/OL	11KV Insulator failed near Panakabanda (V)	No
4		Choutuppal	Jublakpally	11KV	Choutuppal	11.25	14.10	02.45	EL/OL	11KV Pin insulator failed near Lingareddy gudem	No
5		Jublakpally	Kanumukula	11KV	Choutuppal	08.04	11.45	03.41	EL/OL	11KV Line snapped near Jublakpally road	No
6		Ramanthapur	vaiikol	11KV	Devarakonda	13:10	13:50	0:40	E/L	11KV Jumper cut	No
1	MDK	EPIP-I	Chaitanya	11KV	Sangareddy	10:00	12:26	2:26		Conductor Snapped	No
2		EPIP-II	Srinivasa Costing	11KV	Sangareddy	15.10	16.10	01.00		Insulator failed	No
1	SDPT	Kodakandla	Akkaram	11KV	Gajwel	4:13	7:52	3:42		LT&11KV Line phase to phase	No
1	RR N	Subhash Nagar	Padma Nagar	11KV	Medchal	14:08	15:35	1:27		63KVA HG Fuse set failed and replaced at Padma Nagar Phase-II	No
2		Subhash Nagar	Salmon Belmor	11KV	Medchal	14.05	15.20	01.15		11KV Disc failed at near by SS	No
3		Subhash Nagar	Jairam Nagar	11KV	Medchal	14.10	16.04	01.54		11KV Jumper cut and replaced at Jeans company	No
4		Subhash Nagar	Suchitra	11KV	Medchal	14.45	16.02	01.17		No visible fault	No
5		GP Pally	Maisammaguda	11KV	Medchal	14:25	15:15	0:50		Tree fallen on the 11KV line at Satyam Computers	No
1	RR E	Nacharam Indore	Sai Baba Temple	11KV	Habsiguda	14:59	16:17	1:18		11KV Pin Insulator failed & 11KV line cut near Sai Baba Temple at Raghavendra Nagar (Due to heavy rain)	No
2		Sainikpuri	Eshwarpuri	11KV	Sainikpuri	14.50	16.28	01.38		Tree branches fallen on 11KV line at Eshwarpuri lake	No
1	HYD N	Prashanth Nagar	Shakthipuram	11KV	VI	07.30	11.20	03.50	EL	Conductor snapped at Rajiv Gandhi Nagar (13:02Hrs 4No DTR's charged)	No
2		Marredpally	Military Hospital	11KV	C-VI	14:00	16:00	2:00	EL,OL-R&Bph	Tree branches fallen on lines at Military Hospital	No
3		Tirumalagiri	Chinna Kamela	11KV	C-VI	16:45	19:00	2:15	EL,OL-R&Bph	Tree branches fallen on lines at Post Office & 1No. Pole damaged	No
4		Pragatools	Eshwar Vimal	11KV	VI	17:46	20:23	2:37	EL,OL	Conductor snapped at Plot No.99, Gandhi Nagar	No
1	HYD S	Falaknuma	Jangammet OH	11KV	III	17.15	18.30	01.15	EL	Cable Jumper buntout and touching to Channel at Jangammet	No
1	HYD C	Toli Chowki	Paramount Colony	11KV	VII	03.34	04.45	01.11	EL,OL-Rph	Twisted Lines at Paramount Colony	No
2		Golconda	Darga UG	11KV	VII	21.15	22.32	01.17	EL,OL	Cable fault at Palama Hotel	21:50 Hrs (5no DTR Kept off) Arranged partial loads on 11KV Narayanamma College fdr