

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		4		4		4			
6	RR(N)	54	550		5		5		5			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		10		10		10			
	Total	606	3055	0	20	0	20	0	20	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	14	5	11	5	11	5	3		3 Nos. 33KV Still
2	NLG	144	988	1	18	1	18	1	18			
3	MDK	107	933	2	10	2	10	2	10			
4	SDPT			1	9	1	9	1	9			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	18	42	15	42	15	42	3	0	
	Grand Total	1082	6468	18	62	15	62	15	62	3	0	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged	
1	MBNR	Makthal	Narva	33KV	Narayanapet	0:35	7:00	6:25	E/L & O/L	Due to Insulator damaged	Narva	Alternate Supply Arranged from 33KV Eklaspur	
2		Makthal	Paspula	33KV	Narayanapet	0:45	6:45	6:00	E/L & O/L	No Visible Fault due to Heavy Wind Gale & Rain	Paspula	No	
3		Makthal	Paspula	33KV	Narayanapet	23:50			E/L	Not Rectified Due to Rain	Paspula	No	
4		Puttapad	Salkarpet	33KV	Narayanapet	23:10				Not Rectified Due to Rain	Salkarpet	No	
5		Puttapad	Nancherla	33KV	Narayanapet	23:30	2:30	3:00			Due to Rain	Nancherla	Alternate Supply Arranged from 33KV Hanwada feeder
6		Marikal	Eklaspur	33KV	Narayanapet	0:40	7:50	7:10	E/L	Due to Heavy Wind Gale & Rain & Tree Fallen on the Line at Eklaspur	Eklaspur	No	
7		Midjil	Madaram	33KV	Jadcherla	23:10				Not Rectified Due to Rain	Madaram	No	
8		Nagarkurnool	Rakonda	33KV	Nagarkurnool	11:53	13:45	1:52	E/L	Insulator Failed at Chinnamudunoor Gate	Rakonda	No	
9		Wanaparthy	Rajapur	33KV	Wanaparthy	3:05	10:52	7:47	E/L & O/L	Flash Over Disc Replacement at Line	Rajapur	No	
10		Wanaparthy	Gopalpet	33KV	Wanaparthy	18:56	21:32	2:36	O/L	Tree Removing on the Line	Gopalpet	No	
11		Ghanapur	Solipur	33KV	Wanaparthy	1:22	6:58	5:36	E/L	No Visible Fault due to Heavy Wind Gale & Rain	Solipur	No	
12		Ghanapur	Kamaludinnpur	33KV	Wanaparthy	1:22	6:58	5:36	E/L	No Visible Fault due to Heavy Wind Gale & Rain	Kamaludinnpur	No	
13		leeza	Venkatapuram	33KV	Gadwal	3:30	10:50	7:20	E/L	No Visible Fault due to Heavy Wind Gale & Rain & Tree cutting	Venkatapuram	No	
14		leeza	Maddelabanda	33KV	Gadwal	3:30	10:20	6:50	E/L	Due to Heavy Wind Gale & Rain & Insulator Failed near SBI Bank at leeza	Maddelabanda	No	
1	NLG	Ramannapet	Chityala	33KV	Nalgonda	8:00	11:00	3:00	EL	LAS Failed at 33/11KV Chityala SS	Chityala	No	
1	MDK	Narayankhed	Kalheer	33KV	Jogipet	3:25	8:13	4:48		Pin Insulator failure	Kalheer	No	
2		Singoor	Mudimanik	33KV	Jogipet	03.15	07.30	04.15		Insulator failure	Mudimanik	No	
1	SDPT	Siddipet	Rangadampally	33KV	Siddipet	5:20	6:40	1:20		Tree branches fallen on the line	Rangadampally	No	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	K V Pet	Bandameedipally	11KV	Jadcherla	00.30	07.30	07.00		11KV Jumper cut near Bandameedipally (V)	No
2		Nawabpet	Kondapur	11KV	Jadcherla	02.00	07.10	05.10		Tree fallen on the 11KV line near Kondapur (V)	No
3		Nawabpet	Lokirev	11KV	Jadcherla	02.00	09.28	07.28		11KV Phase to Phase near Lokirev (V)	No
4		Hemajippur	Koilakunta Tanda	11KV	Jadcherla	2:10	7:50	5:40		Jumper cut near Koilakunta Tanda	No
5		Nizalapur	MD Hussainpally	11KV	Jadcherla	07.43	09.25	01.42		11KV Phase to Phase near MD Hussainpally (V)	No
1	NLG	Eduloor	Naregudem	11KV	Nalgonda	6:00	10:30	4:30	O/L	11KV Insulator Failed	No
2		Cherkupally	Bandapalem	11KV	Nalgonda	5:45	8:00	2:15	E/L	11KV Jumper Cut	No
3		Koppole	Bheemavaram	11KV	Nalgonda	8:30	11:30	3:00	E/L	11KV Line Cut	No
4		Kethepally	Korlapahad	11KV	Nalgonda	6:30	10:40	4:10	E/L	Tree Branches Fallen on Line	No
5		Kamareddygudem	Badalapuram	11KV	Miryalaguda	23:00	4:00	5:00	E/L	11KV Jumper cut at SS	No
6		Seetya Thanda	Mangapuram	11KV	Miryalaguda	15:30	16:45	1:15	E/L	Line snapped	No
7		Yadagiripally	Utlapally	11KV	Miryalaguda	1:30	6:00	4:30	E/L	Line snapped	No
8		Penpahad	Anajipuram	11KV	Suryapet	6:10	8:40	2:30	E/L	Insulator Flash Over	No
9		Nagaram	D.Kothapally	11KV	Suryapet	2:00	7:15	5:15	E/L	Poles Damaged	No
10		Dirsanapally	Chinnanemila	11KV	Suryapet	02.40	07.30	04.50	E/L	Toddy Tree Fallen on the Line	No
11		Munagala	Turkagudem-2	11KV	Huzurnagar	06.00	09.00	03.00	EL	Due to 11KV Jumper Cutted	No
12		Mellacheruvu	Revooru	11KV	Huzurnagar	03.25	06.25	03.00	EL	Due to 11kv Insulator Failure	No
13		IDA	Bommaipally	11KV	Bhongir	16.00	12.00	20.00	EL/OL	11KV Line Sanpped Near Bommipally Village	No
14		MR.Gudem	Gangasanipally	11KV	Bhongir	22.25	07.30	09.05	EL/OL	11 kv Insulator Failed at SS-6 Durgaprasad Thota Near Gangasanipally Village	No
15		Golankonda	Golankonda	11KV	Bhongir	02.05	11.00	08.55	EL/OL	11kv Insulator Failed Near Golankonda Village	No
16		Motakondur	Motakondur Agl	11KV	Bhongir	05.00	10.20	05.20	EL/OL	11kv Line Sanpped Near Motakondur Village	No
17		Paladugu	Panakabanda	11KV	Bhongir	04.00	08.50	04.50	EL/OL	11KV Pin Insulator Failed Near Mushipatla Village.	No
18		Pallerla	Siddapuram	11KV	Bhongir	21.00	10.35	13.35	EL/OL	11kv Pole Damedged Near Siddhapuram Village	No
1	MDK	Sangareddy Town -II	No.III	11KV	Sangareddy	11:10	12:20	1:10		Jumper cut	No
2		Sangareddy Rural	Balaji	11KV	Sangareddy	03.20	07.40	04.20		Tree branches fallen on the line	No
3		Sangareddy Rural	Kothlapur	11KV	Sangareddy	04.35	05.32	00.57		Tree branches fallen on the line	No
4		Sadasivapet	Nandi Kandi	11KV	Sangareddy	02.14	05.00	02.46		Insulator failed	No
5		Sadasivapet	TSM	11KV	Sangareddy	02.14	06.00	03.46		Insulator failed	No
6		Sadasivapet	Town-II	11KV	Sangareddy	02.12	06.36	04.24		Jumper cut	No
7		EPIP-III	Tychy Diecast	11KV	Sangareddy	04.20	08.00	03.40		Tree branches fallen on the line	No
8		Bollaram-I	Kythan	11KV	Patancheru	04.30	07.55	03.25		Jumper cut	No
9		Bollaram-I	Soubhagya	11KV	Patancheru	06.30	10.08	03.38		Conductor snapped	No
10		Bollaram-I	Sulaxshana-I	11KV	Patancheru	7:55	10:00	2:05		Conductor snapped	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	SDPT	Bejjanki	Muthannapet	11KV	Husnabad	1:30	5:30	4:00		Haevy gale and wind	No
2		Bejjanki	kallepally	11KV	Husnabad	02.30	04.30	02.00		AB switch failed	No
3		Ramchandrapur	Varikolu	11KV	Husnabad	03.00	06.10	03.10		Haevy gale and wind	No
4		Samudrala	Samudrala rural	11KV	Husnabad	00.00	11.00	11.00		Haevy gale and wind	No
5		Rebarthi	Rebarthi	11KV	Husnabad	00.10	10.30	10.20		Line cut	No
6		Guruvannapet	Guruvannapet	11KV	Husnabad	00.00	08.42	08.42		Insulator failed	No
7		Guruvannapet	Guruvannapet	11KV	Husnabad	10.30	11.00	00.30		Jumper cut	No
8		Nagapuri	Nagapuri	11KV	Husnabad	04.30	07.55	03.25		Haevy gale and wind	No
9		Nagapuri	Dudekulapally	11KV	Husnabad	4:30	8:10	3:40		Haevy gale and wind	No
1	RR S	Chandanagar	Engineer's Enclave	11KV	Gachibowli	5:10	6:10	1:00		11kv Pin Insulator failed at Khazana Jewellers	No
2		ESCI	ESCI	11KV	Gachibowli	05.40	07.20	01.40		11kv Jumper cut at Jayabheri , 11kv Insulator failed and Tree Branches fallen on the 11kv line at Jayabheri	No
3		L&T	PJR Nagar	11KV	Gachibowli	05.30	06.44	01.14		Tree Branches fallen on the 11kv line at Telecom nagar	No
4		Kothaguda	Izzath Nagar	11KV	Gachibowli	15.05	16.18	01.13		UG Cable damage by GHMC work at NAC Gate	No
1	RR N	Nizampet	Rajadhani school	11KV	Kukatpally	5:30	7:40	2:10	EL	Due to rain, Pin insulator fail at Road no 3	No
2		Nizampet	Bandari Lay out	11KV	Kukatpally	04.35	07.00	02.25	EL/OL	Pin insulator failure at road no 5B at Nizampet	No
3		Prashanthi hills	Srinivasa colony	11KV	Kukatpally	04.30	06.20	01.50	EL	Cable heavy spark Balaji water plant back side LABS open	No
4		Prashanthi hills	Brundavan hills	11KV	Kukatpally	04.30	07.30	03.00	EL/OL	Pin insulator failure at Prashanthi hills	No
5		Ravalkole	Ravalkole	11KV	Medchal	7:00	10:05	3:05	EL/OL	2Nos 11KV PinInsulator failed at Ravalkole Village	No
1	RR E	Narapally	P.Singaram	11KV	Keesara	10:15	10:50	0:35		Pin binding wire removed at koremulla	No
1	HYD N	Hakimpet	Bollarum P.S	11KV	C-VI	02.40	05.15	02.35	EL,OL	Disc Insulator flash over at Bollarum	No
2		Prashasan Nagar	Andhra Bank	11KV	X	4:50	7:30	2:40	EL,OL	AB Cable fault at Plot No.176	No
3		MLA Colony	Cine Ghar	11KV	X	4:57	7:58	3:01	EL,OL	UG Cable End Kit fault at Omega Hospital & Jumper cut at V6 Channel	No
4		Macha Bollarum	Balaji Rice Mill	11KV	C-VI	6:50	8:25	1:35	EL,OL-Rph	Disc Insulator flash over at Railway Track, Bollarum	No
5		Jubilee Hills	A O U	11KV	X	7:18	11:10	3:52	All Indication	Tree fallen on lines & I/C Cable fault at SS	No
6		Road No.2	E-Seva	11KV	X	07.27	10.30	03.03	EL,OL	Jumper cut at Road No.14 (08:45 Hrs partial loads charged)	No
1	HYD C	Toli Chowki	Hakeemsha	11KV	VII	04.40	08.10	03.30	All Indication	Cable fault & Big tree fallen on lines at Subzi Colony	No
2		S.D Hospital	Ahmed Nagar Cable	11KV	VII	04.45	06.00	01.15	EL,OL-Rph	Jumper cut at Bada Bazar	No
3		Golconda	Narayanamma College	11KV	VII	06.06	08.00	01.54	EL,OL-Bph	Tree branches fallen on lines at OSF School	No
4		Asif Nagar	Alapati Nagar	11KV	VII	6:25	7:35	1:10	EL	AB Cable fault at Alapati Nagar & HT lines twisted at P&T Colony	No