

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234	1	2	1	2	1	2			
6	RR(N)	54	550		6		6		6			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		6		6		6			
	Total	606	3055	1	17	1	17	1	17	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	1	2	1	2	1			
2	NLG	144	988		5		5		5			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	6	2	6	2	6	0	0	
	Grand Total	1082	6468	3	23	3	23	3	23	0	0	

TSSPDCL - LMRC / Corporate office

Date: 04.06.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effectted	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Rakonda	33KV	Nagarkurnool	11.56	13.00	01.04	E/L	Tree Fallen on the line and removed near Sarswathi Devi temple	Rakonda	-
2		Alampur	Undavelly	33KV	Gadwal	20.21	20.40	00.19	E/L	PTRs Pull out	Undavelly	-
1	RR S	Amangal	Kadthal	33KV	Rajendranagar	05.00	09.45	04.45	E/L	for Pin bairding replacement near 132KV Amangal SS	Kadthal	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 04.06.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Midjil	Veljal	11KV	Jadcherla	10.50	12.00	01.10		11Kv Jumper Cut Near Vudugulagadda Tanda Side.	-
1	NLG	Aitipamula	CH.Annaram	11KV	Nalgonda	12.00	14.25	02.25	E/L	Insulator Failure	-
2		Kethepally	Korlapahad	11KV	Nalgonda	10.00	11.35	01.35	E/L	Bird died on line	-
3		GT Giri	Gunjaloor	11KV	Suryapet	09.50	12.23	02.33	E/L	Jumper cut	-
4		Azeempet	Azeempet	11KV	Bhongir	10.00	15.40	05.40	E/L	11 kv Line snapped	-
5		Suddala	Pallephad	11KV	Bhongir	11.15	13.05	01.50	E/L	SS-24 DTR Failed	-
1	RR S	Nanakramguda	Mantri Developers	11KV	Gachibowli	07.12	10.24	03.12	BD	Internal problem at Mantri Developers Apartments	-
2		Gachibowli	Sai Baba	11KV	Kondapur	12.50	13.56	01.06	BD	11kv Sai Baba feeder relay problem near Sub-Station(Iron rod fallen on 11kv line at plot no.850, B-block)	-
1	RR N	Jeedimetla SS I	Shapurnagar	11KV	Jeedimetla	12.30	13.40	01.10	EL	11kv AB cable failure at new Shapur DTR	-
2		Jagathgirigutta	Jagathgirigutta	11KV	Medchal	00.35	01.05	00.30	EL/OL	11KV Cable endkit failed at Gym, Anjaiah Nagar(11KV Jumper opened)	-
3		Gowdavelly	IDA Gowdawelly	11KV	Medchal	07.05	09.45	02.40	EL/OL	11KV Brass Patti cut and replaced at Basaragadi	-
4		GP Pally	Neighbourhood	11KV	Medchal	10.00	12.00	02.00	EL	HT/LT Line Melted at Cheruvukatta, GP Pally	-
5		Shameerpet	Anthaipally	11KV	Medchal	08.45	10.20	01.35	EL/OL	11KV Line Cut and replaced at Vital Reddy Bhavi, Anthaipally	-
6		Medchal	IDA-I	11KV	Medchal	03.20	04.30	01.10	EL/OL	11KV Line cut and replaced at BSNL Office backside(3 Places)	-
1	RR E	Nacharam Indore	Surana	11KV	Habsiguda	19.10	20.02	00.52		11KV Pin Insulator failed at Surana Company	-
2		Cherlapally-IV	Sai Nagar	11KV	Habsiguda	09.15	11.15	02.00		Street light pole toching on 11Kv line at KLR (AE)	-
3		Aushapur	Aushapur	11KV	Keesara	19.10	19.50	00.40		HT/LT line twisted at Ankushapur Maszid	-
1	HYD N	Bowenpally	Pension Line	11KV	VI	09.45	11.27	01.42	No Indication	O/G AB Switch Jumper cut & Relay problem at SS	Arranged B/F on 11KV Seetharama Puram feeder
2		Toli Chowki	Road No.86	11KV	X	18.30	19.50	01.20	EL	Pin Insulator flash over at Darga	-----
1	HYD C	Industrial Area	Barkathpura	11KV	II	02.05	04.02	01.57	EL,OL	HT Jumper cut at Padma Colony & O/G AB Switch Y&Bph Jumpers cut at SS	-
2		Asif Nagar	Padmanabha Nagar	11KV	VII	09.52	11.26	01.34	EL,OL-Rph	Tree branches fallen on lines & Jumper cut at Premier Hospital	-
3		Amberpet	Play Ground	11KV	II	10.10	11.35	01.25	EL,OL	Yph Clamp flash over at SS	-
4		Bathkammakunta	Ahobilmutt	11KV	II	18.23	20.15	01.52	EL	Tree branches fallen on lines at Water Works	-