

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044	1	4	1	4	1	4			
	Total	606	3055	1	4	1	4	1	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		2		2		2			
3	MDK	107	933		1		1		1			
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	6	1	6	1	6	0	0	
	Grand Total	1082	6468	2	10	2	10	2	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 06.06.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Manthathi	33kv	Nagarkurnool	11.00	14.05	03.05	O/L	Pin Binding Work at Itikyala Village	Manthathi	-
1	HYD N	132KV Erragadda	Bora Banda	33kv	Erragadda	09.49	09.52	00.03	EL	Tripped on EL	Bora Banda	Loads transferred onto 132KV Erragadda - IDPL-I

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 06.06.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Jalalpuram	Velishala	11kv	Suryapet	08.00	11.40	03.40	E/L	11Kv Insulator failed	-
2		Pallerla	Siddapuram	11kv	Bhongir	00.05	07.00	06.55	EL/OL	16KVA DTR Failed at SS-22 Pailla Gopal reddy well near Siddapuram (V)	-
1	MDK	Patancheru Town	MIA-II	11kv	Patancheru	12.35	14.40	02.05		BD due to Conductor snapped	-
1	SDPT	Bekkal	Kondapur	11kv	Husnabad	10.20	12.45	02.25		Tree fallen in line	-
2		THIMMAREDDYPALLY SS	THIMMAREDDYPALLY	11kv	Gajwel	16.45	18.30	01.45		AB SWITCH PRBLEM	-
3		PALLEPADU SS	SINGARAM	11kv	Gajwel	09.30	13.40	04.10		INSULATOR FAILED	-
1	HYD N	Clock Tower	Sangeeth	11kv	V	10.44	11.52	01.08	EL	HT Jumper cut at Bharath Petroleum	-----
2		Macha Bollarum	Balaji Rice Mill	11kv	V	19.00	20.40	01.40	EL	Lizard fault on lines at Railway Track	-----
3	HYD C	Asif Nagar	N.S.F Colony	11kv	VII	04.28	05.37	01.09	EL	No Visible Fault	Partial feeder charged & Remaining arranged B/F on 11KV Military Hospital fdr
4		Asif Nagar	Toli Chowki	11kv	VII	14.00	15.09	01.09	EL	Insulator flash over & AB Cable sparking at Yousuf Bazar	-----