

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		3		3		3			
3	MDK	107	933		6		6		6			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	11	0	11	0	11	0	0	
	Grand Total	1082	6468	0	14	0	14	0	14	0	0	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Bhoothpur	Rural	11KV	Jadcherla	10.15	11.05	00.50		11KV Jumper cut near Bhoothpur (V)	No
2		Kodgal	Goplapur	11KV	Jadcherla	07.58	11.40	03.42		11KV Pin binding failure near Nallakunta Tanda side	No
1	NLG	Keethavarigudem	Kothagudem	11KV	Huzurnagar	11:50	13:30	1:40	EL	11KV Line snapped	No
2		Mushampally	Mushampally (Agl)	11KV	Nalgonda	08.45	10.00	01.15	EL	11KV Insulator failed	No
3		Thipparthi	Sarvaram	11KV	Nalgonda	06.00	07.00	01.00	EL	Jumper cut	No
1	MDK	Bollaram - I	Sulaxshana-I	11KV	Patancheru	17:20	18:15	0:55		Conductor snapped	No
1	SDPT	Pamulaparthi	Vasundara Express	11KV	Gajwel	7:00	8:00	1:00		Crow fallen on the 11KV Line	No
2		Gowram	Pathur	11KV	Gajwel	08.10	11.20	03.10		Tipper dashed to the pole	No
3		Mednipur	Mangole	11KV	Gajwel	16.40	18.00	01.20		11KV Line cut	No
4		Bejjanki	Muthannapet	11KV	Husnabad	09.15	12.45	03.30		Disc failure	No
5		Cherial Town	Sundarayyanagar Agl	11KV	Husnabad	6:05	13:02	6:57		Pin binding failed	No
1	RR N	Dulapally	IDA-II	11KV	Medchal	14:45	17:27	2:42		11KV Line AB Switch Opened at SVS Kanta No Visible Fault	No
2		Chintal	Dwaraka Nagar	11KV	Medchal	15.20	16.30	01.10		11KV AB Cable End Kit failed at Manikya Nagar	No
1	HYD N	Chinna Thokatta	Hasmathpet	11KV	VI	10.32	12.10	01.38	EL	Foreign material fallen on lines at Cheruvu Katta	No