

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550	1	17	1	17	1	17			
7	RR(E)	168	403		8		8		8			
8	Hyd	194	1044		48		48		48			
	Total	606	3055	1	74	1	74	1	74	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3		3		3				
2	NLG	144	988	4	34	4	34	4	34			
3	MDK	107	933	4	6	4	6	4	6			
4	SDPT			2	36	2	36	2	36			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	13	76	13	76	13	76	0	0	
	Grand Total	1082	6468	14	150	14	150	14	150	0	0	

TSSPDCL - LMRC / Corporate office

Date: 10.06.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Manthathi	33KV	Nagarkurnool	00.55	13.08	12.13	E/L&O/L	Insulator Damaged at Kollapur X Road		AB Swithc opened at Peddamadanoor
2		Gadwal	Maldakal	33KV	Rural	10.35	13.35	03.00	E/L	Conductor snapped at location No 82		NO
3		Gadwal	Maldakal	33KV	Rural	17.05	20.20	03.15	E/L	Pin Binding Failed & Disc Failed at Mangampet		NO
1	NLG	132KV Kanagal	33KV Pagidimarri	33KV	Nalgonda	15.20	16.55	01.35	E/L	Tree Fail On The 33Kv Line		-
2		Suryapet	Chivemla	33KV	Suryapet	03.45	06.35	02.50	E/L	Tree Branch fallen 33Kv Line		-
3		Dirsincherla	Garidepally	33KV	Huzurnagar	03.00	10.10	07.10	EL/OL	Automatic stand		-
4		Munagala	Akupamula	33KV	Huzurnagar	05.00	11.50	06.50	EL/OL	33 kv pin inslater failed		-
1	MDK	Pashamailaram	APL IV	33KV	Sangareddy	00.55	16.05	15.10		BD due to breaker failed at 132KV SS		-
2		Bollaram	Agarwal Globle Steel	33KV	Patancheru	08.45	10.45	02.00		BD due to Jumper cut		-
3		Gummadidala	GPSS-2	33KV	Patancheru	09.55	17.25	07.30		BD due to Pole damaged		-
4		Zaheerabad	Buchinelly	33KV	Zaheerabad	14.10	17.15	03.05		BD due to Jumper cut		-
1	SDPT	Gajwel	Pragnapur	33KV	Gajwel	19.00	22.20	03.20		BD (Rain and Heavy wind)		Jagadevpur 33 Kv From 20:20
2		Duddeda	Kondapaka	33KV	Husnabad	01.20	05.45	04.25		BD (Heavy Gale and Rain)		-
1	RR N	132KV DP Pally	33KV Gowdavelly	33KV	Medchal	01.10	01.35	00.25		Breaker Problem (backfeeding to 33KV Nuthankal feeder(132KV Medchal)		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 10.06.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Palem	Ogodu	11KV	Nalgonda	05.00	07.00	02.00	E/L	11KV Line Jumper Cutting	-
2		Eduloor	Parada	11KV	Nalgonda	06.00	08.15	02.15	E/L	11KV Line Jumper Cutting	-
3		Eduloor	Kurumarthy	11KV	Nalgonda	06.00	09.00	03.00	E/L	SS-3 11KV Line Jumper Cutting And Tree Branches On the line	-
4		Eduloor	Gadibaigudem	11KV	Nalgonda	06.00	09.20	03.20	O/L	SS-4 11KV Line Jumper Cutting	-
5		Aitipamula	R.C.Puram	11KV	Nalgonda	06.00	07.30	01.30	E/L	11KV Line Insulator Failur	-
6		Kattangur	Dugunavelly	11KV	Nalgonda	05.00	07.20	02.20	E/L	Tree Branches On The Line	-
7		Kattangur	Mallaram	11KV	Nalgonda	05.00	07.50	02.20	O/L	Tree Branches On The Line	-
8		Dandampally	Dandampally	11KV	Nalgonda	05.30	09.40	04.10	O/L	Tree Branches On The Line	-
9		Velugupally	A.R.Guda	11KV	Nalgonda	06.00	07.15	01.15	E/L	Tree Branches On The Line	-
10		Narkatpally	M.Yadavally	11KV	Nalgonda	01.00	11.30	11.30	E/L	11KV Line Insulator Failur	-
11		Nakkalapally	Pallepahad	11KV	Nalgonda	07.00	11.25	04.25	E/L	11KV Line Insulator Failur SS-1	-
12		Thipparthi	Sarvaram	11KV	Nalgonda	06.00	09.10	03.10	E/L	11KV Line Disc Failur	-
13		Thipparthi	Marriguda	11KV	Nalgonda	06.20	11.00	04.40	O/L	11KV Line Disc Failur	-
14		Anneparthi	Cherlapally Agl	11KV	Nalgonda	21.30	09.30	11.00	O/L	Tree Branches On The Line	-
15		Thimmannaguda	Thelakantigudem	11KV	Nalgonda	21.00	13.50	17.50	E/L	11KV Kine Cutting SS-4	-
16		Kothapally	Peruvla	11KV	Devarakonda	13.07	13.37	00.30	E/L	11KV Jumper Cut	-
17		Thungathurthy	Pasnoor	11KV	Suryapet	00.30	06.40	06.10	E/L	11Kv Insulator flashover and Conductor snapped	-
18		B.Chandupatla	V.K Pahad	11KV	Suryapet	06.40	09.30	02.50	E/L	11Kv Disc failed	-
19		Nuthankal	Yelkapally	11KV	Suryapet	02.30	07.15	04.45	E/L	11Kv Insulator flashover	-
20		Reddygudem	Kothagudem	11KV	Suryapet	03.20	08.30	05.10	E/L	11Kv Insulator flashover	-
21		Munagala	Kokkereni-2	11KV	Huzurnagar	06.15	08.00	01.45	E/L	11KV Line Snapped	-
22		Keethavarigudem	Rainigudem	11KV	Huzurnagar	05.00	07.30	02.30	E/L	11KV inslater failed	-
23		Nemaragomula	Jiyapally	11KV	Bhongir	12.32	15.10	02.38	EL/OL	11kv Insulator Failed near Jiyapally Village	-
24		Solipet	Indl	11KV	Bhongir	04.00	07.00	03.00	EL/OL	11kv Post off Insulator failed near Solipet (v)	-
25		Sharajipet	Sharajipet	11KV	Bhongir	04.30	06.00	01.30	EL/OL	11kv Line snapped near Sharajipet (v)	-
26		Pamukunta	Pamukunta	11KV	Bhongir	05.00	09.00	04.00	EL/OL	11kv Insulator Failed near Mandollagudem Road	-
27		Motakondur	Motakondur Agl	11KV	Bhongir	02.55	08.00	05.05	EL/OL	11kv Disc failed near Sikindernagar	-
28		Manaikunta	Manaikunta	11KV	Bhongir	06.00	10.00	04.00	EL/OL	11kv Insulator failed near Manaikunta (v)	-
29		Paladugu	Panakabanda	11KV	Bhongir	04.00	09.00	05.00	EL/OL	11kv Insulator Failed near Kalvakunta (v)	-
30		Paladugu	Paladugu	11KV	Bhongir	05.00	09.30	04.30	EL/OL	11kv Insulator failed near paladugu (v)	-
31		Athmakur	Koratikal	11KV	Bhongir	06.00	09.30	03.30	EL/OL	11kv Insulator Failed near Koratikal (v)	-
32		Ambala	Parupally	11KV	Bhongir	01.30	05.10	03.40	EL/OL	11kv Insulator failed at SS-12 near Parupally (v)	-
33		Yennaram	Suraram	11KV	Choutuppal	04.00	08.50	04.50	EL/OL	11kv Disc failed & 11 KV Line snapped near Suraram (v)	-
34		Puligilla	Kerchipally	11KV	Choutuppal	05.20	07.55	02.35	EL/OL	11kv Insulator failed at Jangaiah farm near Kerchipally (v)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MDK	EPIP-III	Tychy Diecast	11KV	Sangareddy	00.34	08.48	08.14		BD due to Disk failed	-
2		EPIP-III	Vilas Polymer	11KV	Sangareddy	00.02	07.30	07.28		BD Conductor snapped	-
3		Kistareddypet	Bheeramguda	11KV	Patancheru	01.05	01.57	00.52		BD due to Insulator failed	-
4		Bollaram - I	Salgutty	11KV	Patancheru	17.15	18.55	01.40		BD due to Insulator failed	-
5			Town -I	11KV	Patancheru	01.20	03.10	01.50		BD due to Tree fallen on line	-
6		Hathnoora	Town Ind	11KV	Patancheru	00.00	06.45	06.45		BD due to Tree fallen on line	-
1	SDPT	GAJWEL	TOWN-1 (LC.NO:7265)	11KV	Gajwel	19.28	20.45	01.07		11KVA DISK FAILED	-
2		JAGADEVPUR	GOWLAPUR (LC.NO: 5539)	11KV	Gajwel	02.29	09.35	07.06		11 KVA LINE PROBLEM	-
3		CHATLA PALLY	CHATLA PALLY AGL (LC.NO: 5719)	11KV	Gajwel	18.50	20.30	01.40		JUMPER WIRE CUT	-
4		KODAKANDLA	RAYAVARAM (LC.NO:)	11KV	Gajwel	01.20	10.50	09.30		INSULATOR BURN	-
5		MARKOOK	MARKOOK AGL (LC.NO: 25271)	11KV	Gajwel	17:40	21:00			11 KVA WIRE CUT	-
6		NACHARAM	MADHARAM (LC.NO: 19006)	11KV	Gajwel	02.00	07.00	05.00		11KVA INSULATOR FAILED	-
7		THUNIKI KALSA	AMBER PET(LC.NO: 26730)	11KV	Gajwel	18.43	21.20	02.30		BREAK DOWN	-
8		SEETHARAM PALLY	VELOOR(LC.NO: 3017)	11KV	Gajwel	15.35	18.00	02.35		BREAK DOWN	-
9		WARGAL SS	WARGAL AGL	11KV	Gajwel	00.41	06.10	04.41		BREAK DOWN	-
10		WARGAL SS	WARGAL TOWN	11KV	Gajwel	23.20	01.30	02.10		BREAK DOWN	-
11		WARGAL SS	WARGAL TOWN	11KV	Gajwel	03.20	06.00	02.40		BREAK DOWN	-
12		KONDAPAK	KONDAPAK INDUSTRIAL(LC.NO : 24308)	11KV	Gajwel	9:15	9:45	0:30		DISK FAILED	-
13		MARPADAGA	MARPADAGA AGL(LC.NO: 25157)	11KV	Gajwel	7:20	8:50	1:40		TREE BRANCH FELL DOWN ON THE 11 KV LINE	-
14		DOMMAT	SURAM PALLY(LC.NO: 3946)	11KV	Gajwel	01.32	08.20	06.48		DISK FAILED	-
15		MUBARAS PUR	MUBARAS PUR 4113)	11KV	Gajwel	11.10	12.11	01.01		FUSS OF CALL	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
16	SDPT	DOMMAT	GAJULAPALLY(LC.NO:3949)	11KV	Gajwel	18.47	20.50	02.03		DISK FAILED	-
17		ANAJIPUR	MANTHUR 1560)	11KV	Gajwel	23:20	6:05	06.45		INSULATOR BURN	-
18		PALLEPAHAD	PALLEPAHAD (LC.NO:8216)	11KV	Gajwel	05.00	06.00	01.00		INSULATOR FAILED	-
19		PALLEPAHAD	SINGATAM(LCNO:8216)	11KV	Gajwel	15.00	17.00	02.00		CHARGE FAILED	-
20		Marumamaula	Salakpoor	11KV	Husnabad	20.00	23.10	03.10		Heavy Gale and Rain	-
21		Chityala	Dommata	11KV	Husnabad	00.00	11.20	11.20		Heavy Gale and Rain	-
22		Pandilla	Pandilla Express	11KV	Husnabad	00.00	08.30	08.30		Jumper Cut	-
23		Pandilla	Pandilla Express	11KV	Husnabad	10.50	11.30	00.40		insulator failed	-
24		Pandilla	Kuchanpally	11KV	Husnabad	12.45	14.15	01.30		Heavy Gale and Rain	-
25		Pandilla	Pandilla Rural	11KV	Husnabad	00.00	08.30	08.30		Heavy Gale and Rain	-
26		Gouravelly	Gudatipally	11KV	Husnabad	00.00	07.10	07.10		3-PH Break Down	-
27		Bejjanki	Cotton Mill	11KV	Husnabad	00.00	12.50	12.50		Insulator failed	-
28		Guggilla	Guggilla	11KV	Husnabad	02.30	11.30	09.00		Poles Break	-
29		Guggilla	Thimmayapalli	11KV	Husnabad	02.30	12.40	10.10		Poles Break	-
30		Guggilla	Gagillapur RRC	11KV	Husnabad	02.30	12.30	10.00		Poles Break	-
31		Thotapally	Thoatapally Rural	11KV	Husnabad	11.10	12.50	01.40		Insulator failed	-
32		Thotapally	Thoatapally Rural	11KV	Husnabad	18.40	09.30	00.50		Break Down	-
33	Thotapally	Veerapur	11KV	Husnabad	09.20	10.20	01.00		Insulator failed	-	
34	Ramchandrapur	Vinjalpally	11KV	Husnabad	02.15	09.10	06.55		Insulator failed	-	
35	Koheda	Teegalakuntapally	11KV	Husnabad	06.50	08.50	02.00		Insulator failed	-	
36	Samudrala	Samudrala Rural	11KV	Husnabad	00.00	07.15	07.15		Heavy Gale and Rain	-	
1	RR S	L&T	PJR Nagar	11KV	Gachibowli	00.58	02.05	01.07		11kv Pin-insulator failed at Amaravathi backside	-
1	RR N	Chandanagar	Sreeramnagar	11KV	Kukatpally	00.40	02.30	01.50	EL/OL	Tree branch fallen on the 11kv line at Gangaram	-
2		Bowrampet	Coca cola	11KV	Jeedimetla	01.35	03.20	01.45	EI	11KV Insulator failure at Simhapuri colony	
3		Bowrampet	Junnurum	11KV	Jeedimetla	02.31	04.20	01.49	OL	Tree falen on the 11 kv line near Akshra school	
4		Chintal	Ganesh Nagar	11KV	Medchal	03.30	04.35	01.05		AB Cable failed at Ram Reddy Nagar(Backfeeding arranged to 11KV Ganesh Nagar feeder from HMT SS)	
5		Subhash Nagar	Jairam Nagar	11KV	Medchal	02.20	03.29	01.09		Tree fallen on the 11Kv Line at Vasudha Apartment	
6		Subhash Nagar	Jairam Nagar	11KV	Medchal	04.25	05.50	01.25		Tree Fallen on the 11KV line at Hanuman Temple	
7		Petbasheerabad	St Ann's	11KV	Medchal	17.35	19.35	02.00		11KV Pin Insulator failed at Andhra Bank	
8		Chintal	Bhagathsingh Nagar	11KV	Medchal	18.30	19.15	00.45		Tree fallen on the 11KV Line at BS Nagar	
9		Subhash Nagar	Suchitra	11KV	Medchal	19.04	21.35	02.31		Tree Fallen on 11KV Line at Sarvotham Company	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
10		Kolthur	Mallannakatta	11KV	Medchal	00.05	04.20	04.15		Tree fallen on the 11Kv Line at Mallanna Temple	-
11		Aliabad	HBL	11KV	Medchal	00.40	02.00	01.20		11KV Pin Insulator failed at Buru Bhavi	-
12		Shameerpet	NTRO	11KV	Medchal	00.05	03.20	03.15		No Fault	-
13		Ravalkole	Ravalkole	11KV	Medchal	06.00	08.00	02.00		Tree Branch fallen on the 11KV Line at SC Basti	-
14		Medchal	IDA-I	11KV	Medchal	13.00	15.20	02.20		11KV Line & Jumper Cut at BSNL Office Opposite & Nut Bolt Company	-
15		Town Medchal	NGO's Colony	11KV	Medchal	19.30	20.45	01.15		11KV Pin Insulator Failed and replaced at KLR Vencher	-
16		GP Pally	GP Pally	11KV	Medchal	18.00	22.20	04.20		11KV Conductor Snapped and replaced at GP Pally Road(Pole Bend)	-
17		Athiwelly	Athiwelly	11KV	Medchal	20.00	22.15	02.15		11KV Pin Insulator Failed and replaced at near by Shantha Biotech Company	-
1	RR E	Polytechnice	Srinivasapuram	11KV	Habsiguda	17.54	19.38	01.44		63KVA DTR insulator fail at sai ram appt Srinivasapuram colony	-
2		Vasanthapuri	Venkateshwara Nagar	11KV	Sainikpuri	00.54	02.00	01.06		Post Of Insuletor fail at Shawales Compony Opp (Artisan/Jamal)	-
3		Kushaiguda	Saibaba Temple	11KV	Sainikpuri	01.20	02.10	00.50		Out Going End Kit Cable fail at SS Yard (AE/OP) Saibaba feeder Load Add on Kushaiguda feeder	-
4		RGK	Nissa	11KV	Sainikpuri	01.30	02.30	01.00		Tree branches fall on 11Kv line at Nissa	-
5		Cherlapally-I	Nagaram	11KV	Sainikpuri	02.20	03.05	00.45		11Kv Insulator failed at Open Jail (AE/OP)	-
6		Uppal	Nava bharath	11KV	Habsiguda	22.05	23.25	01.20		Tree branches fall on 11Kv line at Chamber company	-
7		CRPF	Chennapur	11KV	Keesara	18.30	19.55	01.25		Lorry Dashed to 11kv pole at Dumping yard	-
8		Narapally	P.singaram	11KV	Keesara	05.50	06.35	00.45		Disk fail at Korremulla	-
1	HYD N	Tirumalagiri	Mangapuram	11KV	C-VI	00.25	02.40	02.15	EL,OL-Yph	No Visible Fault (Due to rain)	-
2		Marredpally	A.O.C	11KV	C-VI	00.57	02.50	01.53	AR tripped	No Visible Fault (Due to rain)	-
3		Zamistanpur	Sanjeevapuram	11KV	V	01.50	03.10	01.20	EL,OL-Rph	Tree branches fallen on lines at Sunnam Batti	-
4		Road No.13	Sai Enclave	11KV	X	02.06	04.15	02.09	EL,OL	Disc Insulator flash over at Centaury Hospital	-
5		Monda Market	Gandhi Nagar PS	11KV	V	02.05	03.40	01.35	EL	No Visible Fault (Due to rain)	-
6		H.M.T	Chintal	11KV	VI	01.40	02.45	01.05	EL,OL-Bph	No Visible Fault (Due to rain)	-
7		Marredpally	Tagore Home	11KV	C-VI	03.10	04.30	01.20	EL,OL-Yph	Tree branches fallen on lines at Park	-
8		Gunrock	Tirumalagiri	11KV	C-VI	02.20	03.50	01.30	EL,OL-Rph	No Visible Fault (Due to rain)	-
9		Madhapur	Ohris	11KV	X	11.25	13.00	01.35	EL,OL	Insulator flash over at Opp. My Home	-
10		Macha Bollaram	Reddy Enclave	11KV	C-VI	17.00	18.20	01.20	OL-Rph	Tree branches fallen on lines at Indira Gandhi Statue	-
11		Kalyan Nagar	A.G.Colony	11KV	X	18.06	19.30	01.24	EL,OL	Tree branches fallen on lines at Vikaspuri	-
12		Osm.University	Mettuguda	11KV	V	17.55	19.15	01.20	EL	Tree branches fallen on lines at BSNL Office	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
13		Tirumalagiri	Officers Colony	11KV	C-VI	17.22	18.30	01.08	EL,OL	Tree branches fallen on lines at M.H.Colony	-	
14		R.P.Nilayam	Vaishnavi Matha	11KV	C-VI	17.15	18.40	01.25	EL,OL	Tree branches fallen on lines at Batiya Bakery	-	
15		Chilkaiguda	Dandu Pentaiah	11KV	V	17.03	19.40	02.37	EL,OL	No Visible Fault (Due to rain)	-	
16		Bowenpally	B.B.R Hospital	11KV	VI	17.17	19.40	02.23	All Indication	No Visible Fault (Due to rain)	-	
17		Marredpally	Nehru Nagar	11KV	C-VI	19.00	20.30	01.30	EL	Flexi fallen on lines at Old BPL	-	
18		Film Nagar	Apollo	11KV	X	19.35	21.08	01.33	OL-Rph	Sectionlizer fault & Tree branches fallen on lines at Khaja Surya Narayana Corporater House	-	
1		HYD S	Yakuthpura	Sravani Hospital	11KV	VIII	03.45	05.15	01.30	EL	Breaker Fault at SS	Arranged B/F on 11KV Raza Nagar fdr
2			Madannapet	Jawaharpura	11KV	VIII	18.30	19.45	01.15	EL	Tree branches fallen on lines at Jawaharpura	-
1	HYD C	Fever Hospital	Sriram Nagar	11KV	II	01.18	03.40	02.22	EL,OL-Bph	Tree branches fallen on lines at Moon Café	-	
2		Narayanguda	Narayanguda	11KV	II	01.28	04.20	02.52	EL,OL-Rph	Tree branches fallen on lines at Sundaraiah Park	-	
3		Bathakamma Kunta	C.E.Colony	11KV	II	02.20	05.33	03.13	OL-Rph	Tree branches fallen on lines at C.E Colony Park	(At 03:07Hrs partial fdr charged OK)	
4		Golconda	Shaikpet Water Works	11KV	VII	02.32	04.28	01.56	EL	DTR AB Cable fault at S.R Residnecy	-	
5		Bathkamma Kunta	Saibaba Temple	11KV	II	03.38	05.50	02.12	EL,OL-Rph	Tree branches fallen on lines at Saibaba Temple	-	
6		Industrial Area	Vidya Nagar	11KV	II	03.40	06.40	03.00	EL	Tree branches fallen on lines & Jumper cut at Vidya Nagar	-	
7		Fever Hospital	C.C.Sharroof Hospital	11KV	II	02.32	04.50	02.18	EL,OL-Bph	Tree branches fallen on lines at Rajendra Nagar Community	-	
8		A.S.R.Raju Nagar	Sai Garden	11KV	VII	02.30	04.57	02.27	EL	Tree branches fallen on lines at Ganesh Apartment	-	
9		Bathakamma Kunta	Ramalayam	11KV	II	03.29	05.08	01.39	EL,OL	Tree branches fallen on lines at Ramalayam Temple	-	
10		Nampally	Pearl Regency	11KV	VII	03.53	05.20	01.27	EL	Tree branches fallen on lines at Water Works	-	
11		Toli Chowki	B.S.N.L.	11KV	VII	03.46	05.25	01.39	EL	2Nos. Disc Insulators flash over at Limra Hotel	-	
12		Jawahar Nagar	Ashok Nagar	11KV	I	04.15	05.45	01.30	EL	Tree branches fallen on lines at Ashok Nagar Nala	-	
13		A.S.R.Raju Nagar	Jeevan Kalyan Nagar	11KV	VII	17.52	18.58	01.06	EL,OL	No Visible Fault (Due to rain)	-	
14		Chilkaiguda	Parsigutta	11KV	II	17.55	19.58	02.03	EL	Tree branches fallen on lines at Fish Market	-	
15		ITI Mallepally	Zaheera Masjid	11KV	VII	17.53	20.18	02.25	EL,OL	Faulty loads of 11KV VNC feeder	-	
16		Chilkaiguda	Musheerabad	11KV	I	18.00	20.25	02.25	EL,OL	Pin Insulator flash over at Musheerabad	-	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
17		Vittalwadi	APCO	11KV	II	18.15	20.37	02.22	EL,OL	Tree branches fallen on lines & B/o RMU Lug	-
18	HYD C	Nizam College	Little Flower	11KV	I	19.41	21.18	01.37	OL-Rph	Tree branches fallen on lines at Little Flower School	-
19		Bathakamma Kunta	Ahobilmutt	11KV	II	17.42	20.40	02.58	EL	Tree branches fallen on lines at Krishna Teja Apartment	-
20		Bathakamma Kunta	Saibaba Temple	11KV	II	17.43	19.24	01.41	EL	Tree branches fallen on lines at Hanumanth Rao House	-
21		Bathakamma Kunta	C.E.Colony	11KV	II	17.44	18.45	01.01	EL	LT line snapped at Bhavani Book Shop	-
22		Bathakamma Kunta	Ayyappa Temple	11KV	II	17.54	21.06	03.12	EL	Tree branches fallen on lines at Malikarjuna Nagar	-
23		Bathakamma Kunta	D.D Colony	11KV	II	17.42	22.45	05.03	EL	Jumper cut at O.U Gate	-
24		Golconda	Narayanamma College	11KV	VII	18.40	21.40	03.00	EL,OL	AB Cable fault	-
25		Mothimahal	Zinci Bazar	11KV	VII	22.33	23.42	01.09	EL,OL-Y&Bph	Tree branches fallen on lines & jumper cut at Golconda PS	-
26		Fever Hospital	Sriram Nagar	11KV	II	21.01	00.12	03.11	EL,OL-Bph	Tree branches fallen on lines at BSNL Office	-
27		Fever Hospital	R.O.M	11KV	II	21.00	23.37	02.37	EL,OL-Rph	HT Service fault of Aluminium Company	-
28		Narayanguda	Narayanguda	11KV	II	22.18	00.00	01.42	EL,OL-Bph	Stand by Cable fault at near Nala	-