

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550	1	8	1	8	1	8			
7	RR(E)	168	403		6		6		6			
8	Hyd	194	1044		15		15		15			
	Total	606	3055	1	30	1	30	1	30	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	5	2	5	2	5	2			
2	NLG	144	988		21		21		21			
3	MDK	107	933	1		1		1				
4	SDPT			4	25	4	25	4	25			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	10	48	10	48	10	48	0	0	
	Grand Total	1082	6468	11	78	11	78	11	78	0	0	

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Narva	33KV	Narayanapet	10.20	10.55	00.35	E/L	AB Switch open Yernagan Pally SS	Narva	Alternate Supply Taken to 132KV SS Marikal at 10:35Hrs
2		Maddur	Damargidda	33KV	Narayanapet	18.00	19.10	01.10	E/L	for LA Failure at Kyatanpally SS	Damargidda	-
3		Nagarkurnool	Peddakothapally	33KV	Nagarkurnool	05.35	10.05	04.30	O/L	Insulator Failed near Peddakothapally Side	Peddakothapally	-
4		Singotam	Narsaipally	33KV	Nagarkurnool	07.46	11.52	04.06	E/L	Crassarm Bended near by Mahasamudram SS	Narsaipally	-
5		Alampur	Shanthinagar-I	33KV	Gadwal	15.35	17.15	01.40	E/L	Tree Cutting at Ramapuram	Shanthinagar-I	-
1	MDK	Narayankhed	Poosalpad	33KV	Jogipet	05.10	08.00	02.50		B/D Due to Jumper Cut	Poosalpad	-
1	SDP	Siddipet	Narayanaraopet	33KV	Siddipet	01.20	07.55	06.35		BD (Maintainence work)	Narayanaraopet	-
2		Siddipet	Mittapally	33KV	Siddipet	03.25	05.50	02.25		BD (Maintainence work)	Mittapally	-
3		Siddipet	Narsapur	33KV	Siddipet	01.20	07.30	06.10		BD (Maintainence work)	Narsapur	-
4		Chandlapur	Jakkapur	33KV	Siddipet	02.15	09.50	07.35		BD (Heavy Rain & Wind)	Jakkapur	-
1	RR N	132KV Chintal	33KV UMCC	33KV	Medchal	07.00	15.05	08.05		33KV Cable End kit Failed at 132KV Chintal SS Outside(Backfeeding arranged from 33KV Shapur Nagar Feeder from 220KVA Shapur Nagar Time 07:15)	33KV UMCC	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 12.06.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Boothpur	Amistapur	11KV	Jadcherla	04.45	07.15	02.30		11 KV jumper cut near boothpur BC colony	-
2		Kothamolgara	Maddigatla	11KV	Jadcherla	05.30	11.05	05.35		Due to 11 KV insulater fail near Nalla gutta.	-
1	NLG	Panagal	Panagal T	11KV	Nagonda	12.00	13.20	01.20	E/L	Tree branched fallen on the line	-
2		Nampally	Mandapuram	11KV	Devarakonda	06.00	09.00	03.00	E/L	11 KV Insulator Failed	-
3		Mellavai	Revalli	11KV	Devarakonda	00.30	10.00	09.30	E/L	3-ph 25 KVA DTR Failed Mellavai Village	-
4		Bugathanda	Bugathanda	11KV	Devarakonda	05.00	09.00	04.00	E/L	11 KV Jumper Cutt	-
5		Phanigiri	Malipuram	11KV	Suryapet	09.00	10.40	01.40	E/L	Jumper cut	-
6		Yerkaram	Yerkaram	11KV	Suryapet	06.35	10.20	03.45	E/L	Insulator flashover	-
7		Gundepuri	Gundepuri	11KV	Suryapet	03.00	07.30	04.30	E/L	Insulator flashover	-
8		Kalmalcheruvu	Ganganagar	11KV	Huzurnagar	06.00	08.30	02.30	E/L	11 KV LINE SNAPPED	-
9		Munagala	Kokkereni-2	11KV	Huzurnagar	04.30	06.20	01.50	E/L	11 KV JUMPER CUT	-
10		Anantharam	Anantharam	11KV	Bhongir	00.00	08.30	08.30	E/L	25 kva DTR Failed	-
11		Bollepally	Jampally	11KV	Bhongir	08.00	10.00	02.00	E/L	11 kv Insulator failed	-
12		Peddathanda	Pallepahad	11KV	Bhongir	03.00	10.00	07.00	E/L	11kv Disc Failed	-
13		Kondamadugu	Kondamadugu	11KV	Bhongir	05.00	09.00	04.00	E/L	11kv Insulator Failed	-
14		Solipet	Indl	11KV	Bhongir	04.00	07.20	03.20	E/L	11kv Insulator Failed	-
15		Golankonda	Golankonda	11KV	Bhongir	02.00	08.40	06.40	E/L	11 kv Disc failed	-
16		Rajapeta	Pamukunta	11KV	Bhongir	04.00	10.00	06.00	E/L	11kv Insulator Failed	-
17		Addagudur	Ramaram	11KV	Bhongir	06.00	11.00	05.00	E/L	2no's 11KV Insulator Failed	-
18		Manaikunta	Manaikunta	11KV	Bhongir	06.00	09.15	03.15	E/L	11 KV Insulator failed	-
19		Pallerla	Kurella	11KV	Bhongir	04.00	09.45	05.45	E/L	11 kv insulator failed	-
20		Malkapur	Malkapur Agl	11KV	Choutuppal	03.35	10.12	06.37	E/L	11 kv Disc failed	-
21	Puligilla	Puligilla	11KV	Choutuppal	06.40	10.50	04.10	E/L	11 kv Line snapped	-	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	SDP	GAJWEL	TOWN -1	11KV	Gajwel	02:10	06:07	03:57		DISK FAILED	-
2		JAGADEVPUR	GOULAPUR	11KV	Gajwel	09:15	10:51	01:46		INSULATORE FAIL	-
3		PREGANAPUR	GUNDENAPALLY AGL	11KV	Gajwel	21:42	08:30	10:48		AB SWITCH OPEND	-
4		AMDIPUR	KOLUGUR	11KV	Gajwel	13:30	15:30	02:00		JUMPER CUT	-
5		KODAKANDLA	RAYAVARAM	11KV	Gajwel	01:00	11:00	10:00		DISK FAILED	-
6		KODAKANDLA	BURUGUPALLY	11KV	Gajwel	01:00	10:00	09:00		DISK FAILED	-
7		ERRAVALLY	ERRAVALLY AGL	11KV	Gajwel	6:21	17:35	11:14		3 DISKS FAIL	-
8		WARGAL	TOWN -1	11KV	Gajwel	3:50	8:40	04:50		DISK FAILED	-
9		KOKONDA	SINGANAGUDA	11KV	Gajwel	14:27	17:00	02:33		TREE FELL DOWN ON THE 11 KV LINE	-
10		MEDNIPUR	KUKNOOR PALLY TOWN	11KV	Gajwel	5:10	12:20	7:10		BREAK DOWN	-
11		DOULTHABAD	TOWN	11KV	Gajwel	07:25	09:20	01:55		INSULATORE FAIL	-
12		GURRALASOPA	WADDEPALLY	11KV	Gajwel	8:52	11:00	02:10		INSULATORE FAIL	-
13		PALLEPAHAD	PALLEPAHAD	11KV	Gajwel	03:00	06:00	03:00		INSULATORE FAIL	-
14		GUDIKANDLA	GUDIKANDLA & INDUSTRIAL	11KV	Gajwel	09:00	12:20	03:20		INSULATORE FAIL	-
15		AKUNUR	DOMMATA	11KV	Husnabad	00:00	10:10	10:10		Haevy gale and wind	-
16		AKUNUR	AKUNUR AGL	11KV	Husnabad	09:00	15:00	06:00		BD INSULATOR FAIL	-
17		CHITYAL	DOMMATA	11KV	Husnabad	08:30	12:50	04:20		BD FALLEN ON THE TREE	-
18		CHITYAL	CHITYAL AGL	11KV	Husnabad	02:30	16:00	13:30		BD INSULATOR FAIL	-
19		KOMURAVELLY	KISTAMPET	11KV	Husnabad	00:00	09:10	09:10		Haevy gale and wind	-
20		PANDILLA	XPRESS	11KV	Husnabad	12:20	12:50	00:30		Haevy gale and wind	-
21		RAMCHANDRAPUR	VARIKOLU	11KV	Husnabad	00:00	05:40	05:40		Haevy gale and wind	-
22		KOHEDA	KOHEDA	11KV	Husnabad	04:10	08:40	04:30		Haevy gale and wind	-
23		KOHEDA	KURELLA	11KV	Husnabad	04:20	05:20	01:00		Haevy gale and wind	-
24		KOHEDA	SRIRAMULAPALLY	11KV	Husnabad	04:25	05:40	01:15		Haevy gale and wind	-
25		KOHEDA	THEEGAKUNTAALLY	11KV	Husnabad	06:50	09:30	02:40		Haevy gale and wind	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR S	Nanakramguda	N'Widia	11KV	Gachibowli	03.01	04.25	01.24		(Due to heavy rain, 11kv Disk failed near Vajra)	-
1	RR N	Vijayanagar	Allwyn Colony	11KV	Kukatpally	05.20	06.40	01.20	BD	11kv Pin Insultor failure At Sainagar	-
2		Vijayanagar	Jalakanya	11KV	Kukatpally	06.40	08.05	01.25	BD	Tree Branches Fallen On The11kv Line At Water Pump Shivanagar	-
3		Somashila	Sheshdri nagar	11KV	Kukatpally	02.25	04.12	01.47	BD	Tree Branches Fallen On The11kv Line At V V N Nagar	-
4		Jeedimetla-II	Phase-5	11KV	Jeedimetla	06.30	09.20	02.50	BD	11kv AB Cable Failure At J T E L company	-
5		Kompally	Dholari Dhani	11KV	Medchal	02.30	04.29	01.59	BD	No fault	-
6		Kompally	Jaibheri	11KV	Medchal	02.30	04.15	01.45	BD	11KV Pin Insulator failed at Jaibheri Water Tank(11KV Line AB Switch Opened at Bank Colony)	-
7		Kompally	NCL	11KV	Medchal	05.02	06.15	01.13	BD	11KV Disc failed at Shiva Reddy Godam	-
8		Thurkapally	Yadaram	11KV	Medchal	03.21	06.30	03.09	BD	11KV Disc Failed and replaced at High School Opposite, Thurkapally	-
1	RR E	Uppal	Uppal	33KV	Habsiguda	02.30	05.30	03.00		Tree fallen on 11KV line near Ashok Leyland & 11KV AB Switch post of Insulator failed at SS Yard	-
2		Sai Nagar	RNS Colony	33KV	Habsiguda	06.45	08.25	01.40		11KV AB Switch Insulator failed at RNS Colony Road No.01	-
3		Vasanthapuri	Venkateshwar Nagar	33KV	Sainikpuri	16.41	17.31	00.50		Cat fall on 11Kv line on Brass Patti Jumper cut at BJR Nagar (AE/OP)	-
4		Chakripuram	Ayyappa	33KV	Keesara	02.15	03.00	00.45		Tree fallen on 11kv line at Shakthi nagar	-
5		P&T colony	Canara nagar	33KV	Keesara	06.10	08.10	02.00		Insulaotr failed at Budda nagar	-
6		Nagaram	Bandlaguda	33KV	Keesara	04.15	05.57	01.42		Line AB swicth open at Praja sai garden due to tree fallen	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Road No.2	E-Seva	11KV	X	00.00	01.10	01.10	EL,OL	Tree branches fallen on lines at Road No.4	-----
2		Vasanthapuri	Siripuri	11KV	V	00.45	02.20	01.35	EL,OL	Disc Insulator flash over at Chandra Babu DTR	-----
3		Kalyan Nagar	Jawahar Nagar	11KV	X	01.15	02.30	01.15	EL,OL-Rph	Pin Insulator flash over at Jawahar Nagar	-----
4		Prashanth Nagar	Time Tek	11KV	VI	03.20	05.15	01.55	All Indication	O/G Cable fault	Arranged B/F on 11KV Prashanth Nagar fdr
5		R.P.Nilayam	Alwal	11KV	C-VI	04.25	07.10	02.45	EL	Pin Insulator flash over at Alwal	Arranged B/F on 11KV Madhura Enclave fdr
6		Clock Tower	Railway Reservation	11KV	V	04.30	06.25	01.55	EL,OL	RMU fault at R.P.Road Darga	-----
7		Chinna Thokatta	Hasmathpet	11KV	VI	04.47	07.34	02.47	EL	Disc Insulator flash over at Rajiv Gandhi Nagar	
8		Prashanth Nagar	Andhra Jyothi	11KV	VI	05.45	09.14	03.29	EL	Conductor snapped at R.G.Nagar Court	Arranged B/F on 11KV Ganesh Kanta feeder
9		Road No.12	Chiran Palace	11KV	X	08.27	10.15	01.48	EL	Jumper cut at Baba Pan Shop	-----
10		Gunrock	Gymkhana	11KV	C-VI	16.15	17.30	01.15	EL	No Visible Fault	-----
11		Clock Tower	Railway Reservation	11KV	V	18.12	19.13	01.01	All Indication	R.M.U Insulator flash over at Archana Arcade	-----
1	HYD S	Laxmi Nagar	Singareni Colony	11KV	VIII	00.35	02.08	01.33	EL	Jumper cut at Shishu Mandir	-
1	HYD C	Bathkammakunta	Ramalayam	11KV	II	02.10	04.15	02.05	EL,OL	Pin Insulator flash over at Govt.School DTR	-----
2		Zamistanpur	Jamai Osmania	11KV	II	02.10	06.08	03.58	EL,OL-Bph	RMU & End Kit fault at Lalitha Nagar	Arranged B/F on 11KV Balaji Nagar feeder
3		Z.P Office	Seven Temple	11KV	I	14.30	15.40	01.10	EL,OL	Pin Insulator flash over at Chinthal Basti	-----