

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		5		5		5			
7	RR(E)	168	403		6		6		6			
8	Hyd	194	1044		12		12		12			
	Total	606	3055	0	23	0	23	0	23	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	1	3	1	3	1			
2	NLG	144	988		6		6		6			
3	MDK	107	933	2		2		2				
4	SDPT			2	16	2	16	2	16			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	7	23	7	23	7	23	0	0	
	Grand Total	1082	6468	7	46	7	46	7	46	0	0	

TSSPDCL - LMRC / Corporate office

Date: 16.06.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Devarkadra	33KV	Narayanapet	18.21	18.23	00.02	E/L&O/L	Due to Cable Fault		Alternate Supply Arranged From 33KV Koukuntla at 18:23Hrs
2		Maddur	Kothapally	33KV	Narayanapet	17.25	19.45	02.20	E/L	Pin Insulator Failed Near 33KV Maddur SS		NO
3		Wanaparthy	Buddaram	33KV	Wanaparthy	19.23	20.30	01.07	E/L	Insulators failed at Polkepad		NO
1	MDK	Jogipet	G.Peddapur	33KV	Jogipet	20.05	21.20	01.15		B/D Due to Jumper Cut		-
2		Zaheerabad	Hadnoor	33KV	Zaheerabad	21.15	22.35	01.20		B/D Due to tree Branch fallen on the line		-
1	SDPT	SHANIGARAM	CHELIMEDA	33KV	Husnabad	01.12	12.00	13.12		BREAK DOWN - PIN INSULATOR FAILED		
2		CHANDLAPUR	JAKKAPUR	33KV	Siddipet	22.35	22.45	00.10		EL TO R FACE		

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 16.06.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothamolgara	Elikicherla	11KV	Jadcherla	03.00	10.10	07.10		11KV Phase To Phase Near Chegunta Road	-
1	NLG	Chervupally	Dacharam	11KV	Nalgonda	09.00	10.30	01.30	E/L	Insulator failed	-
2		Turkapally	Turkapally	11KV	Nalgonda	07.45	09.30	01.45	E/L	Jumper cut	-
3		Phanigiri	Anantharam	11KV	Suryapet	04.00	07.25	03.25	E/L	Insulator failed	-
4		Siripuram	Srirangapuram	11KV	Huzurnagar	11.20	13.00	01.40	E/L	11 KV LINE SNAPPED	-
5		Peddakandukur	Bahupet	11KV	Bhongir	04.00	09.50	05.50	E/L	11 kv Disc failed	-
6		Azeempet	Kanchanapally	11KV	Bhongir	03.00	09.30	06.30	E/L	11 kv Insulator failed	-
1	SDPT	HUSNABAD	HUSNABAD TOWN-1	11KV	HUSNABAD	10.48	12.00	02.24		RAIN EFFECT	-
2		BEJJANKI	REGULAPALLY	11KV		07.12	09.36	02.24		RAIN EFFECT	-
3		BEJJANKI	MUTHANNAPET	11KV		07.12	04.48	12.00		RAIN EFFECT TOUCHING TREE BRANCHES ON LINE	-
4		KOHEDA	THEEGALAKUNTAPALLY	11KV		01.12	00.00	13.12		PIN INSULATOR FAILED	-
5		KOHEDA	SRIRAMULAPALLY	11KV		02.24	01.12	13.12		TREE BRANCHES EFFECT	-
6		GURUVANNAPET	GURUVANNAPET	11KV		08.24	00.00	06.00		PMI	-
7		KOMURAVELLY	KOMURAVELLY AGL	11KV		10.48	07.12	10.48		RAIN EFFECT	-
8		KOMURAVELLY	Kistampet	11KV		12.00	12.00	00.00		RAIN EFFECT	-
9		GANDIPALLY	GANDIPALLY	11KV		06.00	01.12	09.36		RAIN EFFECT	-
10		Musthabad x road	Gadichelapally	11KV	SIDDIPET	16.40	17.55	01.15		B/D RAIN EFFECT	-
11		Thadkapally	Venkatapur	11KV		16.30	23.59	07.29		B/D S/P Supply avalabel	-
12		Thornal	Thornal	11KV		17.10	23.59	06.49		B/D S/P Supply avalabel	-
13		Thornal	Appanapally	11KV		17.10	18.05	00.55		B/D	-
14		Ramakkapet	Ramakkapet	11KV		15.40	23.59	08.19		B/D S/P Supply avalabel	-
15		Jangapally	veerareddypally	11KV		16.40	23.59	07.19		B/D S/P Supply avalabel	-
16		GAJWEL SS	TOWN 2 FEEDER	11KV	GAJWEL	08.15	09.25	01.10		TREE BRANCHES FALLEN ON THE 11KV LINE	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	JPTL	KSR Enclave	11KV	Kukatpally	06.35	07.35	01.00	BD	Bynding wire fallen on the ABS near Sai charan aptt	-
2		Madeenaguda	JPN Nagar	11KV	Kukatpally	15.22	17.02	01.40	BD	11KV Disk failure at Nagarjuna enclave	-
3		Gagillapur	F2	11KV	Jeedimetla	17.50	19.01	01.11	BD	Tree fallen on the 11kv line near Arora collage	-
4		Subhash Nagar	Bank Colony	11KV	Medchal	17.30	19.30	02.00	BD	Tree Fallen on 11KV Line at SR Digi School	-
5		Shameerpet	Nalsar	11KV	Medchal	18.05	18.55	00.50	BD	Tree Fallen on 11KV Line at Nalsar Road	-
1	RR E	Boduppal	Ayyappa	11KV	Habsiguda	17.30	18.40	01.10		Insulator failed at road no 6 Balaji hills	-
2		Moula ali	Malkajgiri	11KV	Sainikpuri	17.13	18.22	01.09		11Kv line cut at Hanumna Nagar near Bilal Majid (Artisian Raju)	-
3		Vayupuri	Lakshmipuram	11KV	Sainikpuri	15.57	17.27	01.30		11Kv Pin Insulator failed at TVS Show Room near AS Rao Nagar (LM Anil)	-
4		Peerzathiguda	Uppalhills	11KV	Keesara	15.30	16.20	00.50		Copper patti cut at kurma nagar	-
5		Narapally	P.singaram	11KV	Keesara	17.05	17.50	00.45		Tree branches fallen on 11kv line at Korremulla	-
6		Yadgarpally	Yadgarpally	11KV	Keesara	14.25	14.50	00.25		Tree branches fallen on 11kv Medi bhavi	-
1	HYD N	Madhapur	Vedam	11KV	Banjarahills	15.20	17.20	02.00	EL,OL	Tree branches fallen on lines	Arranged B/F on 11KV APIIC-II fdr
2		Nehru Nagar	Rezimental Bazar	11KV	Sec-Bad	17.10	20.24	03.14	All Indication	Moixture formed in R.M.U	Arranged B/F on 11KV St.Marry fdr
1	HYD S	Malakpet B-Block	LIC Colony	ST	VIII	15.44	16.59	01.15	OL-Rph	DTR Cable End Kit failed near Green Point Hotel	-
2		Asmangadh	Asmangadh	ST	VIII	17.05	18.43	01.38	OL-Yph	Tree branches fallen on lines at Madhava Nagar	-
3		Osm. Hospital	Puranaphool UG	ST	IX	17.32	18.55	01.23	EL,OL-Bph	Disc Insulator flash over at Jummerath Bazar	-
4		Falaknuma	Falaknuma OH	ST	III	17.40	19.00	01.20	EL,OL	UG Cable fault at Jahanuma	-
5		Asmangadh	P & T Colony	ST	VIII	18.20	19.20	01.00	OL-Rph	No Visible Fault	Arranged B/F on 11KV Singareni Colony feeder
6		Yakuthpura	Sravani Hospital	ST	VIII	18.21	20.58	02.37	OL-R&Yph	Disc Insulator flash over at Agriculture University DTR	-
1	HYD C	Mothi Mahal	Saleh Nagar	CEN	VII	15.47	17.18	01.31	EL,OL	Line AB Switch Pin Insulator flash over at Dhan Kot	-
2		Golconda	Q.Q Toombs	CEN	VII	16.35	17.45	01.10	EL,OL-Bph	Pin Insulator flash over & Brass Patti cut at Q.Q Toombs	-
3		Amberpet	Tilak Nagar	CEN	II	17.00	18.15	01.15	EL,OL-Rph	Tree branches fallen on lines at H.P Petrol Bunk	-
4		Asif Nagar	Padmanaba Nagar	CEN	VII	18.37	20.01	01.24	EL,OL	Tree branches fallen on lines	Arranged B/F on 11KV Avalon fdr