

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		3		3		3			
6	RR(N)	54	550	1	15	1	15	1	15			
7	RR(E)	168	403		6		6		6			
8	Hyd	194	1044		19		19		19			
	Total	606	3055	1	43	1	43	1	43	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		4		4		4			
3	MDK	107	933	1	5	1	5	1	5			
4	SDPT				7		7		7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	17	1	17	1	17	0	0	
	Grand Total	1082	6468	2	60	2	60	2	60	0	0	

TSSPDCL - LMRC / Corporate office

Date: 18.06.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Gummadidala	GPSS-2	33KV	Patancheru	18.07	20.40	02.33		BD due to Jumper cut	GPSS-2	-
1	RR N	132KV LGM Pet	33KV MN Park	33KV	Medchal	10.57	11.55	00.58	BD	33KV Line AB Switch Opened at BE SEZ Company(Lighting Arrester Failed And Replaced)	33KV MN Park	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 18.06.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kaverammamet	Bandamidipally	11KV	Jadcherla	08.45	10.03	01.18		11KV Insulator failed Near Thanda	-
1	NLG	Pamanagundla	Pittampally	11KV	Nalgonda	12.00	17.05	05.05	EL	Thatimatta fallen on 11KV line	-
2		Narsingbatla	Narsingbatla AGL	11KV	Nalgonda	10.50	14.15	03.25	EL	11 KV Jumper Cut	-
3		Jalalpuram	Gottiparthi	11KV	Suryapet	08.00	13.20	05.20	EL	132/33KV SS Nutral wire cut and fallen on the 11KV Feeder	-
4		Panhangi	Panhangi Agl	11KV	Choutuppal	13.04	14.50	01.46	EL	11kv Disc Failed near Panthnagi Village	-
1	MDK	EPIP-II	Srinivasa Costing	11KV	Sangareddy	18.25	19.46	01.21		BD due to Tree fallen on line	-
2		SOL	Markwell	11KV	Patancheru	18.05	21.25	03.20		BD due to Insulator failed	-
3		Patancheru Town	BSNL	11KV	Patancheru	18.25	19.25	01.00		BD due to Tree fallen on line	-
4		Anrich Bollaram	Town-II	11KV	Patancheru	11.46	12.55	01.09		BD due to Tree fallen on line	-
5		Gummadidala	Bell Remedies	11KV	Patancheru	02.10	08.15	06.05		BD due to Jumper cut	-
1	SDP	Guruvannapet	Guruvannapet	11KV	Husnabad	18.50	06.10	12.20		Haevy gale and wind (3-Ph)	-
2		Regulapally	Mallamchervu	11KV	Husnabad	09.35	10.46	01.11		Insulator fail	-
3		GAJWEL PREGNAPUR SS	TOWN 1 FEEDER LC NO. 6201	11KV	Gajwel	11:03	1:38	2:35		POLE DAMAGE	-
4		PREGNAPUR SS	GUNDANNAPALLY AGL FEEDER	11KV	Gajwel	17.20	06.24	14.04		BREAKDOWN NOT RECTIFIED PPUR SS NO 9492081482	-
5		MULUGU SS	MULUGU AGL FEEDER LC NO. 14448	11KV	Gajwel	10:35	15:45	5:10		1PHASE DTR FAILED	-
6		MULUGU SS	TOWN FEEDER LC NO. 14449	11KV	Gajwel	21:15	22:40	1:25		TREE BRANCHES FALLEN ON THE 11KV LINE	-
7		DOULTHABAD SS	DEEPAMPALLY FEEDER LCNO. 1845	11KV	Gajwel	10.33	12.13	01.40		BROCKEN POLE WORK	-
1	RR S	Papireddy Colony	Prem Nagar	11KV	Gachibowli	18.05	19.50	01.45		Tree branches fallen on 11kv line at CM Thota(Due to heavy rain)	-
2		Papireddy Colony	Rajiv Swagruha	11KV	Gachibowli	15.00	17.30	02.30		11kv End=kit failed on box pole at Block no.ED-I	-
3		IIIT	GPRA	11KV	Gachibowli	18.31	19.35	01.04		11kv Insulator failed at Laxmi Apartment beside	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Mayurinagar	Ramnaresh nagar	11KV	Kukatpally	18.40	19.50	01.10	BD	11kv Pin Insulator failure at Mithra hills Aptt	-
2		Aleap	Madhuranagar	11KV	Jeedimetla	19.00	20.25	01.25	BD	Tree Fallen the 11kv line at plot:1301, Madhuranagar,{Due to rain}	-
3		Jeedimetla-IV	AAIMatha	11KV	Jeedimetla	10.42	12.00	01.18	BD	11kv AB Cable Failed at AAIMatha, Given B/FJDM SS-I	-
4		Gagillapur	Sundara Asramam	11KV	Jeedimetla	18.40	19.45	01.05	BD	Tree Fallen the 11kv line at paper mill, Duddigal	-
5		HMT	Ganesh Nagar	11KV	Medchal	15.45	16.25	00.40	BD	100KVA T/F 11KV Pin Insulator failed at NTR Nagar	-
6		Subhash Nagar	Jairam Nagar	11KV	Medchal	17.50	18.18	00.28	BD	11KV Line AB Switch Opened at Srujana Hospital(Disc Failed at Rukmini Estate)	-
7		Petbasheerabad	St. Ann's	11KV	Medchal	18.30	19.50	01.20	BD	11KV Jumper Opened at PSR Convension Center(Tree Fallen on 11KVLine)	-
8		Kompally	NCL	11KV	Medchal	18.22	19.10	00.48	BD	Tripped on EL Indication (Due to rain and gale)	-
9		Subhash Nagar	Gayathri Nagar	11KV	Medchal	19.20	20.32	01.12	BD	11KV Pin Insulator failed and replaced at SS Backside	-
10		Subhash Nagar	Pragha Tools	11KV	Medchal	18.19	19.32	01.13	BD	11KV Line AB Switch opened at Mayuri Bar(No Fault)	-
11		Chintal	Dwaraka Nagar	11KV	Medchal	19.25	21.05	01.40	BD	11KV AB Cable Failed & removed at Manikya Nagar Community Hall	-
12		Shameerpet	Thumkunta	11KV	Medchal	09.05	13.00	03.55	BD	11KV Jumper Opened at ORR(Some Load Added to 11KV Thumkunta Feeder from Thumkunta SS)(11KV UG Cable Failed)	-
13		Devarayamjal	Pothaipally	11KV	Medchal	18.20	19.45	01.25	BD	11KV Conductor Snapped and replaced at Yamjal Village	-
14		Kistapur	Suma Biscuit	11KV	Medchal	18.20	19.50	01.30	BD	11KV Pin Insulator Failed and replaced at Suma Biscuit	-
15		GP Pally	GP Pally	11KV	Medchal	18.35	21.10	02.35	BD	11KV Pin Insulator failed and replaced at Flipkart Store	-
1	RR E	Moula-Ali	Jawahar Nagar	11KV	Sainikpuri	18.30	19.19	00.49		11Kv Disk on Insuletor fail at Old Andhra Bank (Artisan/Janaiah)	-
2		Vinayak Nagar	RK Nagar	11KV	Sainikpuri	20.40	21.48	01.08		11Kv Pin Insuletor fail at RK Nagar (AE/OP)	-
3		IDAuppal	Metro	11KV	Habsiguda	19.26	21.00	01.34		11kv line Insulator fail at RN Fillter	-
4		Peerzathiguda	Chinna reddy	11KV	Keesara	18.35	19.46	01.11		Ab swicth Post of insulator fail at Pakala	-
5		Peerzathiguda	Peerzathiguda	11KV	Keesara	18.35	20.10	01.35		CT Cable touched at 11kv line	-
6		Singapur	Annojiguda	11KV	Keesara	19.00	20.40	01.40		Insulator fail at Sai nagar colony	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Prashasan Nagar	B.R.R Hills	11KV	X	15.30	17.04	01.34	EL	Pin Insulator flash over at Road No.51	-----
2		Pragatools	L & T	11KV	VI	18.14	20.55	02.41	EL,OL-Rph	Tree branches fallen on lines at Opp: Eenadu	-----
3		Bhudevi Colony	L.N Colony	11KV	C-VI	19.30	21.55	02.25	EL,OL	Disc Insulator flash over at AWHO Colony Gate	-----
4		Gunrock	Gymkhana	11KV	C-VI	18.25	20.20	01.55	OL	Auto Reclosure Jumper cut at Opp: Bowenpally Market	-----
5		New Bowenpally	Reliance Villa	11KV	VI	18.25	21.00	02.35	EL,OL	No Visible Fault	Arranged B/F on 11KV Chandana Hospital fdr
6		Nehru Nagar	West Marredpally	11KV	C-VI	18.25	19.30	01.05	AR tripped	No Visible Fault	-----
7		Gymkhana	Vasavi Nagar	11KV	C-VI	18.40	20.08	01.28	EL,OL-Rph	HT Jumper cut at Community Hall	-----
1	HYD S	Vittalwadi	Narayanguda W.W	11KV	IX	18.25	20.20	01.55	EL,OL-Rph	Tree branches fallen on lines at Venkateshwara Colony	-
1	HYD C	I.T.I Mallepalli	Indira Nagar	11KV	VII	18.25	19.59	01.34	EL,OL	Pin Insulator flash over at Indira Nagar	-----
2		Fever Hospital	Barkathpura Bus Depot	11KV	II	18.44	20.40	01.56	EL	Tree branches fallen on lines at Barkathpura Bus Depot	-----
3		Narayanaguda	Chikkadapally	11KV	II	18.45	21.15	02.30	AR tripped	Sparkings line AB Switch at Srirama Complex	20:30 Hrs Partial charged (5no DTR off)
4		Industrial Area	Shankermutt	11KV	II	19.00	20.15	01.15	EL	Tree branches fallen on lines at Mathru Sri	-----
5		Narayanaguda	Preventive Medcine	11KV	II	19.05	21.15	02.10	EL,OL-R&Bph	Insulator flash over at Narayanguda Nala	-----
6		Bathakamma Kunta	Ayyappa Temple	11KV	II	18.33	22.50	04.17	EL	Disc Insulator flash over at Hanumanth Rao House	-----
7		Industrial Area	RTC X Road	11KV	II	18.45	22.00	03.15	EL	HT jumper & Tree branches fallen on lines at RTC Bus Bhavan	-----
8		Industrial Area	Azamabad IE	11KV	II	18.45	22.30	03.45	EL	Tree branches on lines at Achi Reddy Marg	-----
9		Asif Nagar	Hakimpet	11KV	VII	18.17	21.05	02.48	EL	Tree branches on lines at Hakimpet	-----
10		Asif Nagar	Mehdipatnam OH	11KV	VII	18.17	20.30	02.13	EL	Tree branches on lines at Mehdipatnam	-----
11		Asif Nagar	Kakatiya Nagar	11KV	VII	18.35	20.38	02.03	EL,OL	Cable fault near SS	Arranged B/F on 11KV Military Hospital fdr