

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		6		6		6			
3	MDK	107	933		1		1		1			
4	SDPT				6		6		6			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>13</b>	<b>0</b>	<b>13</b>	<b>0</b>	<b>13</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>18</b>	<b>0</b>	<b>18</b>	<b>0</b>	<b>18</b>	<b>0</b>	<b>0</b>	



S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	B.Vellemla	Auravani	11KV	Nalgonda	0:14	7:30	7:16	E/L	11KV Insulators failed	No
2		Palem	Palem	11KV	Nalgonda	03.05	06.00	02.55	E/L	11KV Jumper cut	No
3		Koppole	Bheemaram	11KV	Nalgonda	11.00	14.50	03.50	E/L	11KV Jumper cut	No
4		Bopparam	M.K.Gudem	11KV	Suryapet	03.30	07.10	03.40	E/L	Conductor Snapped	No
5		Keethavarigudem	Rainigudem	11KV	Huzurnagar	06.00	08.20	02.20	EL	11KV Line snapped	No
6		Sirikonda	Ravipahad	11KV	Huzurnagar	13:30	14:40	1:10	EL	11KV Line snapped	No
1	MDK	Patancheru Town	Kanjarla	11KV	Patancheru	2:50	5:30	2:40		Jumper cut	No
1	SDPT	Irkdoe	Irkdoe	11KV	Siddipet	10:35	14:35	4:00		11KV Disc failed	No
2		Gurrallagondi	Malyala	11KV	Siddipet	09.55	11.55	02.00		11KV Jumper cut	No
3		Markook SS	11 KV Markook Agl	11KV	Gajwel	12:20	12:45	00:25		Insulator failed	No
4		Bejjanki	Muthannapet	11KV	Husnabad	15.00	16.45	01.45		Insulator failed	No
5		Koheda	Cannal	11KV	Husnabad	09.40	17.10	07.30		Insulator failed	No
6		Chityal	Dommata	11KV	Husnabad	4:05	6:50	2:45		Insulator failed	No
1	RR N	HMT	Ganesh Nagar	11KV	Medchal	14:20	15:45	1:25		11KV Line cut and replaced at Kalpana Society	No
2		Kandlakoya	KV Reddy Nagar	11KV	Medchal	13.45	15.30	01.45		Tree fallen on 11KV line at Kandlakoya Village	No
1	HYD N	Addagutta	Hanuman Temple	11KV	C-VI	09.15	10.35	01.20	EL	Cable fault at MCH Park	Arranged B/F on 11KV Nehru Nagar feeder
1	HYD S	Hyderguda	Jana Priya OH	11KV	III	08.05	09.58	01.53	EL	Cable fault	Arranged B/F on 11KV Hyderguda fdr
1	HYD C	Fever Hospital	Fever Hospital	11KV	II	07.54	09.02	01.08	All Indication	Big tree fallen on lines at Barkathpura Cheman	No