

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	9	0	9	0	9	0	0	
	Grand Total	1082	6468	0	11	0	11	0	11	0	0	



S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Balanagar	Kethireddypally	11KV	Jadcherla	10.01	11.21	01.20		Bird died on the 11KV line near Ekvaipally Mamidipally Thota.	No
1	NLG	G.T Giri	Bakthalapuram	11KV	Suryapet	13:01	14:05	1:04	E/L	11KV Conductor snapped	No
2		Chanupally	Palaram	11KV	Huzurnagar	14.00	15.30	01.30	EL	11KV Conductor snapped	No
3		NG.Bandal	Gandamalla	11KV	Bhongir	19.15	08.15	13.00	EL/OL	11KV Insulator failed at Booster near Gandamalla (V)	No
4		Yennaram	Kunkudupamula	11KV	Choutuppal	03.40	06.10	02.30	EL/OL	11KV Line snapped near Venkatapuram (V)	No
1	SDPT	Kondapak	Thimmareddypally	11KV	Gajwel	7:30	8:40	1:10		Conductor snapped	No
2		kodakandla	kodakandla	11KV	Gajwel	04.45	07.50	03.05		Insulator failed	No
3		Koheda	Sriramulapally	11KV	Husnabad	03.10	05.30	02.20		Insulator failed	No
4		Pedda Kodur	Chinna Kodur	11KV	Siddipet	14.30	16.50	02.20		AB Switch jumper problem	No
1	RR N	Bowrampet	AGL	11KV	Jeedimetla	13:50	14:50	1:00	EL	Lizard fallen on the 11kv line at Gopal reddy T/F	No
1	RR E	Sainikpuri	Ramalayam	11KV	Sainikpuri	19:50	21:16	1:26		11KV Line cut and pin insulator failed at Defence Colony	No