

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988	1	8	1	8	1	8			
3	MDK	107	933	1		1		1				
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	12	3	12	3	12	0	0	
	Grand Total	1082	6468	3	19	3	19	3	19	0	0	

TSSPDCL - LMRC / Corporate office

Date: 24.06.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Damargidda	33KV	Narayanapet	00.20	08.25	08.05		Insulator fail near mosthapet (V)		NO
1	NLG	Suryapet	Chandupatla	33KV	Huzurnagar	00.15	10.05	10.10		33 kv inslater failed		-
1	MDK	Bollaram	Meenakshi	33KV	Patancheru	13.50	16.20	02.30		B/D Due to Conductor Snapped		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 24.06.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Narkatpally	Mandra	11KV	Nalgonda	11.20	12.45	01.25	EL	Insulator failed	-
2		Koppole(K)	Kopolu	11KV	Nalgonda	13.40	15.00	01.20	EL	Jumper cut	-
3		Kudakuda	Komatikunta	11KV	Suryapet	09.40	12.10	02.30	EL	Conductor Snapped	-
4		Yerkaram	Yerkaram	11KV	Suryapet	07.40	11.30	03.50	EL	Disc Failure	-
5		Athmakur(S)	T.Penpahad	11KV	Suryapet	06.00	08.30	02.30	EL	Jumper cut	-
6		Kalmalcheruvu	Kalmalcheruvu	11KV	Huzurnagar	04.00	06.30	02.30	EL	11 KV LINE SNAPPED	-
7		Siripuram	Vallapuram	11KV	Huzurnagar	05.00	07.25	02.25	EL	11 KV JUMPER CUT	-
8		MT.Pally	Dathaipally	11KV	Bhongir	06.00	10.00	04.00	EL	11 KV Line snapped	-
1	SDPT	AHMEEDPUR	KOLUGUR (LC No: 19803)	11KV	Siddipet	15:30	16:15	0:45		Breakdown Insulator failed	-
2		VARDHARAJPUR	VARDHARAJPUR (LC No: 25088)	11KV	Siddipet	10:45	12:15	1:30		Breakdown Insulator failed	-
3		RAMSAGAR	RAMSAGAR (LC No: 10852)	11KV	Siddipet	16:15	17:20	1:05		Breakdown Insulator failed	-
4		RAIPOLE	RAIPOLE AGL (LC No:10987)	11KV	Siddipet	07:30	10:00	2:30		Breakdown 11KV Wire cut	-
1	RR N	Subhash Nagar	Gayatri Nagar	11KV	Medchal	17.45	18.24	00.39		11KV Pin Insulator failed at Omsai Residency	-
1	RR E	Uppal	Chilaka Nagar	11KV	Habsiguda	00.10	00.50	00.40		11KV Cable damaged near Monday Market Anjaneya Swamy Temple	-
2		Yapral	Pedso	11KV	Habsiguda	00.10	01.05	00.55		Lorry Dashed on 3 11Kv Pole Damage at near Hanuman Temple (AE/OP)	-
1	HYD N	Prashanth Nagar	Time Tek	11KV	Bowenpally	02.10	03.40	01.30	EL	No Visible Fault	Partial fdr charged at 02:30Hrs & remaining loads added on 11KV Prashanth Nagar fdr
2		Zamistanpur	MCH Park	11KV	Sec-Bad	18.55	20.03	01.08	EL,OL-Bph	HT/LT Conductor snapped at SBI, Opp MCH Park	-
3		LV Prasad Marg	LV Prasad Marg	11KV	Banjarahills	19.06	20.32	01.26	EL,OL	DTR fault at Hanuman Temple	(1no DTR off)
1	HYD S	Yakuthpura	Khan Nagar	11KV	Asmangadh	10.38	11.59	01.21	EL	O/G Cable fault near Kachrakundi PT	Arranged B/F on 11KV Saleema Khaton fdr