

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		7		7		7			
3	MDK	107	933		2		2		2			
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	13	1	13	1	13	0	0	
	Grand Total	1082	6468	1	14	1	14	1	14	0	0	

TSSPDCL - LMRC / Corporate office

Date: 25.06.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Gadwal	Oil Seeds	33KV	Gadwal	16.21	17.45	01.24		Due to Breaker Problem	Oil Seeds	Alternat Supply Arranged From 132KV SS Alampur at 17:45Hrs.

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 25.06.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Bheelya Naik thanda	Bheelyanaik thanda	11KV	Huzurnagar	03.50	06.50	03.00	E/L	11kv line snapped	-
2		Ananthagiri	Kistapuram	11KV	Huzurnagar	08.40	10.20	01.40	E/L	Bird fall on 11kv line	-
3		Rajapeta	Nemila	11KV	Bhongir	03.00	10.00	07.00	E/L	11kv Disc failed near Nemila (V)	-
4		Chamapur	Chamapur	11KV	Bhongir	03.40	10.50	07.10	E/L	100 kva DTR Failed at SS-1 near Eluka bavi (V)	-
5		Choutuppal	Jublakpally	11KV	Choutuppal	20.30	11.45	15.45	E/L	11kv Pole Dammaged near Choutuppal (V)	-
6		Narketpally	Y.R.Guda	11KV	Nalgonda	12.15	15.00	02.45	E/L	11KV Jumper cut	-
7		Nakrekal	Kadaparthi	11KV	Nalgonda	06.25	11.30	05.05	E/L	11KV Insulators failed	-
1	MDK	Sangareddy Town-I	Kulabgur	11KV	Sangareddy	08.15	08.55	00.40		B/D due to Jumper cut	-
2		Gummadidala	Mambapur	11KV	Patancheru	02.00	08.05	06.05		B/D due to Tree branches fallen on the line	-
1	SDP	Narsapur	Karimnagar IND	11KV	Siddipet	11.25	11.45	00.20		B/D Issulater problem Lc.no.36014	-
2		Y.G.KISTAPUR	THIRUMALAGIRI (LC No: 20168)	11KV	Gajwel	06.00	13.00	07.00		TIPPER DASH POLE DAMAGED (Thukkapur SS 94920 65621)	-
3		Y.G.KISTAPUR	BANJERPALLY (LC No: 20169)	11KV	Gajwel	12.40	14.45	02.05		2Nos INSULATOR FAILED	-
4		PALLEPHAD	VEMULA GHAT (LC No: 0822)	11KV	Gajwel	13.30	14.35	01.05		11KV WIRE CUT	-
1	HYD C	Asif Nagar	Padmanaba Nagar	11KV	VII	17.10	18.20	01.10	EL,OL-Rph	Tree branches fallen on lines at Padmanabha Nagar (4No. DTR's Kept Off)	-