

TSSPDCL - LMRC / Corporate Office
Half-Hourly Demand Recorded in MW for 26.06.2020 (Friday)

Report Generation Date : 27-Jun-2020

Time	Freq.	T-ELR	MBN	NLG	MDK	HYD	RR	SPDCL SCH	SPDCL (ABT- RMD)	UNR- dmd	Diff	GH-dmd	Circle Total
1	2	3	4	5	6	7	8	9	10	11	12(10-9)	13	14
00:00 - 00:30	50.04	0	599	646	827	786	742	4393	4511	4511	118	1528	3600
00:30 - 01:00	50.03	0	599	646	827	786	742	4474	4607	4607	133	1528	3600
01:00 - 01:30	50.02	0	597	670	814	744	716	4480	4700	4700	220	1460	3541
01:30 - 02:00	50.00	0	597	670	814	744	716	4468	4652	4652	184	1460	3541
02:00 - 02:30	50.00	0	610	771	812	711	704	4442	4690	4690	248	1415	3608
02:30 - 03:00	50.03	0	610	771	812	711	704	4424	4691	4691	267	1415	3608
03:00 - 03:30	50.04	0	634	779	831	699	698	4407	4652	4652	245	1397	3641
03:30 - 04:00	50.00	0	634	779	831	699	698	4419	4635	4635	216	1397	3641
04:00 - 04:30	49.98	0	633	795	836	699	716	4417	4644	4644	227	1415	3679
04:30 - 05:00	49.97	0	633	795	836	699	716	4421	4664	4664	243	1415	3679
05:00 - 05:30	49.94	0	723	845	913	722	749	4522	4628	4628	106	1471	3952
05:30 - 06:00	50.00	0	723	845	913	722	749	4619	4759	4759	140	1471	3952
06:00 - 06:30	50.03	0	775	817	984	761	816	5032	4952	4952	-80	1577	4153
06:30 - 07:00	50.04	0	775	817	984	761	816	5254	5065	5065	-189	1577	4153
07:00 - 07:30	49.92	0	768	783	997	815	860	5385	5228	5228	-157	1675	4223
07:30 - 08:00	50.02	0	768	783	997	815	860	5375	5343	5343	-32	1675	4223
08:00 - 08:30	50.06	0	770	693	985	889	895	5496	5423	5423	-73	1784	4232
08:30 - 09:00	50.03	0	770	693	985	889	895	5605	5451	5451	-154	1784	4232
09:00 - 09:30	49.99	0	776	691	991	938	922	5637	5520	5520	-117	1860	4318
09:30 - 10:00	49.98	0	776	691	991	938	922	5694	5595	5595	-99	1860	4318
10:00 - 10:30	49.98	0	815	706	987	985	954	5684	5673	5673	-11	1939	4447
10:30 - 11:00	50.03	0	815	706	987	985	954	5693	5691	5691	-2	1939	4447
11:00 - 11:30	50.06	0	804	712	967	1006	943	5761	5707	5707	-54	1949	4432
11:30 - 12:00	50.02	0	804	712	967	1006	943	5769	5723	5723	-46	1949	4432

TSSPDCL - LMRC / Corporate Office
Half-Hourly Demand Recorded in MW for 26.06.2020 (Friday)

Report Generation Date : 27-Jun-2020

Time	Freq.	T-ELR	MBN	NLG	MDK	HYD	RR	SPDCL SCH	SPDCL (ABT- RMD)	UNR- dmd	Diff	GH-dmd	Circle Total
1	2	3	4	5	6	7	8	9	10	11	12(10-9)	13	14
12:00 - 12:30	50.00	0	792	687	969	1021	944	5766	5761	5761	-5	1965	4413
12:30 - 13:00	50.00	0	792	687	969	1021	944	5769	5806	5806	37	1965	4413
13:00 - 13:30	50.03	0	799	707	975	976	941	5666	5639	5639	-27	1917	4398
13:30 - 14:00	50.03	0	799	707	975	976	941	5654	5644	5644	-10	1917	4398
14:00 - 14:30	49.95	0	811	728	970	945	936	5689	5740	5740	51	1881	4390
14:30 - 15:00	49.98	0	811	728	970	945	936	5751	5563	5563	-188	1881	4390
15:00 - 15:30	49.97	0	807	709	983	913	931	5813	5525	5525	-288	1844	4343
15:30 - 16:00	49.83	0	807	709	983	913	931	5869	5456	5456	-413	1844	4343
16:00 - 16:30	49.98	0	731	513	961	905	898	5839	5578	5578	-261	1803	4008
16:30 - 17:00	49.92	0	731	513	961	905	898	5752	5428	5428	-324	1803	4008
17:00 - 17:30	49.98	0	663	463	874	884	890	5260	5080	5080	-180	1774	3774
17:30 - 18:00	49.95	0	663	463	874	884	890	4814	4757	4757	-57	1774	3774
18:00 - 18:30	50.04	0	647	520	846	947	916	4803	4501	4501	-302	1863	3876
18:30 - 19:00	49.94	0	647	520	846	947	916	4816	4544	4544	-272	1863	3876
19:00 - 19:30	50.00	0	642	534	826	943	926	4878	4811	4811	-67	1869	3871
19:30 - 20:00	49.94	0	642	534	826	943	926	4886	4827	4827	-59	1869	3871
20:00 - 20:30	49.99	0	611	535	823	915	908	4731	4735	4735	4	1823	3792
20:30 - 21:00	49.99	0	611	535	823	915	908	4657	4752	4752	95	1823	3792
21:00 - 21:30	50.04	0	609	532	820	908	889	4587	4567	4567	-20	1797	3758
21:30 - 22:00	50.04	0	609	532	820	908	889	4581	4570	4570	-11	1797	3758
22:00 - 22:30	49.92	0	622	558	822	888	864	4421	4532	4532	111	1752	3754
22:30 - 23:00	49.97	0	622	558	822	888	864	4342	4532	4532	190	1752	3754
23:00 - 23:30	49.98	0	635	574	870	850	864	4370	4498	4498	128	1714	3793
23:30 - 00:00	50.03	0	635	574	870	850	864	4356	4489	4489	133	1714	3793
Max for Day	50.06	0	815	845	997	1021	954	5869	5806	5806	267	1965	4447
Min for Day	49.83	0	597	463	812	699	698	4342	4489	4489	-413	1397	3541

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		8		8		8			
3	MDK	107	933									
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	11	0	11	0	11	0	0	
	Grand Total	1082	6468	0	12	0	12	0	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 26.06.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	RR S				NIL							-
5	RR N				NIL							-
6	RR E				NIL							-
7	HYD N				NIL							-
8	HYD S				NIL							-
9	HYD C				NIL							-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 26.06.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Thimmanagudem	T.K.Gudem	11kv	Nalgonda	00.40	06.10	05.30	EL	11 KV Jumper Cut	-
2		Thurkapally	M.Gouraram	11kv	Nalgonda	00.30	11.25	10.55	EL	11 KV Insulator Failed	-
3		Eduloor	Parada	11kv	Nalgonda	09.45	11.30	01.45	EL	11 KV Jumper Cut	-
4		Nakrekal	Police Station	11kv	Nalgonda	13.30	14.12	00.42	EL	Bird Died on the Line	-
5		Koduru	Thimmapuram	11kv	Suryapet	07.30	10.45	03.15	E/L	Insulator flashover	-
6		Munagala	Barakathgudem	11kv	Huzurnagar	07.40	09.10	01.30	EL	11 KV LINE SNAPPED	-
7		Bollepally	Jampally	11kv	Bhongir	09.00	09.40	00.40	EL/OL	11 kv Line snapped near Mandapuram village	-
8		Voligonda	Mandhapuram	11kv	Choutuppal	10.30	14.50	04.20	EL/OL	11kv Line Snapped near Lingarajupally Village	-
1	SDPT	NAMTOOR	JABBAPUR FEEDER	11kv	Gajwel	05.35	10.05	04.30		11KV LINE CUT	-
2		DAMARAKUNTA	DAMARAKUNTA INDUSTRIAL	11kv	Gajwel	09:40	12:40	03.00		INSULATOR FAILED	-
3		PAMULAPARTHI	PATHURU INDHIRA NAGAR FEEDER	11kv	Gajwel	08:00	10:00	2:00		TREE BRANCHES FALLEN	-
1	RR N	Aliabad	HBL	11kv	Medchal	00.15	01.25	01.10	EL	Tree Branches fallen on the Line at Sangeeth Function Hall, Aliabad	-