

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		14		14		14			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		97		97		97			
	Total	606	3055	0	114	0	114	0	114	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	4		4		4				
2	NLG	144	988		4		4		4			
3	MDK	107	933		1		1		1			
4	SDPT			3	5	3	5	3	5			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	7	10	7	10	7	10	0	0	
	Grand Total	1082	6468	7	124	7	124	7	124	0	0	

TSSPDCL - LMRC / Corporate office

Date: 27.06.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Maddur	33KV	Mogalmadka	23.15	01.35 (28.06.20)	02.20	E/L	Due to Rain , AB Switch open at Kankurthy		No
2		PolePally	APL Helth Care	33KV	Jadcherla	03.03	18.00	14.57	E/L	Cable Changed at APL Helth Care		No
3		Mahabubnagar	Hanwada	33KV	Mahabubnagar	21.22	22.00	00.38	E/L	Due to Rain		Alternate supply Arrnaged form 132KV SS Maddur to 33KV Vepoor from 22:00Hrs
4		Alwal	Padkal	33KV	RR South Circle	20.38	21.28	00.50	E/L	Due to Rain ,No visibule fault		No
1	SDPT	Doultabad	Raipole	33KV	Gajwel	20.40	21.49	01.09		BD (Due to Rain)		-
2		Chandlapur	Vittalapur	33KV	Siddipet	21.30	23.30	02.00		B/D Due to Rain		-
3		Chandlapur	Kamarlapally	33KV	Siddipet	21.50	22.55	01.05		B/D Due to Rain		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 27.06.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Velugupally	Pasnoor	11KV	Suryapet	02.30	06.40	04.10	E/L	Insulator flashover	-
2		Mukunadapuram	Somaram	11KV	Huzurnagar	10.55	13.30	02.35	E/L	11 KV INSLATER FAILED	-
3		NG.Bandal	Gandamalla	11KV	Bhongir	11.40	15.00	03.20	E/L	11 kv Line snapped	-
4		Venkiryala	Padamatisomaram	11KV	Bhongir	00.15	06.30	06.15	E/L	100 kva DTR Failed	-
1	MDK	Hathnoora	Town Ind	11KV	Jogipet	10.25	11.20	00.55		BD Due to 11kv jumpercut	-
1	SDPT	Raghavapoor	Peddalingareddypally	11KV	Siddipet	00.36	10.45	10.09		B/D LT Face To Face	-
2		BANDARAM	DARGA AGL (LC No: 38319)	11KV	Gajwel	15.00	18.10	03.10		11KV WIRE CUT	-
3		ERRAVALLY	ERRAVALLY AGL (LC No: 26319)	11KV		15:07	16:02	00.55		11KV CONDUCTOR CUT	-
4		Bejjanki	Regulapally	11KV	Husnabad	02.05	07.05	05.00		Haevy gale and wind (3-Ph)	-
5		Chityala	Dommata	11KV		00.00	08.05	08.05		Insulator fail	-
1	RR N	Dulapally	Dulapally Village	11KV	Medchal	16.46	17.46	01.00	BD	11KV Line cut & Replacement at Dulapally Main road	-
2		HMT	Qutubullapur	11KV	Medchal	16.56	18.00	01.04	BD	Tripped on EL Indication (Heavy wind & Rain)	-
3		Jagathgirigutta	IDA Jagathgirigutta.	11KV	Medchal	17.05	19.10	02.05	BD	Line AB Switch opened Paipe Line road	-
4		Subhash Nagar	Padma Nagar	11KV	Medchal	16.45	20.06	03.21	BD	Tree fallen on the 11KV Line at Sriram Nagar	-
5		Subhash Nagar	Jeedimetla	11KV	Medchal	17.31	18.55	01.24	BD	Tree Branches fallen on the 11KV Line at Green park	-
6		Subhash Nagar	Jayaram Nagar	11KV	Medchal	17.29	18.59	01.30	BD	Tree Branches fallen on the 11KV Line at SBI Bank	-
7		Chintal	Dwaraka Nagar	11KV	Medchal	17.25	18.50	01.25	BD	Tripped on EL Indication(No fault)	-
8		Kompally	Dholari Dhani	11KV	Medchal	17.40	18.56	01.16	BD	Tripped on EL Indication(No fault)	-
9		Petbasheerabad	vaishnavi Enclve	11KV	Medchal	17.37	19.10	01.33	BD	Tree Branches fallen on the 11KV Line at Balaji Hospital	-
10		HMT	Manikya Nagar	11KV	Medchal	19.53	21.58	02.05	BD	11KV Disc failed at Chintal Market	-
11		Petbasheerabad	Balaji Hospital	11KV	Medchal	19.20	21.00	01.40	BD	Tree Branches fallen on the Line at SN Reddy Enclve	-
12		Chintal	Dwaraka Nagar	11KV	Medchal	19.50	21.10	01.20	BD	11KV PinInsulator failed at Dwaraka Nagar	-
13		Petbasheerabad	vaishnavi Enclve	11KV	Medchal	20.37	21.35	00.58	BD	Tree Branches fallen on the Line at Arsha Hospital	-
14		Medchal	IDA Kandlakoya	11KV	Medchal	18.45	19.45	01.00	BD	11KV Line cut & replacement at Beer company	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR E	Moula ali	Jawahar Nagar	11KV	Sainikpuri	18.00	18.50	00.50		11Kv 2Nd AB Switch opened at Old Andhra Bank Due to Pin Insulator failed (Atrisian Narshima)	-
2		Sainikpuri	Sainikpuri	11KV	Sainikpuri	17.30	18.50	01.20		Tree fallen on 11Kv line at Sainikpuri (AE)	-
3		Narapally	AP Meat	11KV	Keesara	19.55	21.05	01.10		Pin Insulator failed at Powder Company T/F at Ganesh Nagar	-
1	HYD N	Clock Tower	Railway Reservation	NT	V	17.20	18.35	01.15	EL,OL-R&Bph	No Visible Fault (due to rain)	-
2		Film Nagar	Ramanaidu Studio	NT	X	17.20	18.30	01.10	EL	No Visible Fault (due to rain)	-
3		Road No.12	C.R.P.F	NT	X	17.00	18.25	01.25	EL,OL-Bph	Tree branches on lines at Meenakshi Towers	-
4		Bhudevi Nagar	Ramraj Nagar	NT	VI	17.45	19.15	01.30	EL	No Visible Fault (due to rain)	-
5		Macha Bollarum	Reddy Enclave	NT	C-VI	17.30	20.11	02.41	EL	-----	90% feeder Charged OK
6		Marredpally	Ramser Café	NT	C-VI	18.05	20.40	02.35	EL	Brass Patti cut at Ramser Café	-
7		Bansilalpet	Naganna Kunta	NT	V	17.30	18.35	01.05	EL	No Visible Fault (due to rain)	-
8		Bansilalpet	Naganna Kunta	NT	V	18.40	21.40	03.00	EL	Tree Branches fallen on lines at Bondal Gadda	-
9		Bowenpally	Jaya Nagar	NT	VI	16.55	19.10	02.15	EL,OL-R&Bph	Disc Insulator flash over at Andhra Bank	-
10		Bowenpally	Kalinga Enclave	NT	VI	19.55	21.30	01.35	EL	Jumper cut at 2nd line AB Switch	-
11		R.P.Nilayam	Vaishnavi Matha	NT	C-VI	18.02	21.17	03.15	EL	Tree branches fallen on lines at Batiya Bekary	-
12		Hakimpet	Allen by Lines	NT	C-VI	19.35	21.10	01.35	EL	No Visible Fault (due to rain)	-
13		Gymkhana	Tadbun Temple	NT	C-VI	20.22	23.15	02.53	EL	Tree branches fallen on lines	-
14		E.S.I	I.A.S Quarters	NT	IV	20.10	21.48	01.38	A/R Opened	Tree branches fallen on lines at Sridhar Apts	-
15		Marredpally	Ravi Colony	NT	C-VI	19.25	20.50	01.25	EL,OL	No Visible Fault (due to rain)	-
16		I.D.P.L	V.E	NT	VI	21.15	22.40	01.25	EL,OL-Bph	Tree branches fallen on lines at T.C.Bala Nagar	-
17		Seethaphal Mandi	Srinivasa Nagar Colony	NT	V	17.22	20.30	03.08	A/R Opened	No Visible Fault (due to rain)	-
18		Lodha	Hanuman Temple	NT	IV	22.01	23.08	01.07	OL	CT,PT fault at Toyoto Show Room	-
19		Bansilalpet	C.C.Nagar	NT	V	20.13	22.40	02.27	All Indication	Tree branches fallen on lines at C.C.Ngr	-
20		Marredpally	Railway Colony	NT	C-VI	22.40	23.50	01.10	EL,OL	2No DTR'S Kept off at Ganesh Nagar	-
21		K.I.M.S	Bharani Complex	NT	V	17.19	21.59	04.40	EL	Tree branches fallen on lines at Complex	-
22		Bansilalpet	Nagannakunta	NT	V	17.30	18.35	01.05	EL	No Visible Fault (due to rain)	-
23		K.I.M.S	Krishna Nagar	NT	V	18.55	23.08	04.13	EL,OL-Rph	Tree branches fallen on lines	-
24		Nehru Nagar	Rezimental Bazar	NT	V	19.13	22.36	03.23	EL,OL	Pin Insulator flash over at Krishna Apts	-
25		Prashanth Nagar	Sony Complex	NT	VI	17.45	19.15	01.30	EL	No Visible Fault (due to rain)	-
26		Gunrock	M.D.F	NT	VI	23.55	02.25	02.30	All Indication	Tree branches fallen on lines at Prem Sagar Apts	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD S	Womens College	Quthbiguda	ST	IX	17.13	18.58	01.45	EL,OL	No Visible Fault (due to rain)	-
2		Teegalakunta	Shankar Nagar	ST	VIII	17.40	19.06	01.26	OL-Rph	Tree branches on lines at Shankar Nagar	-
3		Salarjung	Abid Ali Eye Hospital	ST	VIII	19.10	21.50	02.40	EL,OL	AB Switch sparking at Hospital	-
4		Santosh Nagar	Chandra Huts	ST	VIII	17.00	18.10	01.10	EL	No Visible Fault (due to rain)	-
5		Teegalaguda	Sri Nagar Colony	ST	VIII	17.41	19.06	01.25	EL	Tree branches fallen on lines at Sri Nagar Colony	-
1	HYD C	Golconda	Darga Cable	CEN	VII	10.55	13.05	02.10	EL,OL-Rph	Cable End failed at Endla Basti & Breaker problem at SS	-
2		S.D Hospital	Crescent Hospital	CEN	VII	17.06	18.20	01.14	OL	Tree branches on lines at Reliance Trend	-
3		Jawahar Nagar	Balaji Indiraprashta	CEN	I	17.10	18.25	01.15	EL	No Visible Fault (due to rain)	-
4		Jawahar Nagar	Post Office	CEN	I	17.10	18.15	01.05	EL,OL-Rph	No Visible Fault (due to rain)	-
5		Indira Park	Talla Basti	CEN	I	17.55	19.00	01.05	EL,OL-Rph	No Visible Fault (due to rain)	-
6		Indira Park	Ambedkar Nagar	CEN	I	17.20	19.00	01.40	EL,OL-Bph	No Visible Fault (due to rain)	-
7		Industrial Area	Barkathpura	CEN	II	17.05	18.25	01.20	EL	No Visible Fault (due to rain)	-
8		Industrial Area	RTC X Road	CEN	II	17.05	18.20	01.15	EL,OL	No Visible Fault (due to rain)	-
9		Public Garden	L.B Stadium	CEN	I	17.22	18.50	01.28	EL,OL-Yph	Tree branches on lines at L.B Stadium	-
10		Nizam College	Rosary Convent	CEN	I	17.19	19.35	02.16	EL	No Visible Fault (due to rain)	-
11		Jawahar Nagar	Ashok Nagar	CEN	I	17.15	18.45	01.30	OL-Rph	No Visible Fault (due to rain)	-
12		Jawahar Nagar	Jawahar Nagar	CEN	I	17.10	18.40	01.30	EL	No Visible Fault (due to rain)	-
13		Amberpet	6no Road	CEN	II	17.15	18.43	01.28	EL	Tree branches on lines at Tulasi Nagar	-
14		S.D Hospital	Ahmed Nagar OH	CEN	VII	17.08	19.06	01.58	EL	Tree branches on lines at Miletown Apartment	-
15		S.D Hospital	Police Mess	CEN	VII	17.09	19.50	02.41	EL	Tree branches on lines at Agra Functional Hall	-
16		A.C Gaurds	Shanthi Nagar	CEN	VII	17.05	19.55	02.50	EL	RMU fault at Shanthi Nagar Park	-
17		A.C Gaurds	N.M.D.C	CEN	VII	18.10	19.45	01.35	OL-Rph	No Visible Fault (due to rain)	-
18		Narayanguda	City Central Library	CEN	I	17.05	18.55	01.50	EL,OL	No Visible Fault (due to rain)	-
19		Narayanguda	Narayanguda	CEN	II	17.05	19.05	02.00	EL,OL	No Visible Fault (due to rain)	-
20		Lumbini Park	Avanthi Nagar	CEN	I	17.10	19.08	01.58	All Indication	Tree branches on lines at Street No.3, Himayath Nagar	-
21		Lumbini Park	A.P Tourisim	CEN	I	17.10	19.06	01.56	EL	Tree branches on lines at Himayath Nagar	-
22		Industrial Area	Vidya Nagar	CEN	II	17.12	19.05	01.53	EL,OL	Tree branches on lines at Vidya Nagar	-
23		Industrial Area	Shankarmutt	CEN	II	17.13	18.25	01.12	EL	No Visible Fault (due to rain)	-
24		Fever Hospital	Barkathpura B.D	CEN	II	17.05	18.30	01.25	EL	No Visible Fault (due to rain)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
25	HYD C	Fever Hospital	C.C.Sharoor Hospital	CEN	II	17.07	19.40	02.33	All Indication	No Visible Fault (due to rain)	-
26		Fever Hospital	Sriram Nagar	CEN	II	17.10	18.35	01.25	EL	No Visible Fault (due to rain)	-
27		Bathakamma Kunta	Shivam	CEN	II	17.18	18.25	01.07	OL-Bph	Tree branches on lines at Shivam Temple	-
28		Nampally	Amba Hospital	CEN	VII	17.04	19.34	02.30	EL	Tree branches on lines at Daulash Functional Hall	-
29		Nampally	FAPCCI	CEN	VII	17.14	18.54	01.40	OL	Tree branches on lines at FAPCCI Building	-
30		Fever Hospital	Fever Hospital	CEN	II	19.10	21.30	02.20	EL	Tree Branches fallen on lines	-
31		Indira Park	Talla Basti	CEN	I	19.45	20.55	01.10	EL	No Visible Fault (due to rain)	-
32		Narayanguda	City Central Library	CEN	I	19.55	22.15	02.20	EL	No Visible Fault (due to rain)	-
33		Jawahar Nagar	Ashok Nagar	CEN	I	20.45	22.25	01.40	EL	Tree branches fallen on lines	-
34		Lakeview	Kapadia Lane	CEN	I	18.45	20.30	01.45	EL	RMU Fault	Arranged B/F on 11KV Dilkusha fdr
35		Zamistanpur	Shastryapuram	CEN	II	17.15	20.57	03.42	EL	No Visible Fault (due to rain)	-
36		Chilalguda	Parsi Gutta	CEN	II	21.12	22.35	01.23	OL-Yph	Tree branches fallen on lines at Srinivasa Timbers	-
37		ITI Mallepally	Afzal Sagar	CEN	VII	21.33	23.36	02.03	EL,OL	No Visible Fault (due to rain)	Arranged B/F on 11KV Nampally Hopsital fdr
38		Vittalwadi	Gandhi Kuteer	CEN	II	17.15	19.05	01.50	EL,OL-Rph	Tree branches fallen on lines at N.Guda P.S	-
39		Vittalwadi	YMCA	CEN	II	17.05	21.06	04.01	EL,OL-Bph	Tree branches fallen on lines at Venkateswara Temple	-
40		Vittalwadi	Kamineni Hospital	CEN	I	17.10	21.15	04.05	EL,OL-Rph	Tree branches fallen on lines at Boggula Kunta	-
41		Vittalwadi	APCO	CEN	II	17.18	21.20	04.02	EL,OL-Bph	Tree branches fallen on lines at N.Guda W.W	-
42		Lumbini Park	A.I.R	CEN	I	17.07	18.11	01.04	EL	No Visible Fault (due to rain)	-
43		Nizam College	Brand Factory	CEN	I	17.17	23.45	06.28	EL	No Visible Fault (due to rain)	-
44		Chilalguda	Bholakpur	CEN	I	17.35	00.30	06.55	EL	Conductor snapped at Tele.Exchange	-
45		Lumbini Park	Loka Yuktha	CEN	I	18.08	21.30	03.22	OL-R&Bph	Tree branches fallen on lines	-
46		Indira Park	Domalguda	CEN	I	17.15	23.30	06.15	EL,OL-Bph	Tree branches fallen on lines	-
47		Indira Park	Himayath Nagar	CEN	I	17.25	21.20	03.55	EL,OL-Rph	Tree branches fallen on lines at RTO Office	-
48		Erra Manjil	Red Rose	CEN	I	17.17	18.55	01.38	EL,OL	Tree branches fallen on lines	-
49	Jawahar Nagar	Anjaiah Bhavan	CEN	I	23.00	01.25	02.25	All Indication	No Visible Fault (due to rain)	-	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
50	HYD C	Narayanguda	Preventive Medcine	CEN	II	17.25	23.20	05.55	EL	Tree branches fallen on lines	-
51		Narayanguda	Chikkadpally	CEN	II	17.05	21.30	04.25	EL	Lines Twisted near SS	-
52		Industrial Area	D.D.H	CEN	II	17.10	22.30	05.20	EL	Tree branches fallen on lines at Vidya Nagar	-
53		Industrial Area	Azamabad IE	CEN	II	17.15	23.10	05.55	EL	No Visible Fault (due to rain)	-
54		Industrial Area	Azamabad Key SS	CEN	II	17.16	00.42	07.26	EL	Cable fault	-
55		Fever Hospital	Fever Hospital	CEN	II	19.10	21.30	02.20	EL,OL	Tree branches fallen on lines at Anjaiah Quarters	-
56		Zamistanpur	Shastry Nagar	CEN	II	17.15	20.57	03.42	EL,OL	No Visible Fault (due to rain)	-
57		Asif Nagar	Hakimpet	CEN	VII	17.14	19.03	01.49	EL,OL	Tree branches fallen on lines at Alasath Colony	-
58		A.S.R.Raju Nagar	Sai Garden	CEN	VII	18.03	21.57	03.54	EL	Disc Insulator flash over at Sai Garden	-
59		A.C Gaurds	Nilofur	CEN	VII	17.15	21.15	04.00	EL	Disc Insulator flash over at Yousufin	-
60		Vittalwadi	ICICI Bank	CEN	I	17.34	01.58	08.24	EL	Big Tree fallen on lines at ICICI Bank	-
61		Lumbini Park	T.T.D	CEN	I	17.13	04.25	11.12	All Indication	RMU fault at Bus Stop	-
62		Hussain Sagar	Gunfoundry	CEN	I	18.30	02.50	08.20	EL,OL-B0ph	No Visible Fault (due to rain)	-
63		Indira Park	Vivek Nagar	CEN	I	19.30	04.00	08.30	EL,OL-Rph	Cable Fault	-
64		Hyderguda	King Koti	CEN	I	15.15	21.05	05.50	EL,OL-Rph	No Visible Fault (due to rain)	-
65		Nizam College	Babukhan Chambers	CEN	I	23.20	01.55	02.35	EL,OL	No Visible Fault (due to rain)	-
66		Vittalwadi	APCO	CEN	II	23.35	03.11	03.36	EL,OL-Bph	Tree branches fallen on lines at Canara Bank	-