

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		8		8		8			
7	RR(E)	168	403		5		5		5			
8	Hyd	194	1044	1	32	1	32	1	32			
	Total	606	3055	1	45	1	45	1	45	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	5	3	5	3	5	3			
2	NLG	144	988		13		13		13			
3	MDK	107	933	2		2		2				
4	SDPT			2	14	2	14	2	14			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	9	30	9	30	9	30	0	0	
	Grand Total	1082	6468	10	75	10	75	10	75	0	0	

TSSPDCL - LMRC / Corporate office

Date: 28.06.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Mogalmadka	33KV	Mahabubnagar	23.15 27.06.20	01.35	02.20	E/L	Post of insulator Directed		No
2		Chinnamaroor	Weepangandla	33KV	Wanaparthi	02.50	05.45	02.55	E/L	Insulator failed at line		No
3		Gadwal	Oil Seed	33KV	Gadwal	12.10	16.45	04.35		LV's Pull Out		Alternate Supply Arranged to 33KV Kodandapur SS at 16:45Hrs
4		Makthal	Kirshna	33KV	Narayanapet	3:05	9:30	6:25	E/L	Insulator replaced near tangedi SS		No
5		Marikal	Koilkonda Water Grid	33KV	Narayanapet	00.00	05.05	05.05	O/L	Dut to Rain Alternate supply arranged from 33KV Parpally		Alternate supply arranged from 33KV Parpally at 5:05Hrs
1	MDK	Narayankhed	Kalher	33KV	Jogipet	14:21	15:20	0:59		Jumper cut	Kalher	No
2		Narayankhed	wasar	33KV	Jogipet	02.15	06.25	04.10		Coductor snapped	wasar	No
1	SDPT	Siddipet	Ponnala	33KV	Siddipet	0:00	8:30	8:30		Insulator failed	Ponnala	No
2		Gajwel	Pragnapur	33KV	Gajwel	15.45	19.15	04.30		Insulator failed	Pragnapur	No
1	HYD N	Jubilee Hills	Road No.12	33KV	Kalyan Ngr	05.40	05.50	00.10	EL,OL	Momentary tripped	Road No.12	Loads transferred onto 132KV J'Hills SS via 33KV Asif Nagar-2 fdr

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1		Pomal	Pomal	11KV	Jadcherla	23.30	07.30	08.00		11KV Phase to phase near Pomal (V)	No
2	MBNR	Midjil	Veljal	11KV	Jadcherla	21.45	06.30	08.45		11KV Insulator failure near Venco Company Side	No
3		Midjil	Munnanoor	11KV	Jadcherla	10.20	11.45	01.25		11KV Disc failure near Vaadyala (V)	No
1		Turkapally	Turkapally	11KV	Nalgonda	11.30	12.37	1.37		Jumper cut	No
2		Turkapally	Hvirajapuram	11KV	Nalgonda	11.15	12.05	01.50	E/L	Insulator failed	No
3		Phanigiri	Malipuram	11KV	Suryaset	06.00	09.45	03.45	E/L	Insulator flashover	No
4		Bollepally	Jampally	11KV	Bhongir	04.00	07.30	03.30	E/L	11 kv Disc failed	No
5		Peddathanda	Pallephad	11KV	Bhongir	06.00	10.00	04.00	E/L	11kv Insulator Failed	No
6		Rajapet	Renikunta Agl	11KV	Bhongir	04.00	09.25	05.25	E/L	11kv Insulator Failed	No
7	NLG	Ishkilla	Kakkireni	11KV	Choutuppal	01.00	07.30	06.30	E/L	11 kv line snapped	No
8		Choutuppal	Jublakpally	11KV	Choutuppal	00.30	09.05	08.35	E/L	11kv Insulator Failed	No
9		Malkapur	Malkapur Agl	11KV	Choutuppal	03.00	08.10	05.10	E/L	11 kv Line snapped	No
10		Panhangli	Panhangli Agl	11KV	Choutuppal	04.00	08.48	04.48	E/L	53kva DTR Failed	No
11		Jai Kesaram	Jai Kesaram Indl	11KV	Choutuppal	15.30	17.15	01.45	E/L	11kv Disc Failed	No
12		BP Pally	Sheemanapally	11KV	Choutuppal	06.20	08.45	02.25	E/L	100kva DTR Failed	No
13		Peddaravlapally	Peddaravlapally	11KV	Choutuppal	14.50	18.06	1.16	E/L	SS-1 63kva DTR Failed	No
1		Laxmidivipally	Ibrahimpur	11KV	Siddpet	00.00	13.30	13.30		Heavy gale and wind	No
2		Chandlapur	Gangapur	11KV	Siddpet	00.10	09.26	09.16		insulator failed	No
3		Akberpet	Akberpet	11KV	Siddpet	00.00	06.41	06.41		Heavy gale and wind	No
4		Pragnapur	Gundapally	11KV	Gajwel	11.41	19.25	04.44		3 Phase breakdown	No
5		Pallepahad	Pallepahad	11KV	Gajwel	17.20	18.40	01.20		insulator failed	No
6		Gowaram	Gowaram	11KV	Gajwel	17.00	18.00	01.00		Tree branches fallen on the line	No
7	SDPT	Gowaram	Gowaram Agl	11KV	Gajwel	17.00	18.20	01.20		Tree branches fallen on the line	No
8		Gududupally	Gududupally	11KV	Gajwel	17.42	18.08	0.42		insulator failed	No
9		Duddeda	Industrial	11KV	Gajwel	15.00	18.10	03.10		Tree branches fallen on the line	No
10		Tipparam	Erravally	11KV	Gajwel	00.05	06.00	05.45		3 Phase breakdown	No
11		Tipparam	Muddapur	11KV	Gajwel	17.00	19.40	02.40		11KV Jumper cut	No
12		Pamulaparthi	Eppalagudem	11KV	Gajwel	15.07	16.02	00.55		LT Line jumper cut	No
13		Guruvannapet	Guruvannapet	11KV	Husnabad	00.00	12.05	12.05		Heavy gale and wind	No
14		Ramchandrapur	Varikolu	11KV	Husnabad	0.30	7.00	6.30		Heavy gale and wind	No
1		Jeedimetla-II	Phase-IV	11KV	Jeedimetla	16.35	17.45	1.10		11kv Pin Insulator failure At Bus Depo	No
2		Aleap	Pragathinagar	11KV	Jeedimetla	15.25	16.40	01.15		11kv Line Cut At Loabour Added	No
3		Subhash Nagar	Jeedimetla	11KV	Medchal	00.30	04.20	03.50		Tree fallen on the 11KV Line at Deewan Dhaaba	No
4	RR N	DP Pally-II	INDO Feb	11KV	Jeedimetla	16.20	17.20	01.00		Tree branches fallen on the 11kv Line At Medchal Road	No
5		Aliabad	HBL	11KV	Medchal	00.15	03.20	03.05		11KV Pin Insulator at HBL Company	No
6		Kistapur	Welsot	11KV	Medchal	04.15	06.45	02.30		Tree fallen on the 11KV Line at Ravalkole	No
7		Kandlakoya	Kandlakoya	11KV	Medchal	07.40	09.10	01.30		11KV Cable failed at Mutyalu Eng Company	No
8		GP Pally	Mallareddy	11KV	Medchal	16.45	17.45	1.00		Tree fallen on the 11KV Line at Mallareddy Collage	No
1		Moula-Ali	Mirzalquda	11KV	Sainikpuri	3.00	4.15	1.15		11KV Disc failed Opp SS yard	No
2		Boduppall	Anjaneya Nagar	11KV	Habsiguda	03.45	04.40	00.55		11KV Disc failed at Saddukunta	No
3	RR E	NGRI	HMT Nagar	11KV	Habsiguda	00.58	02.05	01.07		Tree branches fallen on 11KV Line near Mini Castral Apartment	No
4		Nacharam	Chandamama	11KV	Habsiguda	00.33	02.35	02.02		11KV Pole bend at Road No.09 & HT/LT line heavy sparked & 2 Span of line cut at SS Yard outside	No
5		Balaji Nagar	Sai Baba Temple	11KV	Keesara	1.58	2.54	0.56		Tree fallen on 11KV line at Firing Katta	No
1		Tirumalagiri	Chinna Kamela	11KV	C-VI	00.45	02.55	02.10	EL,OL	Tree branches fallen on lines at Kamela	No
2		Lodha	Hanuman Temple	11KV	IV	1.06	2.45	1.39	EL	No Visible Fault (due to Rain)	Arranged B/F on 11KV I.E fdr
3		Prakash Nagar	Magestic Mansion	11KV	IV	1:10	2:28	1:18	EL	Pin Insulator flash over at Magestic Mansion	No
4		Addagutta	Addagutta	11KV	C-VI	1:15	3:10	1:55	All Indication	Cable fault	Arranged B/F on 11KV Tukaram Gate & 11KV Shanthi Nikethan fdrs
5		New Bowenpally	Raju Colony	11KV	VI	1:20	3:12	1:52	EL,OL	Tree branches fallen on lines at Raju Colony	No
6	HYD N	J.D.P.L	Wonder Plast	11KV	VI	1:40	5:25	3:45	EL,OL-Bph	Disc Insulator flash over at Patney Colony	No
7		J.D.P.L	Tipcon	11KV	VI	1:55	3:25	1:30	EL,OL-Rph	No Visible Fault (due to Rain)	No
8		Road No.13	Star Hospital	11KV	X	1:58	3:10	1:12	EL,OL	Tree branches fallen on lines at Opp: Star Hospital	No
9		Road No.12	Road No.12	11KV	X	4:50	6:08	1:18	All Indication	No Visible Fault (due to Rain)	Arranged B/F on 11KV Sri Ram Nagar fdr
10		Begumpet	Viduyth Tower	11KV	IV	5:40	6:55	1:15	EL,OL-Rph	Disc Insulator flash over at Leela Nagar	No
11		Hakimpet	Bollarum P.S	11KV	C-VI	12:15	14:15	2:00	EL	Disc Insulator flash over at Barla Doddi	No
12		Macha Bollaram	Father Balalaiah Nagar	11KV	C-VI	13:04	14:05	1:01	OL	Faulty DTR at Father Balalaiah Nagar	No
13		Marredpally	Railway Colony	11KV	C-VI	16.30	17.40	01.10	EL	Faulty DTR at T.I.T. Block	No
1	HYD S	Womens College	Quthbiguda	11KV	IX	01.35	03.16	01.41	EL	No Visible Fault (due to Rain)	Arranged B/F on 11KV Tourist Hotel feeder
1		Nampally	Nampally Hospital	11KV	VII	00.04	01.20	01.16	OL	DTR fault at Nampally Hospital	No
2		Indira Park	Gulshan Nagar	11KV	I	00.05	02.05	02.00	EL,OL	HT Jumper cut at Mother Dairy	No
3		Narayanaguda	City Central Library	11KV	I	00.07	01.35	01.28	EL,OL-Yph	Tree branches fallen on lines at Ram Reddy Chicken Center	No
4		Jawahar Nagar	Ashok Nagar	11KV	I	00.10	01.25	01.15	OL-R&Bph	No Visible Fault	No
5		Narayanaguda	Narayanaguda	11KV	II	00.15	01.20	01.05	EL,OL	Tree branches fallen on lines at Kallu Compound	No
6		Narayanaguda	Chikkadapally	11KV	II	00.17	03.43	03.26	AR tripped	No Visible Fault (due to Rain)	Partial fdr charged at 02:15 hrs. Remaining loads added on 11KV Narayanaguda feeder
7		Gudimalkapur	Murad Nagar	11KV	VII	00.28	02.00	01.32	EL,OL	HT Jumper cut at Zebabagh	No
8		Jawahar Nagar	J.N Home	11KV	I	00.30	02.05	01.35	All Indication	No Visible Fault	No
9	HYD C	Bathkammakunta	Ahobilmutt	11KV	II	00.30	03.20	02.50	AR tripped	Pin Insulator flash over at Hotel Management	No
10		Fever Hospital	Fever Hospital	11KV	II	00.30	03.40	03.10	EL	Tree branches fallen on lines at Nala & Insulator flash over at P.F. Office	No
11		Vittalwadi	Taj Mahal	11KV	I	01.00	02.30	01.30	All Indication	Cable End Kit failed	Arranged B/F on 11KV Kamineni Hospital fdr
12		Vittalwadi	Gandhi Kuteer	11KV	II	01.05	02.30	01.25	EL,OL-Bph	Sparking AB Switch at Melkot Park	No
13		Nizam College	Big Bazar	11KV	I	02.05	04.10	02.05	EL,OL	Tree branches fallen on lines at Big Bazar	No
14		Hyderguda	Urdu Hall	11KV	I	02.45	11.16	08.31	EL	Pin Insulator flash over at CDR Hospital	No
15		Industrial Area	D.D.H	11KV	II	04.35	06.45	02.10	EL,OL-R&Bph	HT Jumper cut & Pin Insulator flash over at Vidya Nagar	No
16		S.D Hospital	Police Mess	11KV	VII	05.30	06.46	01.16	EL,OL-R&Bph	HT Jumper cut at Alpha Bakery	No
17		Durga Nagar	Chenna Reddy Nagar	11KV	II	9:48	11:25	1:37	EL,OL-Rph	Twisted HT/LT Lines at C.R Nagar	No
18		Narayanaguda	Preventive Medicine	11KV	II	13.22	14.45	01.23	EL	Disc Insulator flash over at Ambedkar College	No