

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		5		5		5			
	Total	606	3055	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	6	1	6	1	6			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	7	1	7	1	7	0	0	
	Grand Total	1082	6468	1	14	1	14	1	14	0	0	

TSSPDCL - LMRC / Corporate office

Date: 08.03.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Nalgonda	Anneparthi	33KV	Nalgonda	16.35	18.50	02.15	EL	Insulator Failed	Anneparthi	-

TSSPDCL - LMRC / Corporate office

Date: 08.03.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Pamangundla	Pittampally	11KV	Nalgonda	07.00	08.45	01.45	EL	Jumper Cut	-
2		Pulimamidi	Pulimamidi	11KV	Miryalaguda	13.40	16.00	02.20	EL	11Kv Pin Insulator Failed	-
3		Kodur	Kodur	11KV	Suryapet	05.00	07.15	02.15	EL	Jumper cut	-
4		Golankonda	Golankonda	11KV	Bhongiri	06.00	08.45	02.45	OL	11 KV Line Snapped Near Ammanabole Village.	-
5		Pallerla	Siddapuram	11KV	Bhongiri	12.18	14.15	01.57	OL	100 kva DTR Failed at SS-24 Near Siddapuram Village	-
6		Choutuppal	Thangedipally	11KV	Choutuppal	03.05	07.45	04.40	EL	11 kv Disc Failed Near Thangedipally Village	-
1	MDK	Kistareddypet	Kistareddypet	11KV	Patancheru	06.05	07.00	00.55		B/D due to Jumper cut	-
1	RR N	Jeedimetla-II	NRSA	11KV	Jeedimetla	16.35	17.50	01.15		11KV AB cable failure	-
1	RR E	CRPF	Chennapur	11KV	Keesara	22.25	23.40	01.15		11KV Line Cut at Dumping Yard and AB Switch Open at Malkaram	-
1	HYD N	Macha Bollaram	Balaji Rice Mill	11KV	C-VI	15.31	17.35	02.04	EL,OL	Pin Insulator flash over at Balaji Rice Mill	Arranged B/F on 11KV Reddy Enclave fdr
1	HYD S	Kandikal Gate	G.M.Chowni	11KV	III	17.40	21.50	04.10	EL	AB Cable fault at Kishan Hospital (At 18:30Hrs partial fdr charged)	-
2		Kandikal Gate	Kandikal Gate	11KV	III	18.15	20.29	02.14	EL,OL	Cable fault & Lugs burntout at Phool Bagh DTR (At 19:10Hrs Partial fdr charged)	-
3		Kandikal Gate	Rakshapuram	11KV	III	18.15	20.00	01.45	EL,OL	Tree fallen on HT Lines at Baba Dairy Form	-
4		Panjasha	Metherwadi	11KV	III	18.25	19.40	01.15	EL	No Visible Fault (Due to rain)	-