

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	3	1	3	1	3			
7	RR(E)	168	403									
8	Hyd	194	1044		4		4		4			
	Total	606	3055	1	7	1	7	1	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988	1	1	1	1	1	1			
3	MDK	107	933	1		1		1				
4	SDPT				7		7		7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	8	4	8	4	8	0	0	
	Grand Total	1082	6468	5	15	5	15	5	15	0	0	

TSSPDCL - LMRC / Corporate office

Date: 09.03.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Peddanandigama	33KV	Vikarabad	10.10	11.15	01.05	E/L&O/L	Kite Fallen on the Line	Peddanandigama	-
2		Kodangal	Hamsanpally	33KV	Vikarabad	08.20	09.55	01.35	E/L	Due to Rain No Visible Fault	Hamsanpally	-
1	NLG	Mattampally	BNL Thanda	33KV	Huzurnagar	06.25	09.55	03.20		33 KV JUMPER CUT	BNL Thanda	-
1	MDK	Gummadidala	AFA	33KV	Patancheru	10.40	13.05	02.25		B/D due to Conductor snapped	AFA	-
1	RR N	132KV Medchal	33KV Aliabad	33KV	Medchal	23.40	08.20	08.40		No visible Fault	33KV Aliabad	-

TSSPDCL - LMRC / Corporate office

Date: 09.03.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	S.Lingotam	S.Lingotam Agl	11KV	Bhongir	08.10	09.50	01.40	EL	11kv Pole Damedged Lorry Near Supper Gas Company	-
1	SDP	Cherial Town	Cherial-Town	11KV	Husnabad	03.30	06.35	03.05		BD due to Jumper cut	-
2		Akunoor	Aknoor Agl	11KV	Husnabad	07.00	11.10	04.10		BD due to AB Switch failed	-
3		Guruvannapet	Guruvannapet	11KV	Husnabad	05.35	05.45	00.10		BD due to Jumper cut	-
4		Guruvannapet	Posanpally	11KV	Husnabad	00.00	05.45	05.45		BD due to conductor snapped	-
5		Komuravelly	Komuravell 24 Hrs	11KV	Husnabad	07.10	09.10	02.00		BD due to Jumper cut	-
6		Komuravelly	Kistampet	11KV	Husnabad	00.00	12.25	12.25		BD due to conductor snapped	-
7		Rebarthy	Ladnoor	11KV	Husnabad	03.25	09.10	05.45		BD due to conductor snapped	-
1	RR N	Dulapally	Karthika Vanam	11KV	Medchal	02.00	03.22	01.22		11KV Disc Failed at Ganganstan	-
2		Petbasheerabad	St.Anns	11KV	Medchal	00.04	01.17	01.13		11KV Pin Insulator Failed at near by SS(Backfeeding arranged from 11KV Balaji Hospital)	-
3		Aleap	Punchavati	11KV	Jeedimetla	08.05	09.05	01.00	EL/OL	11kv Jumper Cut Touched On Channel At Pt no-1206 pragathinagar	-
1	HYD N	N.I.M.S	Tata Rao	11KV	X	15.48	16.58	01.10	EL,OL	No Visible Fault	Arranged B/F on 11KV E-Seva feeder
2		Gymkhana	Mudfort	11KV	C-VI	17.15	18.25	01.10	EL,OL-R&Yph	Auto Reclosure problem	Arranged B/F on 11KV Tadbun feeder
3		Kandikalgate	Naseeb Nagar	11KV	III	16.02	18.00	01.58	EL,OL	UG Cable fault at Parivahar Township	(At 17:35 hrs 80% feeder charged stood OK)
1	HYD S	Kandikalgate	Naseeb Nagar	11KV	III	16.02	18.00	01.58	EL,OL	UG Cable fault at Parivahar Township	(At 17:35 hrs 80% feeder charged stood OK)