

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		1		1		1			
3	MDK	107	933	2		2		2				
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	3	3	3	3	3	0	0	
	Grand Total	1082	6468	3	6	3	6	3	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 10.03.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthy	Chinnamaroor	33KV	Wanaparthy	22.10	23.15	01.05		LVs Pulled out	Chinnamaroor	At 23:15 hrs. back feeding supply taken from 33KV Peddadagada feeder
1	MDK	Bollaram	Bollaram - II	33KV	Patancheru	8:55	11:05	2:10		Conductor snapped	Bollaram - II	No
2		Gummadidala	GPSS-2	33KV	Patancheru	16.00	18.25	02.25		Jumper cut	GPSS-2	No

TSSPDCL - LMRC / Corporate office

Date: 10.03.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mkundapuram	Kalluru	11KV	Huzurnagar	11:05	12:05	1:00	EL	11KV Line snapped	No
1	SDPT	Gurvannapet	Posanpally	11KV	Husnabad	15:05	16:45	1:40		Tree fallen on the line	No
2		Gouravelly	Gubbadi	11KV	Husnabad	09.50	12.20	02.30		HT/LT	No
1	RR N	Jeedimetla SS III	Black lite hylam	11KV	Jeedimetla	1:48	2:55	1:07		11kv cable endkit failure at Dulapally road	No
2		Kandlakoya	Saigeetha Ashramam	11KV	Medchal	09.45	11.20	01.35		11KV Line cut and replaced at Somani Company	No
1	HYD N	Gunrock	Anjaiah Nagar	11KV	VI	11.35	12.45	01.10	EL	No visible fault	Arranged B/F on 11KV Park View Enclave for