

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	3	1	3	1	3			
3	MDK	107	933									
4	SDPT			7	7	7	7	7	7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	8	10	8	10	8	10	0	0	
	Grand Total	1082	6468	8	14	8	14	8	14	0	0	

TSSPDCL - LMRC / Corporate office

Date: 12.03.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Mattampally	B.N. THANDA	33kv	Huzurnagar	12.10	15.00	02.50		33 KV JUMPER CUT	B.N. THANDA	-
1	SDPT	Habsipur	Ragothampally	33kv	Siddipet	17.00	17.35	00.35		BD (Heavy wind)	Ragothampally	-
2		Gajwel	Gowraram	33kv	Gajwel	15.48	00.00	08.12		BD (Heavy wind)	Gowraram	Idle feeder
3		Gajwel	Mulugu	33kv	Gajwel	15.48	00.00	08.12		BD (Heavy wind)	Mulugu	Alternate supply given at 16.00 hrs
4		Gajwel	Ahmedipur	33kv	Gajwel	16.50	18.30	01.40		BD (Heavy wind)	Ahmedipur	-
5		Gajwel	Pragnapur	33kv	Gajwel	15.47	18.35	02.48		BD (Heavy wind)	Pragnapur	-
6		Doultabad	Doultabad	33kv	Gajwel	19.00	00.00	05.00		BD (Heavy wind)	Doultabad	Alternate supply given at 19.15 hrs
7		Mustyala	Nagpuri	33kv	Husnabad	20.25	21.00	00.35		BD (Heavy wind)	Nagpuri	-

TSSPDCL - LMRC / Corporate office

Date: 12.03.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kethepally	Korlapahad	11kv	Nalgonda	05.00	06.55	01.55	EL	Jumpercut	-
2		Chervupally	Dacharam	11kv	Nalgonda	07.00	08.15	01.15	EL	Insulator failed	-
3		Garidepally	L B Nagar	11kv	Huzurnagar	11.00	12.00	01.00	EL	11 KV LINE TOUCHED AT Cutting Machine	-
1	SDPT	Potharam	Mirzapoor	11kv	Husnabad	05.00	06.30	01.30		Insulator Fail	-
2		Akkannapet	Gollakunta	11kv	Husnabad	11.15	11.46	00.31		Tree cut	-
3		Koheda	Sriramulapally	11kv	Husnabad	08.30	09.00	00.30		Insulator Fail	-
4		Komuravelly	Kadavergu	11kv	Husnabad	08.34	12.35	04.01		Jumper cutting	-
5		Bekkal	Bairanpally	11kv	Husnabad	09.45	10.40	00.55		Insulator Fail	-
6		Rebarthy	Gagillapur Agl	11kv	Husnabad	00.00	10.00	10.00		Tree fallen on line	-
7		Rebarthy	Ladnoor	11kv	Husnabad	17.00	20.00	03.00		Insulator Fail	-
1	RR N	GP Pally	Apparel Park	11kv	Medchal	17.50	18.50	01.00		Tree Fallen on 11KV Line at Icon Infra company	-
1	RR E	Sainikpuri	Ramalayam	11kv	Sainikpuri	14.02	15.30	01.28		Tree fallen and Insulator failed at Defence Colony (AE)	-
2		Sainikpuri	Eshwarpuri	11kv	Sainikpuri	16.06	17.58	01.52		Bus dashed to 11Kv pole 2 poles broken at Eshwarpuri (AE)	-
1	HYD N	Ch' Baradari	Gazi Banda	11kv	Charminar	23.00	00.58	01.58	EL,OL	Cable fault at Gazi Banda (Partial fdr charged at 00:15Hrs)	Arranged B/F on 11KV Satter Bagh feeder