

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------|------------------------------|------|------------------------------------|------|-------------------------|------|-------------------------------------|------|--------------------------------|------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | 1 | | 1 | | 1 | | | |
| 7 | RR(E) | 168 | 403 | | 1 | | 1 | | 1 | | | |
| 8 | Hyd | 194 | 1044 | 1 | 3 | 1 | 3 | 1 | 3 | | | |
| | Total | 606 | 3055 | 1 | 5 | 1 | 5 | 1 | 5 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|-------------|-------------------------------|------|------------------------------------|------|-------------------------|------|-------------------------------------|------|--------------------------------|------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | | | | | | | | | |
| 2 | NLG | 144 | 988 | 1 | 2 | 1 | 2 | 1 | 2 | | | |
| 3 | MDK | 107 | 933 | 1 | 2 | 1 | 2 | 1 | 2 | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 2 | 4 | 2 | 4 | 2 | 4 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 3 | 9 | 3 | 9 | 3 | 9 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 13.03.2020

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|-----------------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--------------------------------------|-----------------------|--|
| 1 | NLG | Haliya | Rajavaram | 33kv | Miryalaguda | 14.00 | 14.55 | 00.55 | EL | Jumper Cut at Near Rajavaram Village | Rajavaram | - |
| 1 | MDK | Kandi | HFC-I | 33kv | Sangareddy | 12.00 | 15.30 | 03.30 | | B/D due to Conductor snapped | HFC-I | - |
| 1 | HYD C | 132KV Asif Nagar - Shaikpet | Golconda (PTR-3 & 4) | 33kv | Mehdipatnam | 11.20 | 11.22 | 00.02 | EL,OL-Rph | Cable damaged by G.H.M.C Wing | Golconda (PTR-3 & 4) | Loads transferred onto 132KV J' Hills SS via 33KV Golconda fdr |

TSSPDCL - LMRC / Corporate office

Date: 13.03.2020

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---|
| 1 | NLG | Janpahad | Janpahad | 11kv | Huzurnagar | 14.30 | 15.35 | 01.05 | EL | Due to 11KV Jumper Cutted | - |
| 2 | | B.B.Nagar | Raghavapuram | 11kv | Bhongiri | 10.00 | 15.45 | 05.45 | EL | B.B.Nagar SS Inside 11KV Disc Failed | - |
| 1 | MDK | Bollaram-II | Rupa | 11kv | Sangareddy | 18.30 | 19.10 | 00.40 | | B/D due to Conductor snapped | - |
| 2 | | Inole | Pedda Kanjarla | 11kv | Sangareddy | 10.25 | 12.35 | 02.10 | | B/D due to Jumper cut | - |
| 1 | RR N | Subhash Nagar | Padma Nagar | 11kv | Medchal | 06.35 | 07.30 | 00.55 | EL | Line patrolling but No Fault | - |
| 1 | RR E | Kushaiguda | Kamala Nagar | 11kv | Habsiguda | 18.50 | 19.50 | 01.00 | | 11Kv line cut at Vamshi Tower Mahesh Nagar (LM Srinivas) | - |
| 1 | HYD S | Panjasha | Gulzar House | 11kv | III | 02.00 | 03.05 | 01.05 | EL | Cable fault at Mittika Share | ----- |
| 2 | | E.N.T | Rang Mahal | 11kv | IX | 15.14 | 16.40 | 01.26 | EL,OL-Rph | Fault loads of 11KV C.B.I feeder | ----- |
| 3 | Hyd C | Nampally | Red Hills | 11kv | VII | 11.15 | 12.55 | 01.40 | A/R Opened | No Visible Fault | Auto Recloser opened & closed at Nisha Hospital |