

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044	1	1	1	1	1	1			
	Total	606	3055	1	3	1	3	1	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		5		5		5			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	5	0	5	0	5	0	0	
	Grand Total	1082	6468	1	8	1	8	1	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.03.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	HYD N	132KV Erragadda	LV Prasad Marg (Idle)	33KV	Kalyan Ngr	14.58	17.00	02.02	OL-R,Y&Bph	Bph female Contact damaged at 132KV Erragadda SS	LV Prasad Marg (Idle)	-

TSSPDCL - LMRC / Corporate office

Date: 15.03.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Koduru	Koduru	11KV	Suryapet	12.15	13.40	01.25	EL	Jumper cut	-
2		Nadigudem	Nadigudem Agl	11KV	Huzurnagar	02.00	05.00	03.00	EL	Due to 11kv line snapped	-
3		Gaddipally	Ponugodu	11KV	Huzurnagar	13.54	15.30	01.36	EL	Due to 11kv Jumper cutted	-
4		Arlagaddagudem	N.R.Gudem	11KV	Nalgonda	06.10	09.10	03.00	EL	11KV jumper cut	-
5		Arjalabavi	Arjalabavi AGL	11KV	Nalgonda	05.20	09.00	03.40	EL	11KV jumper cut	-
1	RR N	GP Pally	Apparel Park	11KV	Medchal	14.25	15.00	00.35		Tree Branch fallen on the 11KV Line at Pokarna Company	-
1	RR E	Sainikpuri	Eshwaripuri	11KV	Sainikpuri	07.35	10.00	02.25		2 11Kv line cut at OUT Colony (AE/OP)	-
1	HYD C	Hussain Sagar	Gunfoundry	11KV	I	04.05	05.10	01.05	EL	Cable fault at Horticulture DTR	-