

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	3	1	3	1	3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	3	1	3	1	3	0	0	
	Grand Total	1082	6468	1	8	1	8	1	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 16.03.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Suryapet	Yerkaram	33KV	Suryapet	08.00	11.15	03.15	EL	Insulator failed		-

TSSPDCL - LMRC / Corporate office

Date: 16.03.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Pamangundla	Ismailpally	11KV	Nalgonda	08.00	09.45	01.45	EL	Jumpercut	-
2		Kasarabadha	TK Pahad	11KV	Suryapet	06.30	08.30	02.00	EL	Jumper cut	-
3		Maryala	Chowderpally	11KV	Bhongir	04.30	08.40	04.10	EL	11kv lline Snpped near KK Thanda	-
1	RR N	Jeedimetla SS I	Sudharshan durgs	11KV	Jeedimetla	10.30	12.00	01.30	BD	11kv AB Cable kit failure at KLG Plastic company	-
1	RR E	Vajpayee Nagar	Kakatiya Nagar	11KV	Sainikpuri	07.47	08.17	00.30		11KV Jumper cut	-
2		CRPF	Chennapur	11KV	Keesara	12.15	14.05	01.50		11KV Pin Insulator failed	-
1	HYD N	R.P.Nilayam	Venkatapuram	11KV	C-VI	13.05	14.20	01.15	EL,OL-Yph	Cable fault at SS Bill Counter backside	Arranged B/F on 11KV Adarsh Nagar & 11KV Vaishnavi Matha feeders
1	HYD C	Amberpet	Golnaka	11KV	II	09.55	11.05	01.10	EL,OL-Bph	Tree branches fallen on lines at Tirumala Nagar	-