

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT			1		1		1				
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	1	2	1	2	1	0	0	
	Grand Total	1082	6468	2	3	2	3	2	3	0	0	

TSSPDCL - LMRC / Corporate office

Date: 18.03.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Alampur	Undavelly	33KV	Gadwal	18.12	18.42	00.30	EL&OL	33KV CT Blost	Undavelly	Alternate supply arraged from 33KV Alampur town feeder
1	SDPT	Doultabad	Doultabad	33KV	Gajwel	17:15	18:20	1:05		Insulator failed	Doultabad	No

TSSPDCL - LMRC / Corporate office

Date: 18.03.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Nadigudem	Krishnanagar	11KV	Huzurnagar	4:30	7:00	2:30	E/L	11KV Jumper cut	No
1	RR S	SEZ	Siddique Nagar	11KV	Kondapur	0:40	1:45	1:05		11kv Line AB switch jumper cut near Siddique nagar, Community hall (11KV Pole dashed by lorry)	No
1	RR E	CRPF	Chennapur	11KV	Keesara	14:40	15:50	1:10		Line patrolling but no visible fault & AB Switch opened at Mallaiah Gutta	No