

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550	1	20	1	20	1	20			
7	RR(E)	168	403		15		15		15			
8	Hyd	194	1044	1	58	1	58	1	58			
	Total	606	3055	2	95	2	95	2	95	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988	2	4	2	4	2	4			
3	MDK	107	933		6		6		6			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	10	4	10	4	10	0	0	
	Grand Total	1082	6468	6	105	6	105	6	105	0	0	

TSSPDCL - LMRC / Corporate office

Date: 19.03.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Machanpally	33kv	Mahabubnagar	18.30	23.40	05.10	E/L	Disc Flash Over & Conductor Snapped Near JPNCE College Dharmapur	Machanpally	-
2		Wanaparthy	Buddaram	33kv	Wanaparthy	10.15	13.07	02.52	E/L	Jumper Cut at 33KV SS Gopalpet	Buddaram	-
1	NLG	Kanagal	Thurkapally	33kv	Nalgonda	15.45	17.15	01.30	E/L,O/L	Moment fault due to rain	Thurkapally	-
2		Kanagal	Yadavelly	33kv	Nalgonda	15.50	18.00	02.10	E/L,O/L	Moment fault due to rain	Yadavelly	-
1	RR N	132KV Medchal	33KV Bandamadaram	33kv	Medchal	17.57	19.53	01.56	BD	Tripped on EL Indication (Due to rain) (No Fault)	33KV Bandamadaram	-
1	HYD S	220KV Osm. University	Lalaguda	33KV	Asmangadh	18.10	18.25	00.15	EL	33KV Jumper cut at St. Ann's School, Lalaguda & 33KV Pin Insulator flash over	Lalaguda	Loads transferred onto 220KV Osm. University SS via 33KV SCR fdr

TSSPDCL - LMRC / Corporate office

Date: 19.03.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Palakaveedu	Palakeedu	11KV	Huzurnagar	16.20	17.20	01.00	EL	Due to 11Kv Jumper Cutted	-
2		Palleria	Kurella	11KV	Bhongir	16.35	18.50	01.15	EL/OL	Due to 11Kv Jumper Cutted	-
3		S.Lingotam	S.Lingotam	11KV	Choutuppal	14.35	17.30	02.35	EL/OL	11kv Insulator Failed near Tallasinagarm near	-
4		MT.Pally	Moglipaka	11KV	Choutuppal	16.20	17.30	01.10	EL/OL	11KV Insulator failure	-
1	MDK	EPIP-I	Chitrakoot	11KV	Sangareddy	17.45	19.00	01.15		BD Due to Conductor Snapped	-
2		EPIP-I	Chitrakoot	11KV	Sangareddy	19.20	20.25	01.05		BD Due to disk fail	-
3		EPIP-I	Chaitanya	11KV	Sangareddy	17.45	19.00	01.15		BD due to insulator failure	-
4		Pati	Shalimar	11KV	Patancheru	18.30	19.30	01.00		BD Due to Tree Fallan on line	-
5		Patancheru Town	High power	11KV	Patancheru	17.55	19.10	01.15		BD due Jumpercut	-
6		Bollaram - I	Town -I	11KV	Patancheru	18.04	22.50	04.46		BD Due to Conductor Snapped	-
1	RR S	Chanda Nagar	Tara Nagar	11KV	Gachibowli	10.35	11.45	01.10	BD	11kv Line snapped at Telephone Colony	-
2		Manikonda	Lalamma Garden	11KV	Ibrabimbagh	17.56	19.35	01.39	BD	11KV endkit failed at Lalamma garden	-
1	RR N	Prashanthi Hills	Srinivasa Colony	11KV	Kukatpally	17.40	18.40	01.00	BD	A bird fallen the 11kv PinInsulator at Sai Nivas apt	-
2		Nizampet	Bandari-lay-out	11KV	Kukatpally	17.32	18.45	01.13	BD	Due to Havy Rain ,(line Petroling No Visble falt)	
3		Jeedimetla-II	Apuroopa Colony	11KV	Jeedimetla	18.25	21.35	03.10	BD	Due to Havy Rain ,(11kv PinInsulater failure at Apuroopa Colony }	
4		Jeedimetla-II	UtthamBiscuty	11KV	Jeedimetla	18.25	20.10	01.45	BD	Due to Havy Rain ,(line Petroling No Visble falt)	
5		Jeedimetla-II	NRSA	11KV	Jeedimetla	18.25	21.10	01.45	BD	Due to Havy Rain ,(line Petroling No Visble falt)	
6		Jeedimetla-III	Back lighty Hylam	11KV	Jeedimetla	19.35	22.50	03.15	BD	Due to Havy Rain ,(line Petroling No Visble falt)	
7		Jeedimetla-IV	Tagoure	11KV	Jeedimetla	17.45	19.29	01.44	BD	Due to Havy Rain ,(line Petroling No Visble falt)	
8		Jeedimetla-IV	Vasudha	11KV	Jeedimetla	17.48	19.45	01.57	BD	Due to Havy Rain ,(line Petroling No Visble falt)	
9		Jeedimetla-IV	Auto stand	11KV	Jeedimetla	17.48	20.05	02.17	BD	Due to Havy Rain ,(line Petroling No Visble falt)	
10		Jeedimetla-I	JETL	11KV	Jeedimetla	20.20	21.50	01.30	BD	11kv AB Cable Failure at SS out side	
11		Jagathgirigutta	IDA	11KV	Medchal	18.15	20.10	01.55	BD	11KV Cable endkit failed at Hari Showroom	
12		HMT	Quthbullapur	11KV	Medchal	18.25	19.00	00.35	BD	Tree fallen on the 11KV Line at Vimanapuri Colony	
13		HMT	Manikya Nagar	11KV	Medchal	18.35	19.20	00.45	BD	Kite removed on the 11KV Line at Indra Singh Nagar	
14		Dulapally	KK Society	11KV	Medchal	17.52	20.35	02.43	BD	No Fault	
15		Dulapally	Karthika Vanam	11KV	Medchal	17.49	19.50	02.01	BD	No Fault	
16		Dppally-II	Tech Mahendra	11KV	Jeedimetla	17.45	19.15	01.30	BD	Tree branchesh fallen the 11kv line at Tech Mahendra Road	
17	Dppally	Bowrampet	11KV	Jeedimetla	21.40	22.42	01.02	BD	Flex Fallen the 11kv line at Rangreddy bai T/F , Bowrampet		
18	Kandlakoya	KV Reddy Nagar	11KV	Medchal	18.05	19.05	01.00	BD	CTPT failed at Guruvotham Company		
19	Kandlakoya	Godrej IDA	11KV	Medchal	18.05	19.10	01.05	BD	Tree fallen on the 11KV Line at Raju Seeds Company		
20	GP Pally	GP Pally	11KV	Medchal	18.10	19.10	01.00	BD	Tree fallen on the 11KV Line at Venkateshwara Pipes Company		

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR E	NGRI	HMT Nagar	11KV	Habsiguda	03.00	04.50	01.50		11KV Line snapped at High Court Colony	-
2		Uppal	Bank Colony	11KV	Habsiguda	13.45	15.00	01.15		11KV Pin Insulator failed at Kalyanipuri Main Road due to rain	-
3		IICT	Snehapuri	11KV	Habsiguda	18.00	20.20	02.20		11KV pole bend & touched to 11KV line at St Paul Degree & PG College	
4		Kushaiguda	Kapral	11KV	Sainikpuri	15.25	16.15	00.50		11Kv line Twisting at Bavani Nagar due to Haevy Sound (AE/OP)	
5		Kushaiguda	Neredmet	11KV	Sainikpuri	19.35	20.35	01.00		Bird fall on 11Kv line at HMTV (LM Srinivas)	
6		Vayupuri	Vayupuri	11KV	Sainikpuri	18.03	20.33	02.30		11Kv Pin Insuletor fail at Vayupuri Plot No 29 (LM Chandu)	
7		Vinayak Nagar	RK Nagar	11KV	Sainikpuri	18.00	18.45	00.45		Tree fallen on 11Kv line at RK Nagar Street No 2 (L Insp Venu Gopal)	
8		Ananadbagh	NMDC	11KV	Sainikpuri	17.59	19.15	01.16		11Kv Pin Insuletor fail at Mani Kanta Apt East Anadbagh (L Insp Ramulu)	
9		Ananadbagh	BS Nagar	11KV	Sainikpuri	18.01	19.33	01.32		Tree fallen on 11Kv line at Vishnupuri Colony (L Insp Ramulu)	
10		Ananadbagh	Krupanand	11KV	Sainikpuri	18.02	19.53	01.51		Coconut Tree fallen on 11Kv line at Chalapathi Residency (L Insp Ramulu)	
11		CRPF	Chennapur	11KV	Keesara	12.25	13.00	00.35		Line patrolling but no visible fault	
12		P&T Colony	Chengicherla	11KV	Keesara	14.40	15.25	00.45		11KV Insulator failed at Sage International School	
13		P&T Colony	Canara Nagar	11KV	Keesara	18.00	19.10	01.10		Lizard fallen on 11kv line at P&T Colony Community Hall	-
14		P&T Colony	Chengicherla	11KV	Keesara	18.00	19.15	01.15		11KV Brass patti cut & 11KV Disc failed at Kamala Nagar	-
15		Narapally	Narapally	11KV	Keesara	18.40	19.50	01.10		11KV Disc failed at Delhi Public School	-
1	HYD N	Seethaphal Mandi	Srinivasa Nagar Colony	11KV	V	15.30	16.45	01.15	EL,OL-Rph	Jumper Cut at Masjid	-----
2		Nehru Nagar	Rezimental Bazar	11KV	V	18.03	21.20	03.17	EL,OL-Yph	No Visible Fault (Due to Rain)	-----
3		Lalaguda	St.Anns	11KV	V	18.05	19.30	01.25	EL,OL-Bph	Jumper Cut at Sagar Apts	-----
4		New Bowenpally	Reliance Villa	11KV	VI	14.01	16.40	02.39	EL	Pin Insulator flash over at VBR Garden	-----
5		Bowenpally	Plassy Line	11KV	VI	14.50	16.10	01.20	EL	No Visible Fault (Due to Rain)	-----
6		Chinna Thokatta	Mahathma Nagar	11KV	VI	14.50	16.14	01.24	EL	Tree Branches fallen on lines	-----
7		Bowenpally	Pension Line	11KV	VI	14.50	16.32	01.42	EL	No Visible Fault (Due to Rain)	Arranged B/F on 11KV Seetharam puram fdr
8		Chinna Thokatta	Park View Enclave	11KV	VI	14.50	17.10	02.20	EL	No Visible Fault (Due to Rain)	-----
9		Gunrock	Anjaiah Nagar	11KV	VI	14.53	17.50	02.57	EL,OL-Rph	No Visible Fault (Due to Rain)	-----
10		Bowenpally	Kalinga Enclave	11KV	VI	14.55	16.15	01.20	EL	No Visible Fault (Due to Rain)	-----
11		Bowenpally	Akshaya Enclave	11KV	VI	17.45	20.35	02.50	EL	No Visible Fault (Due to Rain)	-----
12		Bowenpally	Jaya Nagar	11KV	VI	17.50	19.50	02.00	EL	No Visible Fault (Due to Rain)	-----
13		Bowenpally	Ferozguda	11KV	VI	17.50	19.15	01.25	EL	No Visible Fault (Due to Rain)	-----
14		Bowenpally	Pipe Line	11KV	VI	17.50	19.15	01.25	EL	No Visible Fault (Due to Rain)	-----
15		Bowenpally	I.A.F.	11KV	VI	17.55	19.50	01.55	EL	No Visible Fault (Due to Rain)	-----
16		Tirumalagiri	Khanajiguda	11KV	VI	18.00	20.45	02.45	EL,OL-Y&Bph	No Visible Fault (Due to Rain)	-----
17		Bowenpally	Kalinga Enclave	11KV	VI	18.25	20.35	02.10	EL	No Visible Fault (Due to Rain)	-----
18		Bowenpally	Akshaya Enclave	11KV	VI	21.10	23.40	02.30	EL	Cable fault at Old Airport	-----
19		Thirumalagiri	Sri Nagar Colony	11KV	C-VI	15.00	16.20	01.20	EL,OL-Rph	Tree Branches & Flexi fallen on lines at Military Area	-----
20		R.P.Nilayam	Naga Devatha	11KV	C-VI	17.59	19.11	01.12	EL	No Visible Fault (Due to Rain)	-----
21		Tirumalagiri	Chinna Kamela	11KV	C-VI	18.00	19.20	01.20	EL,OL-Rph	No Visible Fault (Due to Rain)	-----
22		Gymkhana	Tadbun Temple	11KV	C-VI	18.05	19.29	01.24	EL,OL-Bph	Tree branches fallen on lines at Tadbun	-----
23		Gymkhana	Rani Bagh	11KV	C-VI	18.06	20.05	01.59	EL,OL-R&Bph	Tree branches fallen on lines at Rani Bagh	-----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
24	HYD N	Nehru Nagar	LIC Colony	11KV	C-VI	18.07	20.03	01.56	EL,OL-Yph	No Visible Fault (Due to Rain)	-----
25		Gunrock	Tirumalagiri	11KV	C-VI	18.30	21.20	02.50	OL-R&Bph	No Visible Fault (Due to Rain)	-----
26		Gunrock	Medchal	11KV	C-VI	18.35	19.45	01.10	EL,OL	No Visible Fault (Due to Rain)	-----
27		Tirumalagiri	Officers Colony	11KV	C-VI	18.36	19.50	01.14	EL,OL-Rph	No Visible Fault (Due to Rain)	-----
28		Road No.22	UCO Bank	11KV	X	17.50	21.08	03.18	EL,OL-Rph	Tree branches fallen on lines at UCO Bank	-----
29		Road No.22	Road No.22	11KV	X	17.52	21.58	04.06	EL,OL-Bph	No Visible Fault (Due to Rain)	-----
30		Film Nagar	Apollo	11KV	X	17.54	19.40	01.46	EL	Partial fdr charged	Remaing loads added on 11KV fdr
31		Jubilee Hills	B.S.N.L.	11KV	X	17.55	20.30	02.35	EL,OL-R&Bph	No Visible Fault (Due to Rain)	-----
32		Jubilee Hills	A.O.U.	11KV	X	17.55	20.25	02.30	EL,OL-R&Bph	Tree branches fallen on lines at Road No.72	-----
33		Kalyan Nagar	Krishna Nagar	11KV	X	17.57	19.29	01.32	EL	No Visible Fault (Due to Rain)	-----
34		Kalyan Nagar	Rahamath Nagar	11KV	X	17.57	19.55	01.58	EL	No Visible Fault (Due to Rain)	-----
35		Kalyan Nagar	Jawahar Nagar	11KV	X	17.57	20.16	02.19	EL	No Visible Fault (Due to Rain)	-----
36		Tolichowki	Hanuman Temple	11KV	X	17.59	22.50	04.51	EL	Pin Insulator flash over at Vijaya Shanthi's House	-----
37		Prashasan Nagar	Arogya Sree	11KV	X	18.00	19.20	01.20	EL,OL	No Visible Fault (Due to Rain)	-----
38		Prashasan Nagar	B.N.R.Hills	11KV	X	18.00	20.04	02.04	EL,OL	No Visible Fault (Due to Rain)	-----
39		MLA Colony	K.B.R.Park	11KV	X	18.05	19.20	01.15	EL,OL-R&Yph	Cloth fallen on lines at Apollo Hospital	-----
40		Kalyan Nagar	Vengalrao Nagar	11KV	X	18.07	19.34	01.27	EL	No Visible Fault (Due to Rain)	Arranged B/F on 11KV A.G.Colony fdr
41		Road No.22	Jubilee Hills PS	11KV	X	18.14	19.48	01.34	EL,OL-Rph	No Visible Fault (Due to Rain)	-----
42		Yousufguda	Celebration	11KV	X	18.20	19.55	01.35	EL	Cable Burnt out at Plt.No.91	-----
43		Prashasan Nagar	Siri Culture	11KV	X	18.28	20.56	02.28	EL,OL	Tree branches fallen on lines at Siri Culture	-----
44	Film Nagar	Ambedkar Nagar	11KV	X	19.50	21.46	01.56	EL,OL-Rph	End Kit failed at Govt. School, Vinayak Nagar	-----	
1	HYD S	Santosh Nagar	Bhavani Nagar	11kv	VIII	18.28	20.05	01.37	EL	Cable fault at Jaffar Gally	-----
2		Santosh Nagar	Jahangir Nagar	11kv	VIII	19.38	20.40	01.02	EL	Kite sticks on lines at Jahangir Nagar	-----
3		Yakuthpura	Somnath Temple	11kv	VIII	21.50	23.18	01.28	EL,OL-R&Bph	Faulty DTR at Bhavani Nagar PS	-----
1	HYD C	Jawahar Nagar	Post Office	11kv	I	18.00	19.35	01.35	EL,OL-Rph	Tree branches fallen on lines at Post Office	-----
2		Lakeview	NKMS Hotel	11kv	I	18.06	19.45	01.39	EL	Insulator flash over at Benz Show Room	-----
3		Narayanguda	Chikkadpally	11kv	II	13.40	15.10	01.30	All Indication	Tree Branches fallen on lines at Metro Station	-----
4		Nampally	FAPCCI	11kv	VII	13.30	15.03	01.33	A/R Opened	No Visible Fault (Due to Rain)	Arranged B/F on 11KV Red Hills & Pearls Regency fdrs
5		Golconda	Darga Cable	11kv	VII	17.50	19.10	01.20	EL	No Visible Fault (Due to Rain)	-----
6		A.C.Guards	Shanthi Nagar	11kv	VII	17.52	19.02	01.10	EL	Jumper cut at JIMS centre	-----
7		Tolichowki	Kala Banglaw	11kv	VII	18.00	19.24	01.24	EL	Insulator flash over at Nala	-----
8		A.C.Guards	Nilofer	11kv	VII	18.02	19.22	01.20	EL	Tree Branches fallen on lines at Opp.SS	-----
9		ITI Mallepally	Anjuman	11kv	VII	18.04	19.50	01.46	EL,OL	No Visible Fault (Due to Rain)	Arranged B/F on 11KV Sri Ram Nagar fdr
10		A.C.Guards	N.M.D.C	11kv	VII	18.37	19.55	01.18	EL	Jumper cut Hockey Ground	-----
11		ITI Mallepally	Afzal Sagar	11kv	VII	19.25	20.57	01.32	EL,OL	No Visible Fault (Due to Rain)	Arranged B/F on 11KV Nampally Hospital fdr