

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		5		5		5			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	7	1	7	1	7	0	0	
	Grand Total	1082	6468	1	12	1	12	1	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.03.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Sadasivpet	Koheer	33KV	Sangareddy	09.45	10.30	00.45		BD Due to Tree branches falen on line	Koheer	-

TSSPDCL - LMRC / Corporate office

Date: 23.03.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marrikal	Malkapur	11KV	Jadcherla	11.50	13.20	01.30		Tree Fallen on line near Agraharam(v)	-
1	NLG	Nuthankal	Yedavelly	11KV	Suryapet	13.55	15.20	01.25	EL	Jumper cut	-
2		Dirsincherla	Somaram	11KV	Huzurnagar	06.30	09.30	03.00	EL	Due to Bird fall on 11Kv line	-
3		Mattampally	Allipuram	11KV	Huzurnagar	11.47	14.32	02.45	EL	Due to 11Kv jumper cutted	-
4		Bhongir(R)	Bollepally	11KV	Bhongir	04.30	07.55	03.25	EL	11 KV Insulator failed at Rice mill near Nagireddypally	-
5		Bondugula	Bondugula AGL	11KV	Bhongir	13.40	14.15	00.35	EL/OL	100KVA DTR Failed near Bondugula Village	-
1	MDK	Patancheru Town	MIA-II	11KV	Patancheru	14.45	16.10	01.25		BD due to Jumper cut	-
1	RR S	Chanda Nagar	Market	11KV	Kukatpally	05.20	06.50	01.30	BD	11kv Pole Damaged at Taranagar Market (Car dashed to 11kv Pole)	-
1	RR N	Jeedimetla-II	Apuroopa Colony	11KV	Jeedimetla	02.05	03.35	01.30	EL	11kv AB Cable Failure At Phase-III	-
2		Bahadurapally	I D A Bhadurapally	11KV	Jeedimetla	13.30	15.30	02.00	EL/OL	11kv Pole damaged by DCM At Old Age Home	-
3		Kolthur	Anatharam	11KV	Medchal	13.25	14.45	01.20	EL	11KV Line AB Switch Opened at Bondalagadda, Anantharam (HT/LT Line Melted)	-
1	HYD N	Gunrock	Lal Bazar	11KV	C-VI	17.46	18.52	01.06	EL	LT Line snapped at D.A.D.Quarters	-