

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	5	1	5	1	5	0	0	
	Grand Total	1082	6468	1	10	1	10	1	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 27.03.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Midjil	Vemula	33kv	Jadcherla	21.32	23.10	01.38	OL	Tree branch follen on the line and removed	Vemula	-

TSSPDCL - LMRC / Corporate office

Date: 27.03.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Peddarevelly	Macharam	11kv	Jadcherla	12.40	15.20	02.40		11KV Phase To Phase Near Suraram Vagu Side	-
1	NLG	Nagaram	Machireddypally	11kv	Suryapet	14.45	16.10	01.25	E/L	Conductor Snapped	-
2		Timmareddy gudem	Timmareddy gudem	11kv	Huzurnagar	04.24	06.35	02.11	EL	Due to 11kv jumper cutted	-
3		Sharajipet	Kollur	11kv	Bhongir	08.30	09.00	00.30	EL/OL	11kv Line Snapped near Kollur Village	-
4		Raghunathpur	Challur Agl	11kv	Bhongir	06.30	09.00	02.30	EL/OL	11 kv Pin Insulator failed Near Saduvelly village	-
1	RR N	Jagathgiringutta	Maqdoom Nagar	11kv	Medchal	09.40	11.10	01.30		11KV AB Cable Failed at Polala Basthi	-
2		Kompally	Kompally	11kv	Medchal	14.20	15.11	00.51		AB Cable Problem at Kompally Gramapanchayiti	-
1	HYD S	E.N.T	Jambagh	11kv	IX	00.48	02.10	01.22	EL,OL	Suspected Cable fault	Arranged B/F on 11KV M.J Market feeder
2		Gosha Mahal	M.J Market	11kv	IX	15.30	18.15	02.45	EL	Star Cable fallen on lines at Malakunta	Partial feeder charged & Remaining fdr arranged B/F on 11KV Osmangunj fdr
3		E.N.T	Troop Bazar	11kv	IX	18.05	19.50	01.45	EL	Cable End Kit fault at Rama Krishna Theater & Faulty loads of 11KV Jambagh fdr	-----