

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	3	0	3	0	3	0	0	
	Grand Total	1082	6468	0	5	0	5	0	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 30.03.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Jammigadda	Durajpally	11KV	Suryapet	11.20	13.30	02.10	E/L	11Kv Insulator failed	-
2		Mukundapuram	Kalluru	11KV	Huzurnagar	09.00	10.45	01.45	E/L	11kv Line sanpped	-
3		Malkapur	Thoshiniwal Indl	11KV	Choutuppal	06.15	16.00	09.45	EL/OL	11kv Line sanpped near Malkapuram Cherru	-
1	HYD N	Chilkaiguda	Pragatools	11KV	V	13.55	16.25	02.30	EL	AB Cable fault at Musheerabad X Road	14:10Hrs Arranged partial loads B/F on 11KV Rajya Laxmi feeder
1	HYD C	Indira Park	Goshala	11KV	I	19.40	21.05	01.25	EL	Sparkings on HT Cable near Goshala	-