

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550	3	12	3	12	3	12			
7	RR(E)	168	403		5		5		5			
8	Hyd	194	1044	2	23	2	23	2	23			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>5</b>	<b>41</b>	<b>5</b>	<b>41</b>	<b>5</b>	<b>41</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	5	6	5	6	5	6			
2	NLG	144	988		2		2		2			
3	MDK	107	933	4	4	4	4	4	4			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>9</b>	<b>12</b>	<b>9</b>	<b>12</b>	<b>9</b>	<b>12</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>14</b>	<b>53</b>	<b>14</b>	<b>53</b>	<b>14</b>	<b>53</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

Date: 01.05.2020

## Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Polepally	Jadcherla	33kv	Jadcherla	13.34	16.55	03.21		Tree fallen on the line	Jadcherla	-
2		Maddur	Kankurthy	33kv	Narayanpet	18.25	19.15	00.50		Due to rain	Kankurthy	-
3		Alampur	Shanthinagar - I	33kv	Gadwal	18.10	03.30.00 (02.05.2020)	09.20		Due to insulators fail	Shanthinagar - I	Loads trasferred onto Shantinagar - II fdr
4		Alampur	Shanthinagar - II	33kv	Gadwal	21.40	22.16	00.36		Tree fallen on the line	Shanthinagar - II	-
5		Kothur	Sangem	33kv	Shadnagar	15.50	19.55	04.05		R-phase clamp redhot occurred	Sangem	-
1	MDK	Kandi	ACE Tyres	33kv	Sangareddy	14.20	16.30	02.10		BD due to Tree branches fallen on line	ACE Tyres	-
2		Narayankhed	Narayankhed T	33kv	Jogipet	14.50	18.14	03.24		BD due to Tree fallen on line & Conductor snapped	Narayankhed T	-
3		Narayankhed	Sirgapur	33kv	Jogipet	14.50	18.14	03.24		BD due to Tree fallen on line & Conductor snapped	Sirgapur	-
4		Borapatla	Covalent	33kv	Jogipet	13.27	18.09	04.42		BD due to Insulator failed	Covalent	-
1	RR N	132KV Medchal	33KV Medchal-I	33kv	Medchal	13.30	15.10	01.40	BD	33KV Jumper cut and replaced at Medchal SS	33KV Medchal-I	-
2		132KV DP Pally	33KV Gowdavelly	33kv	Medchal	16.30	18.06	01.36	BD	33KV Lighting arrester Failed at Mega Engineering(Line Isolator Opened)	33KV Gowdavelly	-
3		132KV Medchal	33KV Medchal-II	33kv	Medchal	16.28	17.35	01.07	BD	33KV Pin Insulator failed at Sarvotham Company	33KV Medchal-II	-
1	HYD N	132KV J' Hills - Road No.13A	Road No.12	33KV	Jubilee Hills	14.09	14.14	00.05	EL,OL-R&Yph	Cable damaged at Police Command Control New SS	Road No.12	Loads transferred onto 132KV J' Hills SS
2	HYD C	132KV Asif Nagar	Mothi Mahal	33KV	Mehdipatnam	11.15	11.22	00.07	EL	Cable Joint failed at M.D Lines	Mothi Mahal	Loads transferred onto 132KV J' Hills SS

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 01.05.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Rajapur	Chennavelly	11kv	Jadcherla	16.15	18.30	02.15		Tree fallen on the line	-
2		Kuchoor	Ippatoor	11kv	Jadcherla	16.40	18.40	02.00		Phase to phase problem	-
3		Nawabpet	Kondapur	11kv	Jadcherla	16.15	19.50	03.35		Jumper cut	-
4		Bhootpur	Amisthapur agl	11kv	Jadcherla	17.30	19.00	01.30		Jumper cut	-
5		Donur	Singamdoddy	11kv	Jadcherla	15.24	17.25	02.01		Insulator failed	-
6		Kaverampet	Townfeeder	11kv	Jadcherla	16.47	17.32	00.45		Tree fallen on the line	-
1	NLG	Balemla	Gandhi Nagar	11kv	Suryapet	04.00	07.50	03.50	E/L	11Kv Insulator failed	-
2		Chamapur	Chandepally	11kv	Bhongir	04.10	12.20	07.10	EL/OL	11kv Insulator Failed near Chandepally (V)	-
1	MDK	SOL	IDA-II	11kv	Patancheru	15.35	16.45	01.10		BD due to Tree fallen on line	-
2		Pati	My Home	11kv	Patancheru	15.35	17.20	01.45		BD due to Tree fallen on line	-
3		Patancheru Town	Shanthinagar	11kv	Patancheru	17.50	18.50	01.00		BD due to Conductor snapped	-
4		Hathnoora	Town Ind	11kv	Jogipet	15.30	16.30	01.00		BD due to Jumper cut	-
1	RR S	ESCI	Nanakramguda	11kv	Gachibowli	14.00	15.20	01.20		11kv Cable jumpe cut and fallen on LT line at White house ,Timber lake colony	-
1	RR N	Jeedimetla SS II	Uthambiscuite	11kv	Jeedimetla	13.40	14.50	01.10	BD	Due to rain, AB Cable failue at Phase III	-
2		HMT	Ganesh nagar	11kv	Medchal	13.45	15.15	01.30	BD	Iran rod fallen on the 11KV Line at delkush nagar	-
3		Dp Pally SS II	Indo fab	11kv	Jeedimetla	13.42	15.25	01.43	BD	Tree fall on the 11kv line at Medchal road	
4		Shameerpet	Devarayamjal	11kv	Medchal	09.15	11.50	02.35	BD	11KV Line cut and replaced at Hanuman Temple	
5		Keshavaram	Keshavaram	11kv	Medchal	14.15	15.40	01.25	BD	11KV PinInsulator failed at Nagishetypally Village	
6		Shameerpet	Anthaipally	11kv	Medchal	14.55	16.20	01.25	BD	11KV Jumper opened at Upparapally Village(Tree Branches removed at Upparapally)	
7		Uddamarry	Snehafarm	11kv	Medchal	14.00	18.00	04.00	BD	11KV Pin Insulator Failed at Adraspally Poultry farm	
8		Bommarajpet	Karkamma	11kv	Medchal	13.30	19.00	05.30	BD	Tree fallen on the 11KV Line at Gopalarao thota	
9		Bommarajpet	Ponnal	11kv	Medchal	13.30	17.00	03.30	BD	11KV Pin Insulator failed at Ponnal Village & 11KV Line cut at Pochamma Temple	-
10		Bandamadaram	Railapur	11kv	Medchal	14.27	17.30	03.03	BD	Tree fallen on the 11KV Line at Girimapur Village	-
11		GP Pally	GP Pally	11kv	Medchal	13.35	14.55	01.20	BD	Tree fallen on 11KV Line at Sunitha House,GP Pally	-
12		Medicity	Pudur	11kv	Medchal	16.50	17.50	01.00	BD	LT Line touched to 11KV Line at Ganpur Thanda	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR E	Moula-Ali	Venkateshwar Nagar	11kv	Habsiguda	13.53	14.50	00.57		Coconut Tree branches fall on 11Kv line Laxmi Nagar on Ganesh Nandini School (Artisan/Kristofar)	-
2		Nagaram	S N Colony	11kv	Habsiguda	13.23	15.13	01.50		100KVA T/F HG Fuse insulator failed at Survi Babaiah Garden	-
3		Aushapur	Aushapur	11kv	Habsiguda	14.50	15.40	00.50		Flexi fallen on 11kv line at Aushapur-Warangal Highway	-
4		Aushapur	Sandupatlaguda	11kv	Habsiguda	14.15	16.10	01.55		11KV Disc failed at Kothagudem	-
5		Singapur	Singapur-2	11kv	Habsiguda	14.30	15.50	01.20		Tree fallen on 11kv line near Singapur Township	-
1	HYD N	I.D.P.L	SIFCO	11kv	VI	13.45	15.45	02.00	EL,OL	Tree branches fallen on lines at Hyd. Chemicals Galli	
2		I.D.P.L	Samatha Nagar	11kv	VI	13.45	15.50	02.05	EL,OL	Tree branches fallen on lines at Samatha Nagar	
3		New Bowenpally	Police Quarters	11kv	VI	13.50	15.30	01.40	EL,OL	No Visible Fault	
4		H.A.L	Samrat	11kv	VI	13.55	15.20	01.25	EL,OL	HT Jumper cut at Bala Nagar	
5		Marredpally	Lalitha Nagar	11kv	C-VI	14.00	15.35	01.35	EL	HT Jumper cut at Rainbow Hospital	
6		Zamistanpur	S.P College	11kv	V	14.08	15.21	01.13	EL	Tree branches fallen on lines at Royal Estate Apts	
1	HYD S	Osm. Hospital	Puranapool OH	11kv	IX	03.20	04.39	01.19	OL-Rph	Nuetral line touching to HT lines at Nagarkhana	
2		Kulsumpura	Ambedkar Nagar	11kv	IX	14.14	15.46	01.32	EL	Kite Sticks fallen on lines at Auto PT	
3		Kulsumpura	Jali Hanuman	11kv	IX	14.15	16.40	02.25	EL,OL	Disc Insulator flash ove at Jali Hanuman	
4		Malakpet	M.M.H	11kv	VIII	14.18	16.00	01.42	EL	HT Jumper cut at M.M.H	
5		Salarjung	Q.Q Stadium	11kv	III	14.20	15.55	01.35	EL,OL	Big Tree fallen on lines at City College	
6		Kanchanbagh	Kanchanbagh	11kv	VIII	14.22	15.35	01.13	EL	No Visible Fault	
7		Gunj	Gunj	11kv	VIII	14.26	16.24	01.58	All Indication	Tree fallen on lines at Gunj	Arranged B/F on 11KV Super Bazar feeder
8		Devibagh	Siddiq Gulshan	11kv	III	14.38	15.50	01.12	EL,OL-Rph	Tree branches fallen on lines at Indian Oil Petrol Bunk	
1	HYD C	Bathkammakunta	Shivam	11kv	II	13.58	15.10	01.12	EL,OL-Rph	DTR fault at Reliance Digitals	
2		Bathkammakunta	Bathkammakunta	11kv	II	13.58	15.17	01.19	EL,OL-Rph	Tree branches fallen on lines at Venkata Narayana House	
3		Bathkammakunta	Ahobilmutt	11kv	II	14.03	15.35	01.32	EL	Tree branches fallen on lines at Taruni Super Market	
4		Bathkammakunta	Saibaba Temple	11kv	II	14.12	15.16	01.04	EL	Tree branches fallen on lines at Library	
5		Durga Nagar	Bapu Nagar	11kv	II	14.13	15.20	01.07	EL,OL-Rph	No Visible Fault	
6		Industrial Area	Vidya Nagar	11kv	II	14.15	15.20	01.05	EL	No Visible Fault	
7		Fever Hospital	Tourist Hotel	11kv	II	14.26	15.35	01.09	EL,OL	DTR fault at Bhumanna Residence	
8		Golnaka	Moulana Azad Nagar	11kv	II	14.38	16.18	01.40	EL,OL	Burntout LT Lugs at Nala DTR	
9		Amberpet	Patel Nagar	11kv	II	15.07	16.20	01.13	EL,OL	HT Jumper cut at Ali Café	