

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	4		4		4				
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	4	4	4	4	4	0	0	
	Grand Total	1082	6468	4	7	4	7	4	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 02.05.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Machanpally	33KV	Mahabubnagar	12.15	14.20	02.05		Pin binding replaced	Machanpally	-
2		Maddur	Vepur	33KV	Mahabubnagar	16.35	17.35	01.00		Insulator damaged	Vepur	-
3		Kodangal	Ansanpally	33KV	Vikarabad	14.45	17.10	02.25		Pin binding replaced	Ansanpally	-
4		Srirangapur	Mogiligidda	33KV	Rajendranagar	15.36	19.15	03.39		Conductor snapped	Mogiligidda	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 02.05.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Balemla	Gandhi Nagar	11KV	Suryapeta	04.00	07.50	03.50	EL	Insulator failed	-
2		Tripuraram	Bejjikal	11KV	Miryalaguda	06.00	09.30	03.30	EL	Jumper cut	-
3		PD Pally	Gajalapuram	11KV	Miryalaguda	08.40	11.05	02.25	EL	Tree fall	-
4		Kamareddygudem	Brundavanpuram	11KV	Miryalaguda	05.30	09.30	04.00	EL	Disk fail,	-
1	RR S	Gachibowli	Gopanpally	11KV	Gachibowli	15.25	16.40	01.15		11kv Out going jumper cut at SS	-
2		KPHB	JNTU	11KV	Kondapur	14.44	16.05	01.21		3no's Birds fallen on line at HIG-220, HG fuse and Brass patti cut at Saiplaza and Sprial fallen on DTR at HIG-188	-
1	HYD C	Fever Hospital	Tourist Hotel	11KV	II	16.18	17.40	01.22	All Indication	No Visible Fault	-