

**Status Report on Breakdowns (Urban / Rural)****Urban**

| S.No | Circle       | No.of Feeders Existing Urban |             | Breakdowns occurred during the day |           | Attended during the day |           | Time taken for restoring the supply |           |                                |          | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
|      |              | 33KV                         | 11KV        | 33KV                               | 11KV      | 33KV                    | 11KV      | Rectified (Within 24 Hours)         |           | Not Rectified (Above 24 Hours) |          |                   |
|      |              |                              |             |                                    |           |                         |           | 33KV                                | 11KV      | 33KV                           | 11KV     |                   |
| 1    | MBN          | 18                           | 107         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 2    | NLG          | 22                           | 358         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 3    | MDK          | 97                           | 359         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 4    | SDPT         |                              |             |                                    |           |                         |           |                                     |           |                                |          |                   |
| 5    | RR(S)        | 53                           | 234         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 6    | RR(N)        | 54                           | 550         | 1                                  | 9         | 1                       | 9         | 1                                   | 9         |                                |          |                   |
| 7    | RR(E)        | 168                          | 403         |                                    | 2         |                         | 2         |                                     | 2         |                                |          |                   |
| 8    | Hyd          | 194                          | 1044        |                                    | 1         |                         | 1         |                                     | 1         |                                |          |                   |
|      | <b>Total</b> | <b>606</b>                   | <b>3055</b> | <b>1</b>                           | <b>12</b> | <b>1</b>                | <b>12</b> | <b>1</b>                            | <b>12</b> | <b>0</b>                       | <b>0</b> |                   |

**Rural**

| S.No | Circle             | No.of Feeders Existing Rurals |             | Breakdowns occurred during the day |           | Attended during the day |           | Time taken for restoring the supply |           |                                |          | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
|      |                    | 33KV                          | 11KV        | 33KV                               | 11KV      | 33KV                    | 11KV      | Rectified (Within 24 Hours)         |           | Not Rectified (Above 24 Hours) |          |                   |
|      |                    |                               |             |                                    |           |                         |           | 33KV                                | 11KV      | 33KV                           | 11KV     |                   |
| 1    | MBN                | 107                           | 849         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 2    | NLG                | 144                           | 988         | 1                                  | 4         | 1                       | 4         | 1                                   | 4         |                                |          |                   |
| 3    | MDK                | 107                           | 933         |                                    | 3         |                         | 3         |                                     | 3         |                                |          |                   |
| 4    | SDPT               |                               |             |                                    |           |                         |           |                                     |           |                                |          |                   |
| 5    | RR(S)              | 58                            | 396         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 6    | RR(N)              | 38                            | 114         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 7    | RR(E)              | 22                            | 133         |                                    |           |                         |           |                                     |           |                                |          |                   |
|      | <b>Total</b>       | <b>476</b>                    | <b>3413</b> | <b>1</b>                           | <b>7</b>  | <b>1</b>                | <b>7</b>  | <b>1</b>                            | <b>7</b>  | <b>0</b>                       | <b>0</b> |                   |
|      | <b>Grand Total</b> | <b>1082</b>                   | <b>6468</b> | <b>2</b>                           | <b>19</b> | <b>2</b>                | <b>19</b> | <b>2</b>                            | <b>19</b> | <b>0</b>                       | <b>0</b> |                   |

## TSSPDCL - LMRC / Corporate office

## Circle-wise 33KV Breakdowns

Date: 08.05.2020

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown   | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|-----------------------|---------------------------|
| 1    | NLG    | Miryalaguda         | Tripuraram           | 33KV | Miryalaguda          | 16.20 | 20.05 | 03.45    | EL               | Disc Failed  | Tripuraram            | -                         |
| 1    | RR N   | 132KV Medchal       | 33KV Nuthankal       | 33KV | Medchal              | 07.45 | 11.40 | 03.55    |                  | 33KV Pin Insulator failed and replaced at ORR(Backfeeding arranged from 33KV Athiwelly Feeder) | 33KV Nuthankal        | -                         |

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 08.05.2020

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown   | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1    | NLG    | Pottichelma        | Nellikal             | 11kv | Miryalaguda          | 02.25 | 06.10 | 03.45    | EL               | Tree Branches fallen the Line                              | -                         |
| 2    |        | Thimmapuram        | Kupaspally           | 11kv | Miryalaguda          | 11.42 | 12.42 | 01.00    | EL               | Conductor Snapped  | -                         |
| 3    |        | G.T.Giri           | Gunjaloor            | 11kv | Suryapet             | 16.20 | 17.30 | 01.10    | EL               | HT/LT Line Melt  | -                         |
| 4    |        | Panhangi           | Panhangi Agl         | 11kv | Choutuppal           | 07.10 | 09.29 | 02.19    | EL               | 100KVA DTR Failed Near Panhangi Village.                   | -                         |
| 1    | MDK    | Gummadidala        | Bell Remedies        | 11kv | Patancheru           | 06.50 | 09.20 | 02.30    |                  | B/D due to Jumper cut                                      | -                         |
| 2    |        | Kistareddypet      | Industrial           | 11kv | Patancheru           | 04.10 | 08.10 | 04.00    |                  | B/D due to Jumper cut                                      | -                         |
| 3    |        | Narayankhed        | Town-I               | 11kv | Jogipet              | 14.02 | 17.37 | 03.35    |                  | B/D due to Jumper cut                                      | -                         |
| 1    | RR N   | Dulapally          | KK Society           | 11kv | Medchal              | 07.20 | 08.24 | 01.04    |                  | 11KV Pin Insulator Failed at Vasantha Tools Opp            | -                         |
| 2    |        | Town Medchal       | Balaji Nagar         | 11kv | Medchal              | 06.53 | 08.30 | 01.37    |                  | Tree Fallen on 11KV Line at KLR Vencher                    | -                         |
| 3    |        | Pudur              | Pudur                | 11kv | Medchal              | 07.30 | 09.00 | 01.30    |                  | 11KV Line AB Switch Opened at DNR School                   | -                         |
| 4    |        | Athiwelly          | Dabeelpur            | 11kv | Medchal              | 09.00 | 13.15 | 04.15    |                  | Stick Fallen on 11KV Line at MAA TV Vencher,Athiwelly      | -                         |
| 5    |        | Athiwelly          | IDA                  | 11kv | Medchal              | 09.00 | 10.40 | 01.40    |                  | 11KV Pin Insulator failed at RK Company                    | -                         |
| 6    |        | Ravalkole          | Cheruvukatta         | 11kv | Medchal              | 08.22 | 10.15 | 01.53    |                  | 2 Nos LT Pole Damaged at Laxmareddy Bavi,Ravalkole         | -                         |
| 7    |        | Thurkapally        | Thurkapally          | 11kv | Medchal              | 09.10 | 11.18 | 02.08    |                  | 11KV Cross arm replaced at Durgamma Temple                 | -                         |
| 8    |        | Shameerpet         | Leo Meridian         | 11kv | Medchal              | 08.00 | 10.40 | 02.40    |                  | 11KV Conductor Snapped and replaced at ORR                 | -                         |
| 9    |        | ICICI              | Bharath Biotech      | 11kv | Medchal              | 16.15 | 17.55 | 01.40    |                  | Lizard Fallen on 11KV Line at Zenotech Company,Thurkapally | -                         |
| 1    | RR E   | Aushapur           | NFC Nagar            | 11kv | Keesara              | 01.05 | 03.00 | 01.55    |                  | 11KV Line cut at Dathathreya Colony                        | -                         |
| 2    |        | CRPF               | CRPF                 | 11kv | Keesara              | 21.45 | 23.25 | 01.40    |                  | Cat falleon on Insulaters in SS Yard                       | -                         |
| 1    | HYD N  | Muffakamza College | I.V.R.C.L            | 11kv | X                    | 07.37 | 08.45 | 01.08    | EL               | Conductor snapped at IVRCL                                 |                           |