

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	2	3	2	3	2			
2	NLG	144	988		3		3		3			
3	MDK	107	933		2		2		2			
4	SDPT			1	10	1	10	1	10			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	17	4	17	4	17	0	0	
	Grand Total	1082	6468	4	18	4	18	4	18	0	0	

TSSPDCL - LMRC / Corporate office

Date: 11.05.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	SLC Mills	33KV	Mahabubnagar	01.55	08.15	06.20	E/L	Insulator Damaged	SLC Mills	Alternate Supply Arranged from Town-III Fedder
2		Shadnagar	Rayalseema	33KV	R.R.South	00.00	09.50	09.50	E/L	Insulator failed at Verlapally Road	Rayalseema	No
3		Wanaparthy	Wanaparthy	33KV	Solipur-2	21.55	00.00	02.05	O/L	33KV Ghanapur AB Switch open at Solipur SS (Solipur SS, Upparipally SS Dark)	Wanaparthy	No
1	SDPT	Habsipur	Raghothampally	33KV	Siddipet	6:05	8:05	2:00		Insulator failed at Boppapur	Raghothampally	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marrikal	Malkapur	11KV	Jadcherla	10.20	11.00	00.40		11KV Wire cut near SS	No
2		Boothpur	Amistapur Agl	11KV	Jadcherla	05.40	06.20	00.40		11KV Jumper cut near Seripally	No
1	NLG	Koduru	Kommala	11KV	Suryapet	13:20	14:35	1:15	E/L	Insulator flashover	No
2		Azeempet	Repaka	11KV	Bhongir	06.20	11.30	05.10	E/L	11kv Line snapped	No
3		Gundala	Gangapur	11KV	Bhongir	07.30	13.00	05.30	E/L	11kv Disc failed	No
1	MDK	Patancheru Town	Shanthinagar	11KV	Patancheru	12:30	13:40	1:10		Insulator failed	No
2		Patancheru Town	Kanjarla	11KV	Patancheru	02.45	06.00	03.15		Jumper cut	No
1	SDPT	Thimmapur	Thimmapur	11KV	Siddipet	13:04	13:59	0:55		Treebranches fallen on the line	No
2		Chittapur	Chittapur	11KV	Siddipet	06.25	09.45	03.20		Treebranches fallen on the line	No
3		Chittapur	Dharmaram	11KV	Siddipet	19.00	23.10	04.10		15 KVA DTR failed	No
4		Peddacheekode	Areppally	11KV	Siddipet	06.10	07.10	01.00		11 KV Line cut	No
5		Peddacheekode	Achumaipally	11KV	Siddipet	09.40	11.15	01.35		Treebranches fallen on the line	No
6		Peddacheekode	Kammarpally	11KV	Siddipet	09.40	11.15	01.35		Treebranches fallen on the line	No
7		Akbarpet	Akbarpet	11KV	Siddipet	06.02	14.10	08.08		11 KV Wire cut	No
8		Vittalapur	Vittalapur	11KV	Siddipet	10.28	10.58	00.30		11 KV Wire cut	No
9		Machapur	Machapur	11KV	Siddipet	08.40	10.41	02.01		Poles Damage	No
10		Gandipally	Gandipally	11KV	Husnabad	4:40	7:30	2:50		Line cut	No
1	HYD N	Marredpally	Ramser Café	11KV	C-VI	07.05	08.15	01.10	EL,OL-Bph	No visible fault	No