

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		2		2		2			
3	MDK	107	933	1		1		1				
4	SDPT			3	4	3	4	3	4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	6	4	6	4	6	0	0	
	Grand Total	1082	6468	4	9	4	9	4	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.05.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Gummadidala	GPSS-II	33KV	Patancheru	14.45	16.55	02.10		B/D due to Conductor snapped	GPSS-II	-
1	SDPT	Gajwel	B V pur	33KV	Gajwel	19.15	19.30	00.15		BD (Insulator failure)	B V pur	-
2		Thukkapur	Mirdoddy	33KV	Gajwel	18.45	19.00	00.15		BD (Line Problem)	Mirdoddy	Alternate Supply Arranged from 132Kv Habsipur - 33KV Khajipur @ 19.00 hrs
3		Mustyala	Cherial	33KV	Husnabad	22.30	23.00	00.30		BD (Heavy wind)	Cherial	Alternate Supply Arranged from 132KV Musstyala - 33KV Dhoolmitta @ 23.00 hrs

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 14.05.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	B.Chandupatla	Pandya thanda	11KV	Suryapet	15.30	17.25	01.55	E/L	Bird fallen on the11Kv line	-
2		Munagala	Nelamarry	11KV	Huzurnagar	14.50	16.15	01.25	E/L	11kv Line snapped	-
1	SDPT	THIGULLA	THIGULLA AGL (LC NO:6795)	11KV	Gajwel	10.02	11.48	01.46		11 KV WIRE CUT	-
2		NACHARAM	MADARAM (LC NO:3492)	11KV	Gajwel	19.05	22.00	02.55		11 KV INSULATOR FAILED	-
3		METTU	GHANPUR (LC NO: 14058)	11KV	Gajwel	18.30	20.00	01.00		AB SWITCH OPEN	-
4		THUKKAPUR	KANGAL (LC NO: 6140)	11KV	Gajwel	19.35	21.50	02.15		3 POLES PIN BINDING CUT	-
1	HYD S	Sulthan Bazar	Sulthan Bazar	11KV	IX	02.10	04.40	02.30	All Indication	No Visible Fault	Arranged B/F on 11KV Esamiya Bazar feeder
2		Malakpet	Prabath	11KV	IX	03.10	04.30	01.20	EL	DTR fault at A.K.P Milk	-----
3		Miralam	Tadbun	11KV	III	03.15	05.02	01.47	EL,OL-Rph	DTR fault at Kabarstan DTR	-----