

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	1	1	1	1	1	0	0	
	Grand Total	1082	6468	1	4	1	4	1	4	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 15.05.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Ghanapur	Lattupally	33kv	Wanaparthi	16.33	17.21	00.48	O/L	Pin Baining replaced near Salkarpet	Lattupally	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 15.05.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mattampally	Town	11kv	Huzurnagar	05.10	07.00	01.50	EL	11 KV LINE SNAPPED	-
1	RR S	Ayyappa Society	Ayyappa Society	11kv	Kondapur	12.00	13.12	01.12		11KV UG Cable failed near YSR Statue (Damaged by Reliance Jio Pole Worker's)	-
1	RR E	CRPF	Chenapur	11kv	Keesara	13.45	14.55	01.10		11KV insulaotr fail at Fara nagar	-
1	HYD N	Gunrock	Gymkhana	11kv	Secunderabad	06.40	07.45	01.05	EL	Bird fault on lines at Surya Nagar	