

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	3	11	3	11	3	11			
3	MDK	107	933	2	2	2	2	2	2			
4	SDPT			1	3	1	3	1	3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	6	16	6	16	6	16	0	0	
	Grand Total	1082	6468	6	22	6	22	6	22	0	0	

## TSSPDCL - LMRC / Corporate office

Date: 17.05.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Gudapoor	Narsingbatla	33KV	Nalgonda	16:30	19:30	3:00	E/L	Due to Heavy Gale and Wind Pole damages	Appijipeta, Narsingbatla, P.D.Pally	Appajipeta-4 19:30 PM Narsingbatla-8 (Alternate from 33 KV Pagidimarri) P.D.Pally (Alternate from 33 KV Gudapoor from 132/33 KV SS Nalgonda)
2		Aitipamula	Aitipamula	33KV	Nalgonda	16.30	19.05	02.35	E/L	Tree Branch fallen on the 33 KV Line	Aitipamula	No
3		Kodad	Indoor	33KV	Huzurnagar	05.00	09.00	04.00	EL/OL	33KV Conductor snapped	Indoor	No
1	MDK	Sadasivpet	Koheer	33KV	Sangareddy	10:25	13:15	2:50		Insulator failed and	Koheer	Alternate suply arranged from 132KV ZHB, 33KVJharasangem feeder
2		Jogipet	Gadipeddapur	33KV	Jogipet	19.00	23.55	04.55		Insulator failed	Gadipeddapur	No
1	SDPT	Gajwel	Jagadevpur	33KV	Gajwel	17:45	19:45	2:00		Insulator failed	Jagadevpur	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Pulimamidi	Marapaka	11KV	Miryalguda	6:10	8:10	2:00	E/L	11KV Insulator failed near (v)	No
2		Seethya Thanda	Seethya Thanda	11KV	Miryalguda	08.05	09.00	00.55	E/L	Tree branches fallen on the line	No
3		Seethya Thanda	Thopucherla-II	11KV	Miryalguda	06.00	11.15	05.15	E/L	11KV conductor snapped at agriculture field	No
4		Agamothkur	Chirumarthy	11KV	Miryalguda	06.30	10.00	03.30	E/L	11KV Insulator failed near (v)	No
5		Penpahad	S.R Palem	11KV	Suryapet	02.30	06.10	03.40	E/L	11KV Insulator flashover	No
6		Adivemla	Kunchamarthy	11KV	Suryapet	06.00	08.00	02.00	E/L	11KV Insulator flashover	No
7		Reddygudem	Kothagudem	11KV	Suryapet	16.40	17.44	01.04	E/L	Tree branch fallen on the 11KV line	No
8		BNL Thanda	Vardhapuram	11KV	Huzurnagar	04.00	07.00	03.00	E/L	11KV Conductor snapped	No
9		Aligapuram	Chennaipalem	11KV	Huzurnagar	06.00	07.30	01.30	E/L	11KV Jumper Cut	No
10		Bondugula	Parupally	11KV	Bhongir	06.00	14.00	08.00	EL/OL	11 kv Insulator failed near Kurraram (v) & 4 Different places Tree branches fallen at line near Parupally (v)	No
11		Gundala	Gangapur	11KV	Bhongir	0:00	6:00	6:00	EL/OL	11KV Insulator failed at SS -6 near Gangapur (v)	No
1	MDK	Sadashivapet	Kambalapally	11KV	Sangareddy	2:40	8:20	5:40		Jumper cut	No
2		Ismailkhanpet	Erdanoor	11KV	Sangareddy	07.55	10.15	02.20		Insulator failed	No
1	SDPT	Husnabad	Husnabad Town-1	11KV	Husnabad	16:20	16:40	0:20		Lines twisted	No
2		Husnabad NEW	Malapally	11KV	Husnabad	07.10	14.10	07.00		11KV Conductor snapped	No
3		Marmamula	Salakpoor	11KV	Husnabad	11.30	06.30	07.00		Tree branch fallen on the 11KV line	No
1	RR N	Kompally	Dholari Dhani	11KV	Medchal	4:15	5:30	1:15		11KV AB Cable failed at Harshita Hospital	No
1	RR E	AS Rao Nagar	AS Rao Nagar	11KV	Sainikpuri	12:07	13:10	1:03		Tree branches fallen on the line	No
1	HYD N	E.S.I.	IAS Quarters	11KV	IV	08.42	10.15	01.33	EL,OL-Rph	Cable fault at IAS Quarters	No
2		E.S.I.	IAS Quarters	11KV	IV	14:52	16:20	1:28	Auto Recloser	AB Cable fault at IAS Quarters	No
1	HYD S	C.R.P.F.	Maisaram	11KV	III	00.05	01.30	01.25	EL,OL-Bph	Multiple UG Cable faults (5Nos DTR's kept off)	No
1	HYD C	Golnaka	Tulasi Nagar	11KV	II	00.03	01.35	01.32	EL,OL	Faulty loads of 11KV Shivalayam feeder	No