

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988	1	6	1	6	1	6			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT			1	14	1	14	1	14			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	22	3	22	3	22	0	0	
	Grand Total	1082	6468	3	24	3	24	3	24	0	0	

TSSPDCL - LMRC / Corporate office

Date: 19.05.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Ramapuram	Mellacheruvu	33KV	Huzurnagar	05.00	10.30	05.30	EL/OL	33 KV JUMPER CUT		-
1	MDK	Jogipet	G.Peddapur	33KV	Jogipet	08.30	10.30	02.00		B/D Due to Insulator Failure		-
1	SDPT	Thukkapur	Mirdoddy	33KV	Gajwel	00.00	08.45	08.45		BD (Conductor falling at Kangal Cheruv)		

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 19.05.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Udithyal	Udithyal	11KV	Jadcherla	10.30	13.00	02.30		Phase to Phase near Udithyal	-
1	NLG	B Chandupatla	Thimmapuram	11KV	Suryapet	15.10	17.00	01.50	EL	Jumper cut	-
2		Nuthankal	Chilpakuntla	11KV	Suryapet	12.00	14.35	02.35	EL	Conductor snapped	-
3		Dirsincherla	Dirsincherla	11KV	Huzurnagar	05.00	07.30	02.30	EL	Pole Damaged	-
4		Garidepally	Ponugodu	11KV	Huzurnagar	03.00	06.45	03.45	EL	11 KV LINE SNAPPED	-
5		Palem	Ogodu	11KV	Nalgonda	14.15	15.20	01.05	EL	Jumper cut	-
6		Ramannapet	Kommaigudem	11KV	Choutupal	05.00	09.40	04.40	EL/OL	11 kv line snapped near Sub station 3 rd pole	-
1	MDK	Fasalwadi	Fasalwadi	11KV	Sangareddy	08.50	12.25	03.35		B/D Due to Insulator Failure	-
1	SDPT	Ponnala	Ponnala Agl	11KV	Siddipet	07.10	09.30	02.20		B/D-Tree bunches fall down, B/D rectified	-
2		Mittapally	Mittapally	11KV	Siddipet	14.15	16.45	02.30		B/D-Tree bunches fall down, B/D rectified	-
3		Akunoor	Rudraipally	11KV	Husnabad	00.00	02.24	02.24		TREE FALLEN	-
4		Akunoor	Dommata	11KV	Husnabad	00.00	00.00	00.00		HT/LT DUE TO TREE BRANCHES SPRING ON 11 KV LINE	-
5		Gurjakunta	Gurjakunta Agl	11KV	Husnabad	08.24	09.24	01.00		III PHASE BREAK DOWN I PHASE RUNNING	-
6		D. R. Pally	Giripally	11KV	Gajwel	17.10	18.30	01.20		Disk Failed	-
7		Thigul SS	Thigul AGL LC:6800	11KV	Gajwel	16.03	17.33	01.30		Disk Failed	-
8		Kodakandla SS	Rayavaram AGL LC: 19754	11KV	Gajwel	15.00	17.00	02.00		11 KV Jumper cut	-
9		Ganeshpally SS	Angadikistapur	11KV	Gajwel	17.20	18.30	01.10		11 KV Jumper cut	-
10		Gowraram SS	Pamulaparthi LC: 40159	11KV	Gajwel	17.15	19.00	01.45		Lighting Arestor Failed	-
11		Thimmareddy Pally	Thimmareddy Pally AGL LC:14370	11KV	Gajwel	06.10	09.00	02.50		Disk Failed	-
12		Marpadaga SS	Nagireddypally AGL LC: 28105	11KV	Gajwel	06.10	10.10	04.00		HT By LT	-
13		Pallepahad SS	Pallepahad Feeder LC: 08212	11KV	Gajwel	06.00	09.00	03.00		11 KV Wire Cut	-
14		Rampur SS	Rampur LC 10129	11KV	Gajwel	09.00	10.50	01.50		Insulator Fail	-
1	RR N	DP Pally-II	Tech-Mahindra	11KV	Jeedimetla	13.43	14.50	01.07	BD	Tree Branches Fallen On The 11kvLine At Tech Mahindra Road	-
1	RR E	IDA Uppal	Ram Reddy Nagar	11KV	Habsiguda	09.20	10.35	01.15		11KV Cable fault near SS Yard Backside & B/F from 11KV Sri Nagar Colony feeder	-