

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044	1	3	1	3	1	3			
	Total	606	3055	1	6	1	6	1	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	3	0	3	0	3	0	0	
	Grand Total	1082	6468	1	9	1	9	1	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 24.05.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	HYD C	132KV Imlibun	Exhibition	33KV	Asif Nagar	14.10	14.19	00.09	OL-Y&Bph	Cable fault	Exhibition	Loads transferred onto 132KV Vittalwadi SS via 33KV Public Garden fdr

TSSPDCL - LMRC / Corporate office

Date: 24.05.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Ravulapally	Kukkadam	11KV	Suryapet	6:30	10:00	3:30	EI	Insulator flashover	No
1	SDPT	Jagadevpur	Jagadevpur Town	11KV	Gajwel	8:25	9:30	1:05		Jumper cut	No
2		Mubaraspur	Mubaraspur	11KV	Gajwel	07.55	10.05	02.10		Disc failed	No
1	RR N	Vijayanagar	Jayanagar	11KV	Kukatpally	13:25	14:35	1:10		AB Cable end kit failed near laxminilyam at Vijayanagar colony	No
1	RR E	IICT	CCMB	11KV	Habsiguda	7:15	8:45	1:30		Tripped on EL & Net cable touched to HG fuse set at Nacharam Main road	No
2		Narapally	Pravathpur	11KV	Keesara	12.02	13.52	01.50		11KV Line snapped at Mahalaxmi nagar	No
1	HYD N	R.P.Nilayam	Vaishnavi Matha Temple	11KV	C-VI	22.38	23.50	01.12	OL-Rph	Faulty 11KV Adarsha Nagar fdr loads	No
1	HYD C	Golconda	Narayanamma College	11KV	VII	03.50	05.00	01.10	EL,OL	Cable damaged at Narayana School	No
2		Durga Nagar	Sundar Nagar	11KV	II	23:46	1:21	1:35	All Indication	AB Cable failed at Amedkar Nagar	Arranged B/F on 11KV Krishna Nagar fdr