

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		4		4		4			
3	MDK	107	933		2		2		2			
4	SDPT			3	8	3	5	3	5			3 No.s 11KV still
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	14	4	11	4	11	0	0	
	Grand Total	1082	6468	4	21	4	18	4	18	0	0	

TSSPDCL - LMRC / Corporate office

Date: 25.05.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Shadnagar	Rayalseema	33KV	Shadnagar	06.55	20.50	13.55		jumper conecting purpose With line	Rayalseema	-
1		Gajwel	Ahmedipur	33KV	Siddipet	17.00	19.00	02.00		Poles Damage	Ahmedipur	-
2	SDP	Musthyal	Komuravelly	33KV	Siddipet	18.20	19.20	01.00		Tree Branch Fall in Line near Kadaverugu Village	Komuravelly	-
3		Musthyal	Nagapuri	33KV	Siddipet	18.10	19.10	01.00		Tree Branch Fall in Line near Pochampally Village	Nagapuri	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 25.05.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	N B Gudem	Redlakunta	11KV	Huzurnagar	05.00	07.45	02.45	E/L	11Kv Line Snapped	-
2		Laxmapuram	Nidanpally	11KV	Choutuppal	00.00	08.20	08.20	EL/OL	11kv Line snapped at Mallesham well near Nidanpally (V)	-
3		Nakirekal	Kadaparthi	11KV	Nalgonda	11.35	12.40	01.05	E/L & O/L	Movement fult	-
4		Velugupally	lthavarigudem	11KV	Nalgonda	00.00	08.25	08.25	E/L	11KV Line Cut SS-1 Velugupally	-
1	MDK	Pati	Pati	11KV	Patancheru	18.35	20.05	01.30		BD due to under line cable cut	-
2		Gaddapotharam -II	Khajipally Indl.	11KV	Patancheru	01.15	11.55	10.40		BD due to 2No.s Pole Damged, Hitted by Tipper Lorry	-
1	SDP	NACHARAM	ANANTHAGIRIPALLY LC No. 4493	11KV	Gajwel	07.00	11.00	04.00		LT cable barn	-
2		KOKKONDA	KOTHUR LC No. 13589	11KV	Gajwel	19.15	20.28	01.13		11 KV line cut	-
3		KONDAPAK	KONDAPAK INDS LC No. 24303	11KV	Gajwel	18.30	20.15	01.45		Pole dameage	-
4		DOULTHABAD	DOULTHABAD TOWN LC No. 1808	11KV	Gajwel	19.20	20.20	01.00		Core insleter faile	-
5		Bejanki	Cotton Mill	11KV	Husnabad	16.20	18.20	02.00		Insulator Fail	-
6		Guruvannapet	Thapasally & Guruvannapet	11KV	Husnabad	17.20	Still			Heavy Rain & Wind 6 Poles break thapasally 3 poles	-
7		Guruvannapet	Posanpally	11KV	Husnabad	17.20	Still			Heavy rain & wind tree falling	-
8		Gagillapur	Gagillapur Agl	11KV	Husnabad	18.06	Still			Heavy Wind	-
1	RR S	Nanankramguda	Church	11KV	Gachibowli	04.18	05.25	01.07		11kv UG-Cable end-kit failed at Rama Naidu Studio, Nanakramguda	-
2		ESCI	Nanakramguda	11KV	Gachibowli	12.20	13.31	01.11		11kv UG-Cable problem at Divyasree	-
1	RR N	Town Medchal	NGO's Colony	11KV	Medchal	18.40	20.25	01.45	BD	11KV Line cut and replaced at Housing Board	-
2		Athiwelly	Ravalkole Thanda	11KV	Medchal	19.20	21.40	02.20	BD	11KV jumper cut and touched to Cross arm at Thanda Road	-
3		Vijayanagar	Jayanagar	11KV	Kukatpally	13.25	14.35	01.10	BD	AB Cable End kit failed near laxminilyam at Vijayanagar colony	-
1	HYD N	Addagutta	Shanthi Niketan	11KV	C-VI	09.30	10.53	01.23	EL,OL-Bph	Cable fault at Bharath Petrol Pump	Arranged B/F on 11KV Ravi Colony fdr
1	HYD S	Kandikal Gate	Naseeb Nagar	11KV	III	07.00	08.17	01.17	OL	Due to Over Load	Partial feeder charged at 07:35Hrs & remaining loads added on 11KV Phool Bagh fdr