

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	4		3		3				1No 33KV feeder still
3	MDK	107	933	1		1		1				
4	SDPT			2	18	2	18	2	18			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	7	18	6	18	6	18	0	0	
	Grand Total	1082	6468	7	24	6	24	6	24	0	0	

TSSPDCL - LMRC / Corporate office

Date: 27.05.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Narketpally	Narketpally	33KV	Nalgonda	17.03				PTR-1 Breaker limb blast		
2		Narketpally	Nemmani	33KV	Nalgonda	17.03	19.30	02.27				
3		Narketpally	Edukur	33KV	Nalgonda	17.03	20.00	02.57				
4		Narketpally	Nakkalapally	33KV	Nalgonda	17.03	18.15	01.12				
1	MDK	Jogipet	Dakur	33KV	Jogipet	15.35	20.55	05.20		B/D Due to Jumper Cut		-
1	SDPT	Siddipet	Mittapally	33KV	Siddipet	05.20	07.10	01.50		BD (Insulator Failed)		
2		Siddipet	Ponnala	33KV	Siddipet	04.40	07.10	02.30		BD (Insulator Failed)		

Circle-wise 11KV Breakdowns

Date: 27.05.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	SDPT	Gandipally	Gandipally	11KV	Husnabad	00.00	07.10	07.10		Insulator Fail	-
2		Gandipally	Ramavaram Exp	11KV	Husnabad	00.00	10.20	10.20		11KV line fall in	-
3		Gouravelly	Gudatipally	11KV	Husnabad	00.00	08.20	08.20		poles damaged	-
4		Cherial Town	Sundarayyanagar Agl	11KV	Husnabad	09.00	11.00	02.00		Jumper cutting	-
5		Akunoor	Rampoor	11KV	Husnabad	00.00	09.50	09.50		Disc Fail	-
6		Mustyal	Cherial Agl	11KV	Husnabad	06.10	11.05	04.55		Disc Fail	-
7		Chityal	Dommata	11KV	Husnabad	00.00	03.30	03.30		Gale and wind	-
8		AHAMADHIPUR	AHAMADHIPUR LC No. 27480	11KV	Gajwel	18.00	11.40	18.00		Jumper cut	-
9		AHAMADHIPUR	KOLGUR LC No. 27481	11KV	Gajwel	18.00	09.30	18.30		Insleter faile	-
10		AHAMADHIPUR	PIDICHED LC No. 27482	11KV	Gajwel	18.00	06.00	12.00		Pole damage and jumper cut	-
11		AHAMADHIPUR	DHILALPUR LC No. 27483	11KV	Gajwel	18.00	13.00	18.30		Insleter faile	-
12		GOWRARAM	GOWRARAM TOWEN2 LC No. 40163	11KV	Gajwel	16.52	17.00	00.08		Face to face break down	-
13		GOWRARAM	GOWRARAM TOWEN2 LC No. 40164	11KV	Gajwel	08.10	09.10	01.00		11 KV line cut	-
14		MARPADAGA	NAGIREDDYPALLY LC No. 28133	11KV	Gajwel	15.55	18.00	02.05		Line problem	-
15		MARPADAGA	MARPADAGA LC No. 28134	11KV	Gajwel	07.40	08.50	01.00		LT Line cut	-
16		MARPADAGA	SIRSINAGANDLA LC No. 28132	11KV	Gajwel	09.00	10.00	01.00		Caparpatti poendhi anta	-
17		THIMAREDDYPALLY	THIMAREDDYPALLY LC No. 14376	11KV	Gajwel	10.15	11.40	01.25		11 KV Insleter faile	-
18		GURALASOFA	RAMARAM Lc No. 2800	11KV	Gajwel	12.17	13.46	01.29		HT/LT	-
1	RR N	Laxmapur	Laxmapur	11KV	Medchal	14.56	15.56	01.00	BD	11KV Jumper Cut at Laxmapur Cheruvu	-
1	RR E	Kushaiguda	Rukminipuri	11KV	Sainikpuri	10.20	11.10	00.50		Thonda fallen on 11Kv line at Vartex Plaza back side (AE/OP)	-
2		Chengicherla	My Villas	11KV	Keesara	03.30	05.00	01.30		Lorry dashed to 11KV line at Kanaka Durga Nagar	-
3		Aushapur	Madharam	11KV	Keesara	18.00	18.40	00.40		Tree branches fallen on 11KV line at Madharam Village	-
1	HYD N	Lalaguda	Shanthi Nagar	11KV	Sec-Bad	06.09	07.15	01.06	A.R. tripped	No Visible Fault	-
1	HYD C	Golnaka	Brahmin Hostel	11KV	Azamabad	14.42	17.20	02.38	EL,OL	RMU Lugs & Insulator flash over at Indian Ice Cream City	-