

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------|------------------------------|------|------------------------------------|------|-------------------------|------|-------------------------------------|------|--------------------------------|------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | | | | | | | | |
| 7 | RR(E) | 168 | 403 | | | | | | | | | |
| 8 | Hyd | 194 | 1044 | | 2 | | 2 | | 2 | | | |
| | Total | 606 | 3055 | 0 | 2 | 0 | 2 | 0 | 2 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|-------------|-------------------------------|------|------------------------------------|------|-------------------------|------|-------------------------------------|------|--------------------------------|------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | | 1 | | 1 | | 1 | | | |
| 2 | NLG | 144 | 988 | | 4 | | 4 | | 4 | | | |
| 3 | MDK | 107 | 933 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 0 | 5 | 0 | 5 | 0 | 5 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 0 | 7 | 0 | 7 | 0 | 7 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 28.05.2020

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|-----|----------------------|------|----|----------|------------------|--------------------|-----------------------|---------------------------|
| 1 | MBNR | | | | NIL | | | | | NIL | | - |
| 2 | NLG | | | | NIL | | | | | NIL | | - |
| 3 | MDK | | | | NIL | | | | | NIL | | - |
| 4 | SDPT | | | | NIL | | | | | NIL | | - |
| 5 | RR S | | | | NIL | | | | | NIL | | - |
| 6 | RR N | | | | NIL | | | | | NIL | | - |
| 7 | RR E | | | | NIL | | | | | NIL | | - |
| 8 | HYD | | | | NIL | | | | | NIL | | - |

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 28.05.2020

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---------------------------|
| 1 | MBNR | Ponnakal | Rachala | 11KV | Jadcherla | 11.35 | 13.20 | 01.45 | | 11KV Wire cut near Rachala | - |
| 1 | NLG | Palem | Ogodu | 11KV | Nalgonda | 06.10 | 10.30 | 04.20 | E/L | 11KV Jumper Cut | - |
| 2 | | Velugupally | A.R.Gudem | 11KV | Nalgonda | 07.10 | 08.45 | 01.35 | E/L | Squirrel Died on Line at Near Mangalapally | - |
| 3 | | Pullemla | Pullemla AGL | 11KV | Nalgonda | 11.20 | 11.15 | 11.55 | E/L | Heavy Gale and Wind | - |
| 4 | | Tekumatla | Pinnaipalem | 11KV | Suryapet | 03.10 | 06.05 | 02.55 | EL | Insulator Flash Over | - |
| 1 | HYD S | Santosh Nagar | Venkateshwara Alayam | 11KV | VIII | 03.33 | 05.30 | 01.57 | EL,OL-Rph | No Visible Fault | |
| 1 | HYD N | Macha Bollaram | Krishna Nagar | 11KV | C-VI | 22.25 | 00.09 | 01.44 | EL,OL | DTR catch fire & Lines snapped at Chandra Nagar (4Nos DTR's kept off) | |