

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044	1	2	1	2	1	2			
	Total	606	3055	1	5	1	5	1	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		3		3		3			
3	MDK	107	933	1		1		1				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	4	1	4	1	4	0	0	
	Grand Total	1082	6468	2	9	2	9	2	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 01.05.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Jogipet	Dakur	33kv	Jogipet	21.05	00.00	02.55		Due to line twisting	Dakur	-
1	HYD S	220KV Ch' Gutta	Malakpet Gunj	33kv	Asmangadh	10.10	10.13	00.03	EL	Tripped on EL		Loads transferred onto 132KV Imlibun SS via 33KV Malakpet Gunj feeder

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 01.05.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Ponnakal	Ponnakal	11kv	Jadcherla	09.15	12.40	03.25		11Kv Wire Cut Near Kummari Narayana Bavi Side	-
1	NLG	Arlagaddagudem	N.R.Gudem	11kv	Nalgonda	05.30	09.15	03.45	E/L	11 KV Jumper Cut	-
2		Mamillagudem	Vibhulapuram	11kv	Huzurnagar	08.15	10.30	02.15	E/L	11kv Line Snapped	-
3		Pallerla	Kurella	11kv	Bhongir	04.40	11.10	06.30	EL/OL	11kv Line Snapped near Swami Reddy Well	-
1	RR N	Vemana colony	Old Bombayroad	11kv	Kukatpally	16.45	17.50	01.05		315 KVA DTR Jumper cut at Old Bombay road	-
2		Athiwelly	Ravalkole Thanda	11kv	Medchal	07.40	08.40	01.00		11KV Line cut & replacement near BS Steel company	-
1	RR E	Uppal	Ghatkesar	11kv	Habsiguda	21.20	21.50	00.30		11KV HG Fuse set blast & fallen on HT Jumper at Beerappa Gadda Smasana Vatika	-
1	HYD N	Bansilalpet	Naganna Kunta	11kv	V	14.28	15.42	01.14	EL,OL-Bph	HT Jumper cut at Bansilalpet Steps DTR	-----
1	HYD S	Toli Chowki	Paramount Colony	11kv	VII	16.30	18.13	01.43	EL	Jumpers touching to AB Switch at Grave Yard	Partial feeder charged & Remaining loads added on 11KV Hakimsha fdr