

**Status Report on Breakdowns (Urban / Rural)****Urban**

| S.No | Circle       | No.of Feeders Existing Urban |             | Breakdowns occurred during the day |            | Attended during the day |            | Time taken for restoring the supply |            |                                |          | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|------------|-------------------------|------------|-------------------------------------|------------|--------------------------------|----------|-------------------|
|      |              | 33KV                         | 11KV        | 33KV                               | 11KV       | 33KV                    | 11KV       | Rectified (Within 24 Hours)         |            | Not Rectified (Above 24 Hours) |          |                   |
|      |              |                              |             |                                    |            |                         |            | 33KV                                | 11KV       | 33KV                           | 11KV     |                   |
| 1    | MBN          | 18                           | 107         |                                    |            |                         |            |                                     |            |                                |          |                   |
| 2    | NLG          | 22                           | 358         |                                    |            |                         |            |                                     |            |                                |          |                   |
| 3    | MDK          | 97                           | 359         |                                    |            |                         |            |                                     |            |                                |          |                   |
| 4    | SDPT         |                              |             |                                    |            |                         |            |                                     |            |                                |          |                   |
| 5    | RR(S)        | 53                           | 234         |                                    | 20         |                         | 20         |                                     | 20         |                                |          |                   |
| 6    | RR(N)        | 54                           | 550         | 1                                  | 46         | 1                       | 46         | 1                                   | 46         |                                |          |                   |
| 7    | RR(E)        | 168                          | 403         |                                    | 20         |                         | 20         |                                     | 20         |                                |          |                   |
| 8    | Hyd          | 194                          | 1044        | 1                                  | 127        | 1                       | 127        | 1                                   | 127        |                                |          |                   |
|      | <b>Total</b> | <b>606</b>                   | <b>3055</b> | <b>2</b>                           | <b>213</b> | <b>2</b>                | <b>213</b> | <b>2</b>                            | <b>213</b> | <b>0</b>                       | <b>0</b> |                   |

**Rural**

| S.No | Circle             | No.of Feeders Existing Rurals |             | Breakdowns occurred during the day |            | Attended during the day |            | Time taken for restoring the supply |            |                                |          | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|------------|-------------------------|------------|-------------------------------------|------------|--------------------------------|----------|-------------------|
|      |                    | 33KV                          | 11KV        | 33KV                               | 11KV       | 33KV                    | 11KV       | Rectified (Within 24 Hours)         |            | Not Rectified (Above 24 Hours) |          |                   |
|      |                    |                               |             |                                    |            |                         |            | 33KV                                | 11KV       | 33KV                           | 11KV     |                   |
| 1    | MBN                | 107                           | 849         | 1                                  | 2          | 1                       | 2          | 1                                   | 2          |                                |          |                   |
| 2    | NLG                | 144                           | 988         | 3                                  | 9          | 3                       | 9          | 3                                   | 9          |                                |          |                   |
| 3    | MDK                | 107                           | 933         | 4                                  |            | 4                       |            | 4                                   |            |                                |          |                   |
| 4    | SDPT               |                               |             | 4                                  | 46         | 4                       | 46         | 4                                   | 46         |                                |          |                   |
| 5    | RR(S)              | 58                            | 396         |                                    |            |                         |            |                                     |            |                                |          |                   |
| 6    | RR(N)              | 38                            | 114         |                                    |            |                         |            |                                     |            |                                |          |                   |
| 7    | RR(E)              | 22                            | 133         |                                    |            |                         |            |                                     |            |                                |          |                   |
|      | <b>Total</b>       | <b>476</b>                    | <b>3413</b> | <b>12</b>                          | <b>57</b>  | <b>12</b>               | <b>57</b>  | <b>12</b>                           | <b>57</b>  | <b>0</b>                       | <b>0</b> |                   |
|      | <b>Grand Total</b> | <b>1082</b>                   | <b>6468</b> | <b>14</b>                          | <b>270</b> | <b>14</b>               | <b>270</b> | <b>14</b>                           | <b>270</b> | <b>0</b>                       | <b>0</b> |                   |

## TSSPDCL - LMRC / Corporate office

Date: 31.05.2020

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown  | Sub Stations Effected | Alternate Supply Arranged               |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---|
| 1    | MBNR   | Nagarkurnool        | Rakonda              | 33KV | Nagarkurnool         | 14.52 | 18.55 | 04.03    | E/L              | Tree fallen on the line & Insualtor failed at Chinnamuddanoor | Rakonda               | No                                      |
| 1    | NLG    | Nalgonda            | Pajjur               | 33KV | Nalgonda             | 14:30 | 17:15 | 2:45     | EL               | Due to heavy rain and wind                                    | Pajjur                | Alternate supply given by Aitipamula    |
| 2    |        | Haliya              | Peddavoora           | 33KV | Miryalaguda          | 14.55 | 15.15 | 00.20    | EL               | Due to heavy rain and wind                                    | Peddavoora            | Alternate supply given by Aitipamula    |
| 3    |        | Haliya              | Haliya               | 33KV | Miryalaguda          | 15.50 | 18.40 | 02.50    | EL               | 33KV Cross arm and 2 Nos Pin insulator failed                 | Haliya                | No                                      |
| 1    | MDK    | Kandi               | HFC-I                | 33KV | Sangareddy           | 16:10 | 19:55 | 3:45     |                  | Jumper cut  | HFC-I                 | No                                      |
| 2    |        | Sadasivapet         | Jogipet              | 33KV | Sangareddy           | 17.05 | 17.45 | 00.40    |                  | Tree branches fallen on the line                              | Jogipet               | No                                      |
| 3    |        | Jogipet             | Laxmisagar           | 33KV | Jogipet              | 14.15 | 17.35 | 03.20    |                  | Tree branches fallen on the line                              | Laxmisagar            | No                                      |
| 4    |        | Jogipet             | Dakur                | 33KV | Jogipet              | 14.15 | 17.35 | 03.20    |                  | Tree branches fallen on the line                              | Dakur                 | No                                      |
| 1    | SDPT   | Siddipet            | Rangadampally        | 33KV | Siddipet             | 14:40 | 18:45 | 04.05    |                  | Due to wind   | Rangadampally         | No                                      |
| 2    |        | Gajwel              | Jagadevpur           | 33KV | Gajwel               | 12:30 | 16:25 | 3:55     |                  | Insulator failed  | Jagadevpur            | No                                      |
| 3    |        | Gajwel              | KDA                  | 33KV | Gajwel               | 12:30 | 16:25 | 3:55     |                  | Insulator failed  | KDA                   | No                                      |
| 4    |        | Shanigaram          | Koheda               | 33KV | Husnabad             | 13:10 | 19:15 | 6:05     |                  | Due to heavy rain and wind                                    | Koheda                | No                                      |
| 1    | RR N   | Medchal             | Aliabad              | 33KV | Medchal              | 15:48 | 19:05 | 3:17     |                  | No visible fault  | Aliabad               | No                                      |
| 1    | HYD S  | 132KV Moosaram Bagh | Malakpet             | 33KV | Malakpet             | 03.00 | 03.10 | 00.10    | EL               | Cable fault   | Malakpet              | Loads transferred onto 132KV Imlibun SS |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown  | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---------------------------|
| 1    | MBNR   | Midjil             | Munnatur             | 11KV | Jadcherla            | 11.10 | 13.05 | 01.55    |                  | 11KV Wire cut near Midjil                                     | No                        |
| 2    |        | Kaverammamet       | Bandamidipally       | 11KV | Jadcherla            | 12.45 | 14.45 | 02.00    |                  | 11KV Jumper cut near Macharam                                 | No                        |
| 1    | NLG    | Urumadla           | Yelikatte            | 11KV | Nalgonda             | 16:55 | 17:40 | 0:45     | EL               | Jumper cut  | No                        |
| 2    |        | Buggabaigudem      | Vemulapally          | 11KV | Miryalaguda          | 10.35 | 12.00 | 01.25    | EL               | 11KV Jumper cut at SS   | No                        |
| 3    |        | B.Annaram          | Miryalguda ®         | 11KV | Miryalaguda          | 16.30 | 18.40 | 02.10    | EL               | 11KV disc insulator failed                                    | No                        |
| 4    |        | B.Annaram          | Miryalguda ®         | 11KV | Miryalaguda          | 16.30 | 18.45 | 02.15    | EL               | Tree fallen on the line                                       | No                        |
| 5    |        | Kondamadugu        | Kondamadugu Agl      | 11KV | Bhongir              | 05.30 | 10.00 | 04.30    | EL               | 11KV Line snapped near Bibinagar cheruvu.                     | No                        |
| 6    |        | Venkiryala         | Venkiryala Agl       | 11KV | Bhongir              | 14.44 | 16.05 | 01.21    | EL               | 11KV Disc failed padamatisomaram road Near Venkiryala village | No                        |
| 7    |        | Azeempet           | Repaka               | 11KV | Bhongir              | 13.20 | 16.00 | 02.40    | EL               | 11 KV Line snapped near Repaka village.                       | No                        |
| 8    |        | Athmakur           | Koratikal            | 11KV | Bhongir              | 07.02 | 08.35 | 01.33    | EL               | 11KV Insulator failed near Koratikal village.                 | No                        |
| 9    |        | D.Nagaram          | Pipalpahad 24        | 11KV | Choutuppal           | 13:15 | 17:00 | 3:45     | EL               | 11KV Insulator failed near Pipalpahad village                 | No                        |
| 1    | SDPT   | Gagillapur         | Vallampata           | 11KV | Husnabad             | 1:00  | 6:00  | 5:00     |                  | Heavy Gale and Rain   | No                        |
| 2    |        | Komuravelli        | Kistampeta           | 11KV | Husnabad             | 13:40 | 15:40 | 2:00     |                  | Insulator Failed  | No                        |
| 3    |        | Komuravelli        | Peddarajipeta        | 11KV | Husnabad             | 15:10 | 17:50 | 2:40     |                  | Heavy Gale and Rain   | No                        |
| 4    |        | Rebarthy           | Rebarthy AGL         | 11KV | Husnabad             | 16:40 |       |          |                  | Heavy Gale and Rain   | No                        |
| 5    |        | Rebarthy           | Ladnoor AGL          | 11KV | Husnabad             | 16:40 |       |          |                  | Heavy Gale and Rain   | No                        |
| 6    |        | Guruvannapet       | Guruvannapet         | 11KV | Husnabad             | 17:25 | 18:40 | 1:15     |                  | Heavy Gale and Rain   | No                        |
| 7    |        | Gurjakunta         | Vecharani            | 11KV | Husnabad             | 13:05 | 16:55 | 3:50     |                  | Heavy Gale and Rain   | No                        |
| 8    |        | Gurjakunta         | Gurjakunta Town      | 11KV | Husnabad             | 13:05 | 16:50 | 3:45     |                  | Heavy Gale and Rain   | No                        |
| 9    |        | Gurjakunta         | Gurjakunta AGL       | 11KV | Husnabad             | 14:45 | 16:50 | 2:05     |                  | Heavy Gale and Rain   | No                        |
| 10   |        | Bejjanki           | Muthannapet          | 11KV | Husnabad             | 12:00 | 17:24 | 5:24     |                  | Heavy Gale and Rain   | No                        |
| 11   |        | Koheda             | Canal                | 11KV | Husnabad             | 20:00 |       |          |                  | Heavy Gale and Rain   | No                        |
| 12   |        | JAGADEVPUR SS      | JAGADEVPUR TOWN      | 11KV | Gajwel               | 17:40 | 19:00 | 1:20     |                  | JAMPUR CUT  | No                        |
| 13   |        | JAGADEVPUR SS      | JAGADEVPUR AGL       | 11KV | Gajwel               | 17:25 | 19:38 | 2:13     |                  | DISC FAILED   | No                        |
| 14   |        | JAGADEVPUR SS      | INDUSTRIAL           | 11KV | Gajwel               | 17:10 |       |          |                  | 11KV LINE CUT AND POST INSULATORS FAILED                      | No                        |
| 15   |        | PREGANPUR SS       | GUNDANNAPALLY        | 11KV | Gajwel               | 14:58 | 17:30 | 2:32     |                  | CONVERT THREE PHASE TO SINGLE PHASE                           | No                        |
| 16   |        | KODAKANDLA SS      | RAYAVARAM            | 11KV | Gajwel               | 17:50 | 19:00 | 1:10     |                  | INSULATOR FAILED  | No                        |
| 17   |        | SINGATAM SS        | ANANTHARAPALLY       | 11KV | Gajwel               | 14:00 |       |          |                  | POLE DAMAGE   | No                        |
| 18   |        | MARKOOK SS         | MARKOOK              | 11KV | Gajwel               | 19:00 |       |          |                  | CONVERT THREE PHASE TO SINGLE PHASE                           | No                        |
| 19   |        | WARDARAJPUR SS     | WARDARAJPUR          | 11KV | Gajwel               | 15:23 | 16:05 | 0:42     |                  | DISC FAILED   | No                        |
| 20   |        | ERRAVALLY SS       | LIFT IRRIGATION      | 11KV | Gajwel               | 14:30 | 16:45 | 2:15     |                  | DISC FAILED AND INSULATOR FAILED                              | No                        |
| 21   |        | ERRAVALLY SS       | LIFT IRRIGATION      | 11KV | Gajwel               | 18:10 | 19:53 | 1:43     |                  | DISC FAILED   | No                        |
| 22   |        | GANESHPALLY SS     | ANGADIKISTAPUR       | 11KV | Gajwel               | 14:40 | 16:40 | 2:00     |                  | DISC FAILED   | No                        |
| 23   |        | DAMARAKUNTA SS     | DAMARAKUNTA          | 11KV | Gajwel               | 19:17 | 19:27 | 0:10     |                  | DISC FAILED   | No                        |

| S.No | Circle        | Name of 33/11KV SS | Name of 11 KV Feeder | Vol      | Name of the Division | From  | To    | Duration | Relay Indication                               | Cause of Breakdown   | Alternate Supply Arranged |
|------|---------------|--------------------|----------------------|----------|----------------------|-------|-------|----------|--|--|---------------------------|
| 24   | SDPT          | KARKAPATLA SS      | GLOBEN               | 11KV     | Gajwel               | 18:20 | 18:55 | 0:35     |  | 11KV DISC FAILED   | No                        |
| 25   |               | PAMULAPARTHY SS    | PAMULAPARTHY         | 11KV     | Gajwel               | 18:40 | 19:05 | 0:25     |  | JUMPER CUT   | No                        |
| 26   |               | GOWRARAM SS        | GOWRARAM TOWN        | 11KV     | Gajwel               | 14:14 | 16:15 | 2:00     |  | TREE BRANCH WAS FALLEN   | No                        |
| 27   |               | GOWRARAM SS        | MAILARAM             | 11KV     | Gajwel               | 14:15 | 18:15 | 4:00     |  | TREE BRANCH WAS FALLEN   | No                        |
| 28   |               | NACHARAM SS        | MADHARAM             | 11KV     | Gajwel               | 15:00 | 19:00 | 4:00     |  | INSULATOR FAILED   | No                        |
| 29   |               | NEMTOOR SS         | NEMTOOR              | 11KV     | Gajwel               | 16:20 |       |          |  | POLE DAMAGE  | No                        |
| 30   |               | THUNKIKHALSA SS    | AMBERPET             | 11KV     | Gajwel               | 15:00 |       |          |  | POLE DAMAGE  | No                        |
| 31   |               | VANTIMAMIDI SS     | INDUSTRIAL           | 11KV     | Gajwel               | 13:10 | 17:30 | 4:20     |  | POST INSULATOR FAILED  | No                        |
| 32   |               | BANDARAM SS        | BANDARAM AGL         | 11KV     | Gajwel               | 13:00 | 15:15 | 2:15     |  | POLE DAMAGE  | No                        |
| 33   |               | DUDEEDA SS         | RAMPALLY             | 11KV     | Gajwel               | 15:00 | 16:10 | 1:10     |  | POLE DAMAGE  | No                        |
| 34   |               | MARPADAGA SS       | SIRSINGALLA AGL      | 11KV     | Gajwel               | 14:50 | 18:00 | 3:10     |  | JUMPER CUT   | No                        |
| 35   |               | MEDINIPUR SS       | MANGOL               | 11KV     | Gajwel               | 14:00 | 18:00 | 4:00     |  | 5 POLES DAMAGE   | No                        |
| 36   |               | THIPPARAM SS       | ERRAVALLY AGL        | 11KV     | Gajwel               | 11:40 |       |          |  | POLE DAMAGE  | No                        |
| 37   |               | THIPPARAM SS       | ERRAVALLY INDUSTRIAL | 11KV     | Gajwel               | 11:40 |       |          |  | POLE DAMAGE  | No                        |
| 38   |               | MUBARASPUR SS      | THIMMAPUR            | 11KV     | Gajwel               | 17:25 | 18:45 | 1:20     |  | 11KV LINE CUT  | No                        |
| 39   |               | RAIPOLE SS         | KOTHAPALLY           | 11KV     | Gajwel               | 14:00 | 17:15 | 3:15     |  | HT TOP PEAS CUT  | No                        |
| 40   |               | GURRALASOFA SS     | RAMARAM              | 11KV     | Gajwel               | 14:05 | 16:05 | 2:00     |  | TREE BRANCH WAS FALLEN   | No                        |
| 41   |               | GURRALASOFA SS     | VADDEPALLY           | 11KV     | Gajwel               | 14:08 | 16:40 | 2:28     |  | TREE BRANCH WAS FALLEN   | No                        |
| 42   |               | GURRALASOFA SS     | INDUSTRIAL           | 11KV     | Gajwel               | 16:14 | 18:35 | 2:19     |  | COPPERPATTI CUT  | No                        |
| 43   |               | Ragothampally      | Ragothampally        | 11KV     | Siddipet             | 15:23 | 18:00 | 2:37     |  | B/D-DTR Lighting Arrester fail   | No                        |
| 44   | Ragothampally | Ragothampally      | 11KV                 | Siddipet | 20:30                |       |       |          | Tree bunches fallen on 11KV line-B/D rectified | No   |                           |
| 45   | Dharmajipet   | Agondaswamy        | 11KV                 | Siddipet | 17:00                | 18:30 | 1:30  |          | Tree branches fallen on HT Line                | No   |                           |
| 46   | Kasulabad     | Kasulabad          | 11KV                 | Siddipet | 4:10                 | 7:30  | 3:20  |          | Tree branches fallen on HT Line                | No   |                           |
| 1    | RR S          | ESCI               | ESCI                 | 11KV     | Gachibowli           | 15:25 | 17:00 | 1:35     |  | 11kv Pin Insulator failed at Engineer's Staff college of india   | No                        |
| 2    |               | Nanakramguda       | N'widia              | 11KV     | Gachibowli           | 13:47 | 17:37 | 3:50     |  | 11kv Pin Insulator failed at Hill Cryst, 11kv disk failed near Google at IT park.  | No                        |
| 3    |               | Nanakramguda       | TNGO'S Colony        | 11KV     | Gachibowli           | 14:10 | 16:56 | 2:46     |  | TNGO'S Colony Breaker O/G AB Switch Y'Phase Lighting Erester failure near Nanakramguda SS, 11kv Pin Insulator failure near TNGO'S Colony Entrance. | No                        |
| 4    |               | Gachibowli         | Nalagandla           | 11KV     | Gachibowli           | 14:45 | 17:40 | 2:55     |  | Due to Heavy Rain and Wind (Tree Branches fallen on the 11kv line at Gopi Nagar)   | No                        |
| 5    |               | Gachibowli         | Sudarshan Nagar      | 11KV     | Gachibowli           | 14:45 | 16:55 | 2:10     |  | Due to Heavy Rain and Wind (Tree Branches fallen on the 11kv line at Sudarshan Nagar)  | No                        |
| 6    |               | Gachibowli         | Aparna               | 11KV     | Gachibowli           | 15:00 | 16:45 | 1:45     |  | Due to Heavy Rain and Wind (Tree Branches fallen on the 11kv line at Gulmohar Park)  | No                        |
| 7    |               | Gachibowli         | Telephone Exchange   | 11KV     | Gachibowli           | 15:25 | 17:00 | 1:35     |  | Due to Heavy Rain and Wind.  | No                        |

| S.No | Circle    | Name of 33/11KV SS | Name of 11 KV Feeder | Vol            | Name of the Division | From    | To    | Duration | Relay Indication | Cause of Breakdown   | Alternate Supply Arranged  |    |
|------|-----------|--------------------|----------------------|----------------|----------------------|---------|-------|----------|------------------|--|--|----|
| 8    | RR S      | Lanco Hills        | Khajaguda            | 11KV           | Gachibowli           | 16:49   | 17:56 | 1:07     |                  | Due to Heavy Rain and Wind (Tree Branches fallen on the 11kv line at Niharika)                                     | No   |    |
| 9    |           | Chandanagar        | Rail Vihar           | 11KV           | Gachibowli           | 14:40   | 15:50 | 1:10     |                  | Due to Heavy Rain and Wind (Tree Branches fallen on the 11kv line at Rail Vihar)                                   | No   |    |
| 10   |           | Chandanagar        | Market               | 11KV           | Gachibowli           | 14:20   | 16:00 | 1:40     |                  | Due to Heavy Rain and Wind (Tree Branches fallen on the 11kv line at Market)                                       | No   |    |
| 11   |           | Chandanagar        | Engineer's Enclave   | 11KV           | Gachibowli           | 14:20   | 16:00 | 1:40     |                  | Due to Heavy Rain and Wind (Tree Branches fallen on the 11kv line at Engineer's Enclave)                           | No   |    |
| 12   |           | Chandanagar        | Madinaguda           | 11KV           | Gachibowli           | 14:20   | 16:30 | 2:10     |                  | Due to Heavy Rain and Wind (Tree Branches fallen on the 11kv line at Madinaguda)                                   | No   |    |
| 13   |           | Chandanagar        | Mythri Nagar         | 11KV           | Gachibowli           | 14:20   | 17:00 | 2:40     |                  | Due to Heavy Rain and Wind (Tree Branches fallen on the 11kv line at Mythri Nagar)                                 | No   |    |
| 14   |           | Chandanagar        | Taranagar            | 11KV           | Gachibowli           | 14:20   | 17:00 | 2:40     |                  | Due to Heavy Rain and Wind (Tree Branches fallen on the 11kv line and 11kv line cut at Ramachary Agriculture land) | No   |    |
| 15   |           | Chandanagar        | Huda Colony          | 11KV           | Gachibowli           | 14:20   | 17:00 | 2:40     |                  | Due to Heavy Rain and Wind (Tree Branches fallen on the 11kv line and 11kv Disc failed at Huda Colony)             | No   |    |
| 16   |           | Chandanagar        | Shanthi Nagar        | 11KV           | Gachibowli           | 14:20   | 17:20 | 3:00     |                  | Due to Heavy Rain and Wind (Tree Branches fallen on the 11kv line at Shanthi Nagar)                                | No   |    |
| 17   |           | Balajinagar        | INDU                 | 11KV           | Kondapur             | 13:23   | 15:18 | 1:55     |                  | 11KV line Phase to Phase at MIG - 617 (Due To Heavy Rain And Wind)   | No   |    |
| 18   |           | Balajinagar        | Moosapet             | 11KV           | Kondapur             | 13:35   | 15:16 | 1:41     |                  | Due to Heavy Rain and Wind.  | No   |    |
| 19   |           | Balajinagar        | 4th Phase            | 11KV           | Kondapur             | 13:46   | 15:02 | 1:16     |                  | Due to Heavy Rain and Wind.  | No   |    |
| 20   |           | Gachibowli         | Kalajyothy           | 11KV           | Kondapur             | 14:45   | 15:45 | 1:00     |                  | Due to Heavy Rain and Wind (Tree Branches fallen on the 11kv line near SBI Bank)                                   | No   |    |
| 1    |           | RR N               | Kompally             | NCL            | 11KV                 | Medchal | 12:00 | 13:04    | 1:04             |  | Tree Fallen on 11KV Line at Saibaba Temple,NCL North                       | No |
| 2    |           |                    | UMCC                 | RM Nagar       | 11KV                 | Medchal | 13:20 | 15:45    | 2:25             |  | 11KV Pin Insulator failed at Ushodaya colony Phase-II                      | No |
| 3    |           |                    | Subhash Nagar        | Meenakshi      | 11KV                 | Medchal | 13:30 | 15:50    | 2:20             |  | 11KV PinInsulator failed at Meenakshi                                      | No |
| 4    |           |                    | Kompally             | Kompally       | 11KV                 | Medchal | 13:50 | 16:18    | 2:28             |  | 11KV AB Cable Failed near Government School                                | No |
| 5    |           |                    | Petbasheerabad       | Satyam Enclave | 11KV                 | Medchal | 14:00 | 17:20    | 3:20             |  | 11KV 2 Nos Disc failed and replaced at Bloom Hospital and Dandamudi Enclve | No |
| 6    |           |                    | Jagathgirigutta      | Maqdoom Nagar  | 11KV                 | Medchal | 14:25 | 16:05    | 1:40             |  | Tree Branches fallen on the 11KV Line at Pochamma Temple                   | No |
| 7    |           |                    | Petbasheerabad       | ST. Ann's      | 11KV                 | Medchal | 14:30 | 19:15    | 4:45             |  | 11KV Disc Failed and replaced at Narayanapur Village                       | No |
| 8    | Laxmapur  |                    | Narayanpur           | 11KV           | Medchal              | 14:15   | 16:55 | 2:40     |                  | 11KV Pin Insulator failed at Yellaguda Village   | No   |    |
| 9    | Uddamarry |                    | Yellaguda            | 11KV           | Medchal              | 14:25   | 17:00 | 2:35     |                  | Tree fallen on the 11KV Line at MC Pally   | No   |    |
| 10   | Laxmapur  |                    | MC Pally             | 11KV           | Medchal              | 16:40   | 19:15 | 2:35     |                  | Tree fallen on the 11KV Line at Malla Reddy Collage  | No   |    |
| 11   | GP Pally  |                    | Malla reddy          | 11KV           | Medchal              | 17:40   | 19:50 | 2:10     |                  | 11KV Disc Failed and replaced at Basaragadi Village  | No   |    |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol            | Name of the Division | From       | To    | Duration | Relay Indication | Cause of Breakdown   | Alternate Supply Arranged                                       |    |
|------|--------|--------------------|----------------------|----------------|----------------------|------------|-------|----------|------------------|--|---|----|
| 12   | RR N   | Gowdavelly         | IDA Gowdawelly       | 11KV           | Medchal              | 15:30      | 17:30 | 2:00     |                  | Tree fallen on the 11KV Line at Arunodaya company back side    | No  |    |
| 13   |        | GP Pally           | Apparel Park         | 11KV           | Medchal              | 14:15      | 16:00 | 1:45     |                  | 11KV Brass Patti cut and replaced at Saigeetha Ashramam        | No  |    |
| 14   |        | Kandlakoya         | Saigeetha Ashramam   | 11KV           | Medchal              | 17:15      | 18:40 | 1:25     |                  | No Fault   | No  |    |
| 15   |        | GP Pally           | GP Pally             | 11KV           | Medchal              | 15:15      | 16:30 | 1:15     |                  | Tree Branches fallen on the 11KV Line at Anatharam Village     | No  |    |
| 16   |        | Kolthur            | Anantaram            | 11KV           | Medchal              | 15:40      | 16:50 | 1:10     |                  | Tree fallen on the 11KV Line Hanuman Temple Nuthankal          | No  |    |
| 17   |        | Nuthankal          | Nuthankal            | 11KV           | Medchal              | 18:35      | 19:40 | 1:05     |                  | Tree fallen on the 11KV Line at Nuzuveedu Seeds Company        | No  |    |
| 18   |        | Kandlakoya         | Godrej IDA           | 11KV           | Medchal              | 20:33      | 21:43 | 1:10     |                  | 11KV Disc failed at Keshavpur Village                          | No  |    |
| 19   |        | Uddamarry          | Keshavpur            | 11KV           | Medchal              | 20:33      | 21:43 | 1:10     |                  | 11KV Disc failed at Keshavpur Village                          | No  |    |
| 20   |        | Nizampet           | Rajadhani scool      | 11KV           | Kukatpally           | 13:50      | 14:50 | 1:00     |                  | Due to heavy rain  | No  |    |
| 21   |        | Nizampet           | Nizampet             | 11KV           | Kukatpally           | 14:00      | 14:52 | 0:52     |                  | Due to heavy rain  | No  |    |
| 22   |        | Vikas              | VOLVO                | 11KV           | Kukatpally           | 14:00      | 15:20 | 1:20     |                  | 11KV line touch the LT pole at Kousalya colony                 | No  |    |
| 23   |        | Madeenaguda        | JPN Nagar            | 11KV           | Kukatpally           | 13:38      | 15:01 | 1:23     |                  | Due to heavy rain  | No  |    |
| 24   |        | Balajinagar        | Vivekananda nagar    | 11KV           | Kukatpally           | 14:37      | 15:55 | 1:18     |                  | Due to heavy rain  | No  |    |
| 25   |        | Mayurinagar        | Gokaraju Rangaraju   | 11KV           | Kukatpally           | 13:45      | 14:53 | 1:08     |                  | Due to heavy rain  | No  |    |
| 26   |        | Mayurinagar        | KTR Colony           | 11KV           | Kukatpally           | 13:50      | 14:54 | 1:04     |                  | Due to heavy rain  | No  |    |
| 27   |        | Prashanthi Hills   | Allaha pur Society   | 11KV           | Kukatpally           | 13:25      | 14:50 | 1:25     |                  | Due to heavy rain  | No  |    |
| 28   |        | Prashanthi Hills   | Srinivasa Colony     | 11KV           | Kukatpally           | 13:25      | 16:05 | 2:40     |                  | 11kv AB Cable Failure At Balaji Water Plant                    | No  |    |
| 29   |        | Vijayanagar        | Ennadu Colony        | 11KV           | Kukatpally           | 13:15      | 14:50 | 1:35     |                  | Due to heavy rain  | No  |    |
| 30   |        | Vijayanagar        | Shanthi Nagar        | 11KV           | Kukatpally           | 13:30      | 14:40 | 1:10     |                  | Due to heavy rain  | No  |    |
| 31   |        | Vijayanagar        | SapathaGiri colony   | 11KV           | Kukatpally           | 14:30      | 16:10 | 1:40     |                  | Due to heavy rain  | No  |    |
| 32   |        | Madinaguda         | Wiedio Colony        | 11KV           | Kukatpally           | 19:25      | 20:45 | 1:20     |                  | 11kv Disk Failure At Ring View Hotel Madinaguda                | No  |    |
| 33   |        | Jeedimetla-III     | Ram Reddy Nagar      | 11KV           | Jeedimetla           | 13:29      | 14:30 | 1:01     |                  | Due To Rain  | No  |    |
| 34   |        | Jeedimetla-III     | U S P Organic        | 11KV           | Jeedimetla           | 13:40      | 17:00 | 3:20     |                  | 11kv AB Cable End Kit Failure At Mylon Company Phase-I         | No  |    |
| 35   |        | Jeedimetla-IV      | Vasudha              | 11KV           | Jeedimetla           | 14:40      | 16:10 | 1:30     |                  | Tree Branches Fallen On The 11kv Line AT Ice Cream Company     | No  |    |
| 36   |        | Jeedimetla-IV      | Aai Matha            | 11KV           | Jeedimetla           | 14:45      | 16:05 | 1:20     |                  | Tree Branches Fallen On The 11kv Line AT Laxmi Package Company | No  |    |
| 37   |        | Suraram            | Sai Baba Nagar       | 11KV           | Jeedimetla           | 16:55      | 18:05 | 1:10     |                  | Re-Closer Lighting Areester Failure At Sai Baba Nagar          | No  |    |
| 38   |        | Jeedimetla-II      | N R SA               | 11KV           | Jeedimetla           | 13:20      | 15:00 | 1:40     |                  | Due To Rain  | No  |    |
| 39   |        | Jeedimetla-II      | Apuroopa Colony      | 11KV           | Jeedimetla           | 13:25      | 16:05 | 2:40     |                  | 11kv AB Cable failure At Modi Apt                              | No  |    |
| 40   |        | Jeedimetla-II      | Phase-V              | 11KV           | Jeedimetla           | 13:25      | 15:00 | 1:35     |                  | Due To Rain  | No  |    |
| 41   |        | Jeedimetla-II      | Kompally Pharma      | 11KV           | Jeedimetla           | 13:35      | 15:00 | 1:25     |                  | Due To Rain  | No  |    |
| 42   |        | Jeedimetla-II      | Excell               | 11KV           | Jeedimetla           | 13:38      | 15:00 | 1:22     |                  | Due To Rain  | No  |    |
| 43   |        | Jeedimetla-II      | Apuroopa Colony      | 11KV           | Jeedimetla           | 16:40      | 17:50 | 1:10     |                  | 11kv AB Cable failure At Rao School                            | No  |    |
| 44   |        | RR N               | Prashanthi Hills     | Mithila nagar  | 11KV                 | Jeedimetla | 13:25 | 16:11    | 2:46             |  | Tree Branches Fallen On The 11kv Line AT Pt-No -69 Mithalanagar | No |
| 45   |        |                    | Bahadurapally        | Katta Maissama | 11KV                 | Jeedimetla | 15:30 | 16:35    | 1:05             |  | Tree Branches Fallen On The 11kv Line AT Kallu Charu            | No |
| 46   |        |                    | Gagillapur           | F-II           | 11KV                 | Jeedimetla | 13:40 | 16:30    | 2:50             |  | Tree Fallen On The 11kv Line At gagillapur kamman               | No |
| 1    |        |                    | NGRI                 | Kalyanpuri     | 11KV                 | Habsiguda  | 13:41 | 14:20    | 0:39             |  | Coverd cable jumper cut at Azmad nagar                          | No |
| 2    |        |                    | NGRI                 | HBG            | 11KV                 | Habsiguda  | 14:15 | 14:59    | 0:44             |  | Coverd cable touched at Brudhavan colony                        | No |

| S.No | Circle           | Name of 33/11KV SS | Name of 11 KV Feeder | Vol          | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown   | Alternate Supply Arranged            |    |
|------|------------------|--------------------|----------------------|--------------|----------------------|-------|-------|----------|------------------|--|--------------------------------------|----|
| 3    | RR E             | Uppal Kalsa        | Vijaypuri colony     | 11KV         | Habsiguda            | 13:06 | 14:15 | 1:09     |                  | 11KV Pin insulator failed at HMDa layout                                   | No                                   |    |
| 4    |                  | Street no 8        | Ravinder nagar       | 11KV         | Habsiguda            | 13:38 | 14:38 | 1:00     |                  | Tree branches fallen on 11kv at SBI Bank road                              | No                                   |    |
| 5    |                  | Janapriya          | Hightension          | 11KV         | Sainikpuri           | 13:20 | 14:10 | 0:50     |                  | Tree branches fallen on 11Kv line Ashok Manipuri Colony                    | No                                   |    |
| 6    |                  | Sainikpuri         | Saipuri              | 11KV         | Sainikpuri           | 14:17 | 15:10 | 0:53     |                  | Tree branches fallen on 11Kv line at Hasthinapuri Saipuri                  | No                                   |    |
| 7    |                  | Kushaiguda         | Kushaiguda           | 11KV         | Sainikpuri           | 12:50 | 14:30 | 1:40     |                  | Tree branches fallen on 11Kv line at Kushaiguda Insdustry                  | No                                   |    |
| 8    |                  | Kushaiguda         | Saibaba Temple       | 11KV         | Sainikpuri           | 12:50 | 14:20 | 1:30     |                  | Tree branches fallen on 11Kv line at ECIL X Road                           | No                                   |    |
| 9    |                  | Moula-Ali          | Moula-Ali            | 11KV         | Sainikpuri           | 14:55 | 16:00 | 1:05     |                  | Tree branches fallen on 11Kv line JTC X Road                               | No                                   |    |
| 10   |                  | AS Rao Nagar       | BSNL                 | 11KV         | Sainikpuri           | 12:58 | 16:39 | 3:41     |                  | Tree fallen on 11Kv line on 2 11Kv line cu at DAV Colony Gate Kamala Nagar | No                                   |    |
| 11   |                  | AS Rao Nagar       | BSNL                 | 11KV         | Sainikpuri           | 18:26 | 19:29 | 1:03     |                  | 11Kv Disc failed Ayyppa Sawamy Temple Kamala Nagar                         | No                                   |    |
| 12   |                  | AS Rao Nagar       | Maruhi Nagar         | 11KV         | Sainikpuri           | 19:34 | 20:32 | 0:58     |                  | 11Kv Disc failed at 35 Bus Stop  | No                                   |    |
| 13   |                  | Vasanthapuri       | Ragavendra           | 11KV         | Sainikpuri           | 16:09 | 18:45 | 2:36     |                  | 11Kv Pin insulator on Disc failed at Bala Saraswathi Nagar                 | No                                   |    |
| 14   |                  | Vasanthapuri       | Ganesh Temple        | 11KV         | Sainikpuri           | 16:19 | 17:10 | 0:51     |                  | 11Kv insulator failed at Vasanthapuri Colony Boomaiah T/F                  | No                                   |    |
| 15   |                  | Anandbag           | Chandragiri Colony   | 11KV         | Sainikpuri           | 13:25 | 14:20 | 0:55     |                  | 11Kv Line Pole earthing at SS Opp  | No                                   |    |
| 16   |                  | Singapur           | I.T park             | 11KV         | Keesara              | 13:10 | 15:20 | 2:10     |                  | 11KV Jumper cut at Raheja  | No                                   |    |
| 17   |                  | Singapur           | RGK                  | 11KV         | Keesara              | 12:10 | 16:00 | 3:50     |                  | 11KV Line cut at Gayatri temple  | No                                   |    |
| 18   |                  | Narapally          | Industrial           | 11KV         | Keesara              | 13:30 | 15:10 | 1:40     |                  | Disc failed at Vijaypuri colony  | No                                   |    |
| 19   |                  | Narapally          | P.singaram           | 11KV         | Keesara              | 14:20 | 15:55 | 1:35     |                  | Tree branches fallen on 11kv line at Koremulla                             | No                                   |    |
| 20   |                  | Narapally          | Narapally            | 11KV         | Keesara              | 15:55 | 17:40 | 1:45     |                  | Disc failed at Delhi school medpally                                       | No                                   |    |
| 1    |                  | HYD N              | Clock Tower          | Station Road | 11KV                 | V     | 12.41 | 15.03    | 02.22            | EL   | No Visible Fault (Due to heavy Rain) | No |
| 2    |                  |                    | Pragatools           | R.R.Nagar    | 11KV                 | VI    | 13:24 | 14:36    | 1:12             | EL   | No Visible Fault (Due to heavy Rain) | No |
| 3    | Pragatools       |                    | Giri Nagar           | 11KV         | VI                   | 13:26 | 14:31 | 1:05     | EL               | No Visible Fault (Due to heavy Rain)                                       | No                                   |    |
| 4    | Tirumalagiri     |                    | Chinna Kamela        | 11KV         | C-VI                 | 13:17 | 14:50 | 1:33     | EL               | No Visible Fault (Due to heavy Rain)                                       | No                                   |    |
| 5    | Srinagar Colony  |                    | Satya Sai            | 11KV         | X                    | 13:24 | 14:54 | 1:30     | EL               | No Visible Fault (Due to heavy Rain)                                       | No                                   |    |
| 6    | Kalyan Nagar     |                    | Sri Ram Nagar        | 11KV         | IV                   | 14:06 | 15:47 | 1:41     | All Indication   | RMU flash over at Dhanunjay Apts   | No                                   |    |
| 7    | Tirumalagiri     |                    | Mangapuram           | 11KV         | C-VI                 | 13:27 | 15:09 | 1:42     | EL               | No Visible Fault (Due to heavy Rain)                                       | No                                   |    |
| 8    | H.M.T.           |                    | Sri Sai Colony       | 11KV         | VI                   | 14:00 | 16:05 | 2:05     | EL               | No Visible Fault (Due to heavy Rain)                                       | No                                   |    |
| 9    | Macha Bollaram   |                    | Sai Reddy Nagar      | 11KV         | C-VI                 | 13:30 | 14:55 | 1:25     | EL               | No Visible Fault (Due to heavy Rain)                                       | No                                   |    |
| 10   | Ravindra Society |                    | Ayyanna Pride        | 11KV         | X                    | 14:15 | 15:20 | 1:05     | EL               | Tree branches fallen on lines at Audi Show Room                            | No                                   |    |
| 11   | Monda Market     |                    | Monda Market         | 11KV         | V                    | 13:55 | 15:00 | 1:05     | EL               | 3Nos. Jumpers cut at Monda Market  | No                                   |    |
| 12   |                  | Gunrock            | A.W.H.O.             | 11KV         | C-VI                 | 13:54 | 16:02 | 2:08     | EL               | Tree branches fallen on Lines & O/G Jumper cut at AWHO Colony              | No                                   |    |
| 13   |                  | Osm. University    | Ladies Hostel        | 11KV         | V                    | 13:10 | 15:00 | 1:50     | EL               | Tree branches fallen on lines at Cycle Stadium                             | No                                   |    |
| 14   |                  | Begumpet           | Vidyuth Towers       | 11KV         | IV                   | 13:58 | 15:24 | 1:26     | EL               | No Visible Fault (Due to heavy Rain)                                       | No                                   |    |
| 15   |                  | Yellareddyguda     | Pragathi Nagar       | 11KV         | X                    | 13:45 | 15:10 | 1:25     | EL               | Tree branches fallen on lines at Sai Teja Apts                             | No                                   |    |
| 16   |                  | Yellareddyguda     | Savera               | 11KV         | X                    | 14:25 | 16:25 | 2:00     | EL               | Disc Insulator flash over at Yousufguda Basthi                             | No                                   |    |
| 17   |                  | Film Nagar         | Apollo               | 11KV         | X                    | 13:45 | 14:47 | 1:02     | EL               | No Visible Fault (Due to heavy Rain)                                       | No                                   |    |
| 18   |                  | Jubilee Hills      | A.O.U.               | 11KV         | X                    | 14:00 | 15:10 | 1:10     | EL               | No Visible Fault (Due to heavy Rain)                                       | No                                   |    |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol        | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown   | Alternate Supply Arranged   |    |
|------|--------|--------------------|----------------------|------------|----------------------|-------|-------|----------|------------------|--|---|----|
| 19   | HYD N  | Prashanth Nagar    | Andhra Jyothi        | 11KV       | VI                   | 13:10 | 15:20 | 2:10     | EL               | No Visible Fault (Due to heavy Rain)                               | No  |    |
| 20   |        | Bowenpally         | B.B.R.Hospital       | 11KV       | VI                   | 13:55 | 17:20 | 3:25     | EL               | No Visible Fault (Due to heavy Rain)                               | No  |    |
| 21   |        | Tirumalagiri       | Officers Colony      | 11KV       | C-VI                 | 12:58 | 15:08 | 2:10     | EL,OL            | No Visible Fault (Due to heavy Rain)                               | No  |    |
| 22   |        | H.M.T.             | Chinthal             | 11KV       | VI                   | 14:05 | 16:40 | 2:35     | EL               | Tree branches fallen on lines at Chinthal                          | No  |    |
| 23   |        | R.P.Nilayam        | Saraswathi Nagar     | 11KV       | C-VI                 | 13:03 | 14:50 | 1:47     | EL,OL            | Coconut tree branch fallen on lines at Saraswathi Nagar            | No  |    |
| 24   |        | R.P.Nilayam        | Venkatapuram         | 11KV       | C-VI                 | 13:31 | 15:12 | 1:41     | EL               | Tree branches fallen on lines at Venkatapuram                      | No  |    |
| 25   |        | Allwyn             | Crown Casting        | 11KV       | IV                   | 13:50 | 17:46 | 3:56     | EL               | No Visible Fault (Due to heavy Rain)                               | Partial fdr charged at 16:40Hrs & remaining loads added on 11KV Lodha fdr |    |
| 26   |        | Lalaguda           | Lalapet              | 11KV       | V                    | 13:45 | 16:05 | 2:20     | EL               | Tree branches fallen on lines at Ram Theater                       | No  |    |
| 27   |        | Pragatools         | Raj Foods            | 11KV       | VI                   | 13:23 | 14:30 | 1:07     | EL               | No Visible Fault (Due to heavy Rain)                               | No  |    |
| 28   |        | Pragatools         | Nagarjuna Signode    | 11KV       | VI                   | 13:25 | 18:10 | 4:45     | EL               | Tree branches fallen on lines & LT line snapped at IDA, Kukatpally | No  |    |
| 29   |        | Hakimpet           | Bollaram PS          | 11KV       | C-VI                 | 13:55 | 15:25 | 1:30     | EL               | No Visible Fault (Due to heavy Rain)                               | No  |    |
| 30   |        | Macha Bollaram     | Radha Sathsang       | 11KV       | C-VI                 | 13:15 | 14:35 | 1:20     | Auto Recloser    | No Visible Fault (Due to heavy Rain)                               | No  |    |
| 31   |        | Prashasan Nagar    | Nandagiri Hills      | 11KV       | X                    | 15:50 | 17:30 | 1:40     | EL               | Tree branches fallen on lines at Nandagiri Hills                   | No  |    |
| 32   |        | Jana Priya         | Bharath Nagar        | 11KV       | X                    | 16:11 | 17:30 | 1:19     | All Indication   | No Visible Fault (Due to heavy Rain)                               | No  |    |
| 33   |        | Srinagar Colony    | Kamalapuri Colony    | 11KV       | X                    | 15:22 | 19:44 | 4:22     | EL,OL            | Cable End Kit failed at Krishna Nagar A-Block                      | No  |    |
| 34   |        | Road No.12         | Kanaka Durga         | 11KV       | X                    | 13:27 | 14:40 | 1:13     | EL               | No Visible Fault (Due to heavy Rain)                               | No  |    |
| 35   |        | Road No.12         | Chiran Palace        | 11KV       | X                    | 13:27 | 18:13 | 4:46     | EL               | Tree branches fallen on lines at Chiran Palace                     | No  |    |
| 36   |        | Chinthal           | Caption Gas          | 11KV       | VI                   | 13:20 | 18:30 | 5:10     | EL               | Tree branches fallen on lines at Various Locations                 | No  |    |
| 37   |        | Addagutta          | Hanuman Temple       | 11KV       | C-VI                 | 17:10 | 18:15 | 1:05     | EL,OL-Bph        | No Visible Fault (Due to heavy Rain)                               | Partial fdr charged & remaining loads added on 11KV Ramser Café fdr       |    |
| 38   |        | I.D.P.L.           | I.E.                 | 11KV       | VI                   | 13:30 | 15:30 | 2:00     | EL,OL            | No Visible Fault (Due to heavy Rain)                               | No  |    |
| 39   |        | I.D.P.L.           | S.V.C.I.E            | 11KV       | VI                   | 13:45 | 17:00 | 3:15     | OL-Rph           | Faulty HT service CT PT at Plot No.15B                             | No  |    |
| 40   |        | MLA Colony         | Cine Ghar            | 11KV       | X                    | 17:02 | 18:12 | 1:10     | EL,OL-R&Bph      | Jumper cut at V-6 Channel  | No  |    |
| 41   |        | Jubilee Hills      | Jubilee Hills        | 11KV       | X                    | 15:05 | 17:15 | 2:10     | EL,OL-Rph        | No Visible Fault (Due to heavy Rain)                               | Arranged B/F on 11KV UCO Bank fdr   |    |
| 42   |        | Jubilee Hills      | P.E.I. UG            | 11KV       | X                    | 15:30 | 17:40 | 2:10     | EL,OL            | No Visible Fault (Due to heavy Rain)                               | No  |    |
| 43   |        | LV Prasad Marg     | Annapurna Studio     | 11KV       | X                    | 18:21 | 19:36 | 1:15     | EL,OL-Rph        | No Visible Fault (Due to heavy Rain)                               | No  |    |
| 44   |        | Prashasan Nagar    | Journalist Colony    | 11KV       | X                    | 17:01 | 18:06 | 1:05     | EL,OL-Rph        | No Visible Fault (Due to heavy Rain)                               | No  |    |
| 45   |        | Osm. University    | Ladies Hostel        | 11KV       | V                    | 17:20 | 20:10 | 2:50     | OL-Bph           | Jumper cut in O.U  | Arranged B/F on 11KV Ravindra Nagar fdr                                   |    |
| 46   |        | Bowenpally         | Plassy Line          | 11KV       | VI                   | 17:10 | 18:10 | 1:00     | EL               | No Visible Fault (Due to heavy Rain)                               | Arranged partial loads B/F on 11KV Ali Complex fdr                        |    |
| 47   |        | Film Nagar         | Apollo               | 11KV       | X                    | 17:02 | 18:10 | 1:08     | EL,OL-Rph        | Tree branches fallen on ilnes near SS                              | No  |    |
| 1    |        |                    | Hyderguda            | Hyderguda  | 11KV                 | III   | 13.35 | 14.59    | 01.24            | EL,OL-R&Bph  | No Visible Fault (Due to heavy Rain)                                      | No |
| 2    |        |                    | Moosarambagh         | SBI Colony | 11KV                 | VIII  | 13:10 | 14:50    | 1:40             | OL-R&Bph   | No Visible Fault (Due to heavy Rain)                                      | No |
| 3    |        |                    | Chanchalguda         | Arya Samaj | 11KV                 | VIII  | 12:48 | 15:45    | 2:57             | EL,OL  | Tree fallen on lines at Ameera Fathima Masjid                             | No |



| S.No | Circle          | Name of 33/11KV SS | Name of 11 KV Feeder | Vol          | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown  | Alternate Supply Arranged  |    |
|------|-----------------|--------------------|----------------------|--------------|----------------------|-------|-------|----------|------------------|---|--|----|
| 4    | HYD S           | Chanchalguda       | ACP Office           | 11KV         | VIII                 | 13:45 | 15:33 | 1:48     | EL,OL-Rph        | Tree fallen on lines at ACP Office                              | No   |    |
| 5    |                 | Moosarambagh       | Dilsukh Nagar        | 11KV         | VIII                 | 13:28 | 14:58 | 1:30     | EL               | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 6    |                 | Santosh Nagar      | Rein Bazar           | 11KV         | VIII                 | 15:28 | 16:43 | 1:15     | EL,OL-Y&Bph      | O/G Jumper cut at SS  | No   |    |
| 7    |                 | Malakpet B-Block   | Akber Bagh           | 11KV         | VIII                 | 13:14 | 17:10 | 3:56     | EL,OL-Rph        | Tree branches fallen on lines at Akber Bagh                     | No   |    |
| 8    |                 | Teegalaguda        | Shankar Nagar        | 11KV         | VIII                 | 13:18 | 15:30 | 2:12     | OL-Rph           | Tree branches fallen on lines at Shakar Nagar                   | No   |    |
| 9    |                 | Asmangadh          | Shiva Ganga          | 11KV         | VIII                 | 12:53 | 14:42 | 1:49     | EL               | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 10   |                 | Asmangadh          | Jaya Nagar           | 11KV         | VIII                 | 12:35 | 14:14 | 1:39     | EL               | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 11   |                 | Hyderguda          | A.G.Colony           | 11KV         | III                  | 16:11 | 17:45 | 1:34     | EL               | Disc Insulator flash over at Nalanda Nagar                      | No   |    |
| 12   |                 | Asmangadh          | Saidabad Colony      | 11KV         | VIII                 | 12:40 | 14:12 | 1:32     | EL               | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 13   |                 | Chanchalguda       | Arya Samaj           | 11KV         | VIII                 | 18:23 | 19:43 | 1:20     | EL,OL-Rph        | Disc flash over at Mani Kanta Tower                             | No   |    |
| 14   |                 | Gunj               | Muntaj College       | 11KV         | VIII                 | 14:25 | 17:10 | 2:45     | EL               | Breaker fault at SS   | Arranged B/F on 11KV Hanuman Temple fdr                            |    |
| 15   |                 | Gunj               | Palton               | 11KV         | VIII                 | 14:30 | 16:55 | 2:25     | OL-R&Bph         | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 16   |                 | Gunj               | Race Course          | 11KV         | VIII                 | 16:30 | 19:52 | 3:22     | OL-Rph           | Jumper Cut at Court Compound                                    | No   |    |
| 17   |                 | Asmangadh          | Saidabad Colony      | 11KV         | VIII                 | 15:25 | 20:03 | 4:38     | EL,OL-Rph        | HG fuse blown at R.S.Brothers                                   | No   |    |
| 18   |                 | Salarjung          | Sadath Nagar         | 11KV         | VIII                 | 20:35 | 22:05 | 1:30     | EL               | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 19   |                 | Asmangadh          | Jaya Nagar           | 11KV         | VIII                 | 17:24 | 18:50 | 1:26     | OL-Rph           | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 20   |                 | Asmangadh          | Saraswathi Nagar     | 11KV         | VIII                 | 12:45 | 14:16 | 1:31     | EL,OL-Rph        | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 21   |                 | Asmangadh          | P&T Colony           | 11KV         | VIII                 | 12:59 | 14:14 | 1:15     | OL-R&Bph         | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 22   |                 | Asmangadh          | Asmangadh            | 11KV         | VIII                 | 13:03 | 14:44 | 1:41     | OL-R&Bph         | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 23   |                 | Asmangadh          | Saibaba Temple       | 11KV         | VIII                 | 17:24 | 19:37 | 2:13     | OL-R&Bph         | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 1    |                 | HYD C              | Asif Nagar           | N.S.F Colony | 11KV                 | VII   | 05.16 | 07.38    | 02.22            | EL,OL-Bph   | 3 No. HT Jumpers cut at O/G AB Switch, Mee Seva DTR & AB Hotel DTR | No |
| 2    |                 |                    | Indira Park          | Kavadiguda   | 11KV                 | I     | 12.50 | 14.45    | 01.55            | EL,OL-Bph   | Street Light line touching to Pole at Balaji Sweet House           | No |
| 3    |                 |                    | Industrial Area      | RTC X Road   | 11KV                 | II    | 13.20 | 14.45    | 01.25            | EL  | No Visible Fault (Due to heavy Rain)                               | No |
| 4    | Amberpet        |                    | Tilak Nagar          | 11KV         | II                   | 13:25 | 14:55 | 1:30     | EL               | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 5    | Amberpet        |                    | Zindatilismath       | 11KV         | II                   | 13:25 | 14:55 | 1:30     | EL               | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 6    | Industrial Area |                    | Azamabad I.E         | 11KV         | II                   | 13:25 | 14:50 | 1:25     | EL               | Tree branches fallen on lines at Post Office                    | No   |    |
| 7    | Bathkammakunta  |                    | Ahobilmutt           | 11KV         | II                   | 13:30 | 15:10 | 1:40     | EL               | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 8    | Amberpet        |                    | Golnaka              | 11KV         | II                   | 13:40 | 14:45 | 1:05     | EL               | Tree branches fallen on lines at Golnaka                        | No   |    |
| 9    | Zamistanpur     |                    | Jamai Osmania        | 11KV         | II                   | 13:38 | 15:17 | 1:39     | EL               | Tree branches fallen on lines at Jamai Osmania                  | No   |    |
| 10   | ITI Mallepally  |                    | Afzal Sagar          | 11KV         | VII                  | 13:09 | 16:03 | 2:54     | EL               | Pin Insulator flash over at Pani Ground                         | No   |    |
| 11   | Osm. University |                    | Boudha Nagar         | 11KV         | II                   | 13:55 | 15:35 | 1:40     | EL,OL-Rph        | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 12   | HYD C           | ITI Mallepally     | Anwar UI-Uloom       | 11KV         | VII                  | 14:14 | 15:16 | 1:02     | EL,OL            | Tree branches fallen on lines at Anwar UI-Uloom College         | No   |    |
| 13   |                 | Industrial Area    | R.O.M.               | 11KV         | II                   | 14:05 | 16:10 | 2:05     | EL,OL-Rph        | Tree branches fallen on lines at Achaiah Nagar                  | No   |    |
| 14   |                 | ITI Mallepally     | Anjuman              | 11KV         | VII                  | 13:44 | 16:52 | 3:08     | EL,OL            | Tree fallen on lines at Siddique Function Hall                  | No   |    |
| 15   |                 | S.D.Hospital       | Ahmed Nagar Cable    | 11KV         | VII                  | 13:57 | 15:25 | 1:28     | EL,OL-Rph        | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 16   |                 | Golnaka            | Brahman Hostel       | 11KV         | II                   | 12:56 | 15:30 | 2:34     | EL,OL-Bph        | Faulty 11KV Ramalayam feeder loads                              | No   |    |
| 17   |                 | Vittalwadi         | Kamineni Hospital    | 11KV         | I                    | 12:45 | 13:50 | 1:05     | EL,OL            | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 18   |                 | Vittalwadi         | ICICI Bank           | 11KV         | I                    | 14:15 | 16:53 | 2:38     | EL               | Tree branches fallen on lines & Jumper cut at ICICI Bank        | No   |    |
| 19   |                 | Vittalwadi         | YMCA                 | 11KV         | II                   | 14:10 | 16:30 | 2:20     | EL               | Tree branches fallen on lines & Jumper cut at Rama Krishna Apts | No   |    |
| 20   |                 | Amberpet           | Tilak Nagar          | 11KV         | II                   | 15:21 | 16:33 | 1:12     | OL-R&Yph         | Tree branches fallen on lines at K.R.Apts                       | No   |    |
| 21   |                 | Nizam College      | Little Flower        | 11KV         | I                    | 13:32 | 14:54 | 1:22     | EL               | No Visible Fault (Due to heavy Rain)                            | No   |    |
| 22   |                 | Nizam College      | Galaxy Hotel         | 11KV         | I                    | 13:33 | 14:53 | 1:20     | EL               | No Visible Fault (Due to heavy Rain)                            | No   |    |

| S.No | Circle     | Name of 33/11KV SS | Name of 11 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication                         | Cause of Breakdown                                  | Alternate Supply Arranged                   |
|------|------------|--------------------|----------------------|------|----------------------|-------|-------|----------|--|---|---|
| 23   | HYD C      | Nizam College      | Brand Factory        | 11KV | I                    | 13:38 | 15:00 | 1:22     | EL                                       | No Visible Fault (Due to heavy Rain)                | No  |
| 24   |            | S.D.Hospital       | Humayun Nagar        | 11KV | VII                  | 14:37 | 16:33 | 1:56     | OL-R&Yph                                 | No Visible Fault (Due to heavy Rain)                | No  |
| 25   |            | S.D.Hospital       | Khadi Bandar         | 11KV | VII                  | 14:51 | 17:05 | 2:14     | EL,OL-R&Yph                              | No Visible Fault (Due to heavy Rain)                | No  |
| 26   |            | S.D.Hospital       | Ahmed Nagar OH       | 11KV | VII                  | 15:52 | 17:07 | 1:15     | EL,OL-Rph                                | No Visible Fault (Due to heavy Rain)                | No  |
| 27   |            | Narayanguda        | City Central Library | 11KV | I                    | 13:35 | 17:05 | 3:30     | EL                                       | Jumper cut at City Central Library                  | No  |
| 28   |            | Lumbini Park       | Avanthi Nagar        | 11KV | I                    | 13:25 | 14:30 | 1:05     | All Indication                           | No Visible Fault (Due to heavy Rain)                | No  |
| 29   |            | Indira Park        | A.V.College          | 11KV | I                    | 13:25 | 15:45 | 2:20     | EL                                       | Tree branches fallen on lines at A.V.College        | No  |
| 30   |            | Lumbini Park       | T.T.D.               | 11KV | I                    | 13:33 | 14:55 | 1:22     | EL,OL-Rph                                | No Visible Fault (Due to heavy Rain)                | No  |
| 31   |            | Jawahar Nagar      | Jawahar Nagar        | 11KV | I                    | 13:25 | 15:30 | 2:05     | EL                                       | No Visible Fault (Due to heavy Rain)                | No  |
| 32   |            | Narayanguda        | Chikkadpally         | 11KV | II                   | 13:23 | 15:05 | 1:42     | Auto Recloser                            | No Visible Fault (Due to heavy Rain)                | No  |
| 33   |            | Narayanguda        | Narayanguda          | 11KV | II                   | 13:23 | 14:50 | 1:27     | EL,OL-Rph                                | No Visible Fault (Due to heavy Rain)                | No  |
| 34   |            | Vittalwadi         | Basanth Colony       | 11KV | II                   | 13:15 | 14:44 | 1:29     | EL,OL-R&Bph                              | No Visible Fault (Due to heavy Rain)                | No  |
| 35   |            | Vittalwadi         | APCO                 | 11KV | II                   | 13:23 | 15:18 | 1:55     | EL,OL-Bph                                | No Visible Fault (Due to heavy Rain)                | No  |
| 36   |            | Industrial Area    | Barkathpura          | 11KV | II                   | 13:20 | 19:15 | 5:55     | EL                                       | Tree branches fallen on lines at Padma Colony       | No  |
| 37   |            | ITI Mallepally     | P.S.Nagar            | 11KV | VII                  | 13:14 | 17:34 | 4:20     | EL                                       | Tree branches fallen on lines at P.S.Nagar          | No  |
| 38   |            | S.D.Hospital       | Crescent Hospital    | 11KV | VII                  | 13:14 | 16:07 | 2:53     | EL,OL-Bph                                | Tree branches fallen on lines at Crescent Hospital  | No  |
| 39   |            | S.D.Hospital       | Ahmed Nagar OH       | 11KV | VII                  | 13:16 | 15:36 | 2:20     | EL                                       | Tree branches fallen on lines at Ahmed Nagar        | No  |
| 40   |            | Nampally           | V.N.C.               | 11KV | VII                  | 13:17 | 18:13 | 4:56     | EL                                       | Tree branches fallen on lines at Vijay Nagar Colony | No  |
| 41   |            | Nampally           | Pearl Regency        | 11KV | VII                  | 13:26 | 15:40 | 2:14     | EL                                       | Tree branches fallen on lines at Nampally           | No  |
| 42   |            | Jawahar Nagar      | Post Office          | 11KV | I                    | 14:05 | 15:35 | 1:30     | EL,OL-Rph                                | Tree branches fallen on lines at Y-Junction         | No  |
| 43   |            | Chilkaiguda        | Golconda X Road      | 11KV | II                   | 13:06 | 17:05 | 3:59     | EL                                       | Phase to phase problem at Sahara Banquit Hall       | Arranged B/F on 11KV Dayara Market          |
| 44   |            | Chilkaiguda        | Parsigutta           | 11KV | II                   | 14:16 | 18:05 | 3:49     | EL                                       | Big Tree fallen on lines at P.G.College             | No  |
| 45   |            | Jawahar Nagar      | J.N.Home             | 11KV | I                    | 13:45 | 16:55 | 3:10     | OL-R&Bph                                 | End Kit failed at J.N.Home                          | Arranged B/F on 11KV Ambedkar Nagar fdr     |
| 46   |            | Bathkammakunta     | Ahobilmutt           | 11KV | II                   | 16:40 | 17:58 | 1:18     | EI                                       | Tree branches fallen on lines at Hotel Management   | No  |
| 47   |            | Lumbini Park       | A.I.R.               | 11KV | I                    | 16:03 | 18:13 | 2:10     | EL                                       | Pin Insulator flash over at All India Radio         | No  |
| 48   |            | Langerhouse        | Fathe Darwaza        | 11KV | VII                  | 15:10 | 16:15 | 1:05     | EL,OL-Bph                                | No Visible Fault (Due to heavy Rain)                | No  |
| 49   |            | A.S.R.Raju Nagar   | J.K.Nagar            | 11KV | VII                  | 14:50 | 17:37 | 2:47     | EL,OL                                    | Disc Insulator flash over at M.M.H. Hospital        | No  |
| 50   |            | Fever Hospital     | BKP Bus Depot        | 11KV | II                   | 14:55 | 16:15 | 1:20     | EL                                       | No Visible Fault (Due to heavy Rain)                | No  |
| 51   |            | Fever Hospital     | Tourist Hotel        | 11KV | II                   | 14:55 | 16:50 | 1:55     | EL                                       | No Visible Fault (Due to heavy Rain)                | No  |
| 52   |            | Golnaka            | Nehru Nagar          | 11KV | II                   | 15:05 | 17:45 | 2:40     | EL                                       | No Visible Fault (Due to heavy Rain)                | Arranged B/F on 11KV Moulana Azad Nagar fdr |
| 53   |            | ITI Mallepally     | P.S.Nagar            | 11KV | VII                  | 18:08 | 20:22 | 2:14     | EL                                       | Tree fallen on lines at Water Works Office          | No  |
| 54   |            | Jawahar Nagar      | Anjaiah Nagar        | 11KV | I                    | 17:05 | 18:15 | 1:10     | OL-Bph                                   | Tree branches fallen on lines at Hanuman Temple     | No  |
| 55   |            | Nampally           | Bada Masjid          | 11KV | VII                  | 14:05 | 16:05 | 2:00     | EL                                       | Pin Insulator flash over at Afzal Sagar             | No  |
| 56   |            | Nampally           | FAPPCI               | 11KV | VII                  | 13:48 | 16:59 | 3:11     | EL                                       | Pin Insulator flash over at FAPCI Building          | No  |
| 57   | Tolichowki | B.S.N.L            | 11KV                 | VII  | 23:30                | 0:40  | 1:10  | EL       | Cable fault 2No DTR's kept of IAS Colony | No  |   |