

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1		1		1			
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	5	0	5	0	5	0	0	
	Grand Total	1082	6468	1	9	0	9	0	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 01.11.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Polepally	Konded	33KV	Jadcherla	14.53	15.29	00.36		Due to LA Blast		Alternate supply arranged from 33KV Gangapur at 15:29Hrs

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 01.11.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Karkonda	Karkonda	11KV	Jadcherla	11.32	13.19	01.47		HT/LT Near Mothulakunta Side	-
1	NLG	Kethepally	Inupamula	11KV	Nalgonda	02.25	07.50	05.25	E/L	AB switch problem at Jamail thota	-
2		Palem	Ogodu	11KV	Nalgonda	10.55	14.35	03.40	E/L	11Kv Jumper cut	-
3		Koppol	Bheemaram	11KV	Nalgonda	13.35	15.30	01.55	E/L	11Kv Jumper cut	-
4		N B Gudem	Redlakunta	11KV	Huzurnagar	05.40	08.00	02.20	E/L	11Kv Line Snapped	-
1	RR N	Kolthur	Mallannakatta	11KV	Medchal	05.30	07.00	01.30		11KV Jumper cut and replaced at Srinivas Reddy Thota, Potharam Road	-
2		Kolthur	Anantharam	11KV	Medchal	10.15	12.10	01.55		11KV Conductor Snapped and replaced at Srinivas Yadav Thota	-
1	RR E	IDA Uppal	Kamakshipuram	11KV	Habsiguda	01.35	02.28	00.53		11KV Cable failed at Happy Bar & B/F from 11KV Ram Reddy Nagar feeder	-
1	HYD N	Clock Tower	Minerva	11KV	Sec-Bad	13.58	15.20	01.22	EL	Faulty DTR at Anjali Theater, due to fire accident	-