

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		4		4		4			
3	MDK	107	933		1		1		1			
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	10	0	10	0	10	0	0	
	Grand Total	1082	6468	0	16	0	16	0	16	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 06.11.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Maddur	Dorepally	11KV	Narayanapet	08.50	11.59	03.09		Break Down due to 11KV insulator failed	-
2		NARAYANPET	YADGIR ROAD	11KV	Narayanapet	13.45	14.15	00.30		DUE TO TREE Fallen ON THE LINE	-
1	NLG	Yerkaram	Yerkaram	11KV	Suryapet	08.00	09.25	01.25	E/L	Insulato failed	-
2		Chilukur	R C Nagar	11KV	Huzurnagar	13.00	14.45	01.45	EL	11 KV LINE SNAPPED	-
3		Pamanagundla	Pittampally	11KV	Nalgonda	01.00	07.28	06.28	EL	Tree branches touches to 11KV line	-
4		Gudipally	Gudipally	11KV	Devarakonda	11.30	15.10	03.40	EL	11 KV Jumper Cutt	-
1	MDK	EPIP-I	ORTIN	11KV	Patncheru	11.22	13.50	02.28		BD due to Conductor snapped	-
1	SDP	Gowaram SS	Gowaram SS	11KV	Gajwel	10.50	12.20	01.30		11KV LV Limb rectified	-
2		Adivimajeedpally SS	Adivimajeed pally	11KV	Gajwel	01.30	10.25	09.55		Parrot has fallen	-
3		Rampur SS	Zapthi lingareddypally	11KV	Gajwel	07.00	13.30	06.30		11 KV Line cut	-
1	RR N	Subhash Nagar	Jeedimetla	11KV	Medchal	16.25	17.40	01.15	BD	11KV Disc failed at Bheema Pride Apartments	-
1	RR E	Kushaiguda	Kamala Nagar	11KV	Sainikpuri	03.30	06.40	03.10		Lorry Dashed 1 no 11Kv Pole on 1 No LT Pole Dammage at South Kamala Nagar Sony Center (AE)	-
1	HYD N	Bowenpally	Pipe Line Road	11KV	VI	11.50	13.05	01.15	OL-Y&Bph	AB Switch sparking & Jumper burnt out at Ayyamgari Bakery	-----
2		Gymkhana	Apollo	11KV	C-VI	15.18	16.30	01.12	EL,OL-R&Yph	HT Jumper cut at SS	-----
3		Road No.12	N.B.T Nagar	11KV	X	16.00	17.30	01.30	EL,OL-Bph	No Visible Fault	-----
1	HYD C	I.T.I Mallepally	Zahira Masjid	11KV	VII	01.05	02.23	01.18	EL,OL	Conductor snapped at Vijaya Nagar Colony	-