

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 07.11.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
<b>NIL</b>												

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Jadcherla	Nagasala	11KV	Jadcherla	10.50	15.45	04.55		11KV Jumper cut near Nasurlabad	No
2		Narayanpet	Yadgir Road	11KV	Narayanapet	07.30	08.15	00.45		Due to tree interruption on the line	No
1	NLG	Akaram	Vaddipamula	11KV	Nalgonda	11:15	16:15	5:00	EL	Jumper Cut	No
2		B.Chandupatla	Chandupatla	11KV	Suryapet	06.40	10.00	03.20	EL	Conductor Snapped	No
3		Datherpally	Jangampally	11KV	Bhongir	13.20	14.40	01.20	EL	11kv Insulator Failed near Jangampally Village	No
1	SDPT	Marpadaga	Sirsingalla AGL	11KV	Gajwel	6:30	8:40	2:10		11KV Line cut	No
1	RR S	JNTU	SP Nagar	11KV	Gachibowli	16:10	17:23	1:13		11KV UG cable damaged at BS Nagar	No
1	RR N	Kandlakoya	KV Reddy Nagar	11KV	Medchal	2:36	3:45	1:09		Tree fallen on the 11KV Line at Hindustan Company	No
1	HYD C	Asif Nagar	Kakatiya Nagar	11KV	VII	20.18	23.02	02.44	EL,OL-Yph	UG Cable fault at Military Wall ( Kept off 1No DTR at Military Wall )	20:18Hrs 11KV Military Hospital fdr tripped & removed faulty loads of 11KV Kakatiya Nagar fdr from 11KV Military Hospital fdr & 23:02Hrs 11KV Kakatiya Nagar fdr loads again added on 11KV Military Hospital fdr ( 23:45Hrs 3No DTR's charged )