

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933		1		1		1			
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 08.11.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	RR S				NIL							-
5	RR N				NIL							-
6	RR E				NIL							-
7	HYD				NIL							-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 08.11.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Annaram	Kothagudem	11kv	Suryapet	06.00	09.15	03.15	E/L	Insulator failed	-
2		Panhangi	Panhangi Agl	11kv	Choutuppal	00.05	07.22	07.17	EL/OL	11 kv Insulator failed & 11 kv Jumper snapped at thukapally Shankaraiah well near Shanigalagutta village	-
3		Tekulasomaram	Edullagudem	11kv	Choutuppal	05.00	07.00	02.00	EL/OL	11 KV Insulator failed near Edullagudem village	-
1	MDK	Bollaram-I	Kythan	11kv	Patancheru	19.20	20.20	01.00		B/d due to Conductor snapped	-
1	SDPT	Pamulaparthi SS	Ippalaguda Feeder	11kv	Gajwel	15.30	17.30	02.00		Disk fail	-
2		Mulugu SS	Narsampally AGL	11kv	Gajwel	11.56	15.15	03.20		11KV Line Cut	-
1	RR N	UMCC	Mini Industries	11kv	Medchal	17.00	18.15	01.15		11KV jumper cut	-
1	HYD S	Falaknuma	Falaknuma OH	11kv	III	16.38	17.55	01.17	All Indication	PTR-2 buchloz Relay act in SS	Arranged B/F on 11KV Jangammet AB Cable fdr