

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	2	1	2	1	2			
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT				5		5		5			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>12</b>	<b>2</b>	<b>12</b>	<b>2</b>	<b>12</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 11.11.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Kollur	33KV	Jadcherla	05.30	09.00	03.30	E/L	Jumer cut near Pitticash Industri	Kollur	No
1	RR N	132KV Medchal	Aliabad	33KV	Medchal	7:45	8:30	0:45		33KV Disc failed at near Ayushman Company	Aliabad	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Palem	Ogodu	11KV	Nalgonda	12:35	1:35	1:00	EL	Insulator failed	No
2		Guraladandi	Jampally	11KV	Bhongir	07.30	10.55	03.25	EL	11kv Disc failed	No
1	SDPT	Thotapally	Thotapally Agl	11KV	Husnabad	3:30	6:00	2:30		Jumper cut	No
2		Bekkal	Kondapur	11KV	Husnabad	03.30	06.20	02.50		Insulator failed	No
3		Pamulaparthi ss	Ippalagudem feeder	11KV	Gajwel	16.20	17.25	01.05		Peacock fallaen	No
4		Nacharam SS	Nacharam Town Feeder	11KV	Gajwel	06.19	09.10	02.51		Tree fallaen on the line	No
5		Dommata SS	Gajulapally Feeder	11KV	Gajwel	15:50	19:05	3:15		11KV Jumper cut	No
1	RR N	Petbasheerabad	Satyam Enclave	11KV	Medchal	9:45	10:15	0:30	EL	11KV Line AB Switch Opened at Venkateswara Garden	No
2		Kandlakoya	KV Reddy Nagar	11KV	Medchal	12.30	13.20	00.50	EL	Tree fallen on the 11KV Line at Kompally Bridge	No
1	HYD N	Prashanth Nagar	Andhra Jyothi	11KV	VI	09.05	10.15	01.10	OL-R&Bph	AB Cable fault at Shakthipuram	No
1	HYD S	Hyderguda	Janapriya OH	11KV	III	19.40	21.23	01.43	EL,OL	I/C Cable fault at SS	Arranged B/F on 11KV A.G.Colony feeder
1	HYD C	Chilkaiguda	44 Bus Stop	11KV	II	23.30	01.05	01.35	EL	No Visible Fault	00:40 Hrs partial feeder charged