

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	1	1	1	1	1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	1	4	1	4	1	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		5		5		5			
3	MDK	107	933									
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	10	0	10	0	10	0	0	
	Grand Total	1082	6468	1	14	1	14	1	14	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.11.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV Medchal	Steel Mill	33KV	Medchal	12:56	13:47	0:51		33KV Line AB Switch Opened at Steel Mill Company (Internal Problem)	Steel Mill	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Ponnakal	Rachala	11KV	Narayanapet	11.30	14.40	03.10		11KV Jumper cut near Dubbapally Vagu	No
2		Pedda Revally	Industrial	11KV	Narayanapet	11.20	13.47	02.27		Tree fallen on the line near Hemajipur	No
1	NLG	Eduloor	Naregudem	11KV	Nalgonda	4:30	10:30	6:00	EL	11KV Jumper cut	No
2		Eduloor	Madaram	11KV	Nalgonda	05.20	10.30	05.10	EL	11KV Jumper cut	No
3		Kattangur	Dugenelly	11KV	Nalgonda	10.50	14.30	03.40	EL	Momentary fault	No
4		Rajupeta	B.V.Gudem	11KV	Nalgonda	15.20	16.00	00.40	EL	11KV Jumper cut	No
5		Penpahad	SR Palem	11KV	Suryapet	5:00	8:40	3:40	EL	Insulator failed	No
1	SDPT	Gonepally	Ramunipatla	11KV	Siddipet	7:20	7:50	0:30		B/d Lc.No 23266	No
2		Ragothampally	Gosanpally	11KV	Siddipet	08.20	08.50	00.30		B/d Jumper cut Lc.No 4842	No
3		Thotapally	Mallampally	11KV	Husnabad	05.05	06.15	01.10		Jumper cut	No
1	RR N	Thumkunta	Thumkunta	11KV	Medchal	7:45	9:50	2:05		11KV Jumper Opened at SC Colony(100KVA T/F Problem)	No
1	RR E	Narapally	Prathap Singaram	11KV	Keesara	13:35	15:15	1:40		Lizard fallen on 11KV line AB switch at Sathethalliguda	No
1	HYD N	Road No.13	Road No.1	11KV	X	15.55	17.02	01.07	EL	Brass Patti burntout at Sarver Hotel	No
2		Seethaphal Mandi	Namala Gundu	11KV	V	23:50	1:00	1:10	OL-Rph	Rat fallen on line Insulator at Namala Gundu	No