

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	2	1	2	1	2			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		4		4		4			
	Total	606	3055	1	8	1	8	1	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	3	2	3	2	3			
2	NLG	144	988		4		4		4			
3	MDK	107	933		2		2		2			
4	SDPT			1	10	1	10	1	10			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	19	3	19	3	19	0	0	
	Grand Total	1082	6468	4	27	4	27	4	27	0	0	

TSSPDCL - LMRC / Corporate office

Date: 16.11.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Alampur	Shanthinagar -2	33KV	Gadwal	09.46	11.10	01.24	E/L	Bird Fallen on the line near Bonkur (V)	Shanthinagar -2	-
2		Gadwal	Maldakal	33KV	Gadwal	15.45	18.55	03.10	E/L	Insulator Damaged at Maldakal	Maldakal	-
1	SDPT	Gajwel	KDA	33KV	Gajwel	10.05	15.20	05.15		BD (Frequently Tripping)	KDA	-
1	RR N	132KV Medchal	33KV Steel Mill	33KV	Medchal	09.59	12.30	02.31	BD	No visible Fault	33KV Steel Mill	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 16.11.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Gundumal	Appaipally	11KV	Mahabubnagar	06.00	10.00	04.00		Due to 11KV Conductor cut	-
2		Nancherla	Juvulapally	11KV	Mahabubnagar	10.24	15.00	04.36		Due to 11KV line snapped and cut	-
3		Vennached	Lingaipally	11KV	Mahabubnagar	12.34	13.23	00.49		Due to 11KV line snapped and cut	-
1	NLG	Kethepalyi	Inupamula	11KV	Nalgonda	08.00	09.45	01.45		11 KV Jumper Cut	-
2		Nakrekal	Marrur	11KV	Nalgonda	10.00	13.15	03.15		11 KV Jumper Cut	-
3		Palem	Ogodu	11KV	Nalgonda	11.30	13.17	01.47		Tree Fallen on the 11 KV Line	-
4		Aitipamula	Gangadevigudem	11KV	Nalgonda	09.05	14.04	04.59		11 KV Jumper Cut	-
1	MDK	Patancheru Town	MIA-II	11KV	Patancheru	12.30	13.20	00.50		BD due to Jumper cut	-
2		Kistareddypet	Industrial	11KV	Patancheru	09.20	11.40	02.20		BD due to Tree branches fallen on line	-
1	SDPT	SINGATAM	DACHARAM	11KV	Gajwel	09:59	15:39	5:48		11KV LINE CUT	
2		WARDARAJPUR	SVPUR	11KV	Gajwel	18.35	18.55	00.20		11KV LINE CUT	
3		MD SHAPUR	MD SHAPUR	11KV	Gajwel	03.25	08.45	05.20		TREE BRACH WAS FALLEN ON THE 11KV LINE	
4		MARPADAGA	SIRSANAGANDLA AGL	11KV	Gajwel	11.26	14.46	03.20		TREE BRACH WAS FALLEN ON THE 11KV LINE	
5		POTHARAM	NAGARAM	11KV	Husnabad	04.48	00.00	09.36		BD, DUE TO TREE FALLEN ON 3 PH LINE	
6		REGULAPALLY	REGULAPALLY	11KV	Husnabad	13.40	00.00	00.43		B D, DUE TO JUMPER CUT	
7		Gurjakunta	Vechareni	11KV	Siddipet	07.12	03.36	03.36		B D DUE TO INSULATOR FAILURE	-
8		Mustyal	Cherial Town	11KV	Siddipet	07.12	08.24	01.12		B D, DUE TO TREE FALLEN ON LINE	-
9		Ragothampally	Gosanpally	11KV	Siddipet	02:15	08:50	06:35		B/D Tree branches folldown LC No.4845	-
10		Ragothampally	Ragothampally	11KV	Siddipet	03:20	08:33	05:13		B/D Tree branches folldown LC No.4846	-
1	RR N	Kompally	Jaibheri	11KV	Medchal	11.56	12.17	00.21	BD	11KV Line AB Switch Opened at CMR Boys Hostel(No Fault)	-
2		Athiwelly	PHI	11KV	Medchal	11.30	14.45	03.15	BD	11KV Pin Insulator Failed at Rekula Bavi	-
1	RR E	Uppal	Nava Bharath	11KV	Habsiguda	19.50	22.10	02.20		Line Petroling Done and Given Back Feeding from 11KV Metro Feeder	-
2		GKSR	Yamunnampet	11KV	Keesara	12.40	13.40	01.00		11KV Insulator fail at Yamunampet	-
1	HYD N	Chilalguda	Pragatools	11KV	V	20.15	21.35	01.20	EL,OL	Cable Jumper cut on 1st Line AB Switch	At 21:05 Hrs arranged partial B/F on 11KV R.L.H.Society feeder
2	HYD S	Durga Nagar	Prashanth Nagar	11KV	VIII	10.01	11.32	01.31	EL,OL-Rph	Cable fault	Arranged B/F on 11KV Sripuram Colony fdr
3		Miralam	Teegalakunta	11KV	III	10.45	12.12	01.27	EL	I/C Cable fault at Gudi-Ka-Dawakhana	Arranged B/F on 11KV Falaknuma UG feeder & 11KV N.S.Kunta fdr
4		Petlaburz	Chowk	11KV	III	22.45	01.00	02.15	EL	Cable fault at Chowk (1No. DTR Kept Off)	Arranged B/F on 11KV Gulzar House fdr